

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
5 - 1C	5127	Lab	2'x2' Suspended Ceiling Tile Flat	NAD	-	-	-	-
5 - 2A	5151A	Conference	Window Sill Caulk	NAD	-	-	-	-
5 - 2B	5114	Office	Window Sill Caulk	NAD	-	-	-	-
5 - 2C	5165	Bed	Window Sill Caulk	NAD	-	-	-	-
5 - 3A	5143	Closet	Wallboard	NAD	-	-	-	-
5 - 3B	5151A	Conference	Wallboard	NAD	-	-	-	-
5 - 3C	5-C-6	Corridor	Wallboard	NAD	-	-	-	-
5 - 4A	5143	Closet	Wallboard Compound	NAD	-	-	-	-
5 - 4B	5151A	Conference	Wallboard Compound	NAD	-	-	-	-
5 - 4C	5-C-6	Corridor	Wallboard Compound	NAD	-	-	-	-
5 - 5A	5151A	Conference	Wall Plaster Skim Coat	NAD	-	-	-	-
5 - 5B	5161	Bed	Wall Plaster Skim Coat	NAD	-	-	-	-
5 - 5C	5215	Work	Wall Plaster Skim Coat	NAD	-	-	-	-
5 - 6A	5151A	Conference	Wall Plaster Base Coat	NAD	-	-	-	-
5 - 6B	5161	Bed	Wall Plaster Base Coat	NAD	-	-	-	-
5 - 6C	5215	Work	Wall Plaster Base Coat	NAD	-	-	-	-
5 - 7A	5196	Storage	Glue w/6" Black Cove Base	NAD	-	-	-	-
5 - 7B	5100	Waiting	Glue w/6" Black Cove Base	NAD	-	-	-	-
5 - 7C	5121	Office	Glue w/6" Black Cove Base	NAD	-	-	-	-
5 - 8A	5143	Closet	2'x2' Suspended Ceiling Tile Bird Feet	NAD	-	-	-	-
5 - 8B	5107	Office	2'x2' Suspended Ceiling Tile Bird Feet	NAD	-	-	-	-
5 - 8C	5183	Bed	2'x2' Suspended Ceiling Tile Bird Feet	NAD	-	-	-	-
5 - 9A	5127	Lab	Sink Undercoating Black	NAD	-	-	-	-
5 - 9B	5112	Linen	Sink Undercoating Black	NAD	-	-	-	-
5 - 9C	5110	Lounge	Sink Undercoating Black	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
5 - 10A	5215	Work	Ceiling Plaster Skim Coat	NAD	-	-	-	-
5 - 10B	5206	Conference	Ceiling Plaster Skim Coat	NAD	-	-	-	-
5 - 10C	5203A	Restroom	Ceiling Plaster Skim Coat	NAD	-	-	-	-
5 - 11A	5215	Work	Ceiling Plaster Base Coat	NAD	-	-	-	-
5 - 11B	5206	Conference	Ceiling Plaster Base Coat	NAD	-	-	-	-
5 - 11C	5203A	Restroom	Ceiling Plaster Base Coat	NAD	-	-	-	-
5 - 12A	Hall at 5100	Corridor	Door Window Panel Putty	NAD	-	-	-	-
5 - 12B	Hall at 5-C-4	Corridor	Door Window Panel Putty	NAD	-	-	-	-
5 - 12C	Hall at Stair1	Corridor	Door Window Panel Putty	NAD	-	-	-	-
5 - 13A	5143	Closet	Red Fire Stop Caulk	NAD	-	-	-	-
5 - 13B	5158	Closet	Red Fire Stop Caulk	NAD	-	-	-	-
5 - 13C	5158	Closet	Red Fire Stop Caulk	NAD	-	-	-	-
5 - 14A	5143	Closet	Duct Seam Sealer	NAD	-	-	-	-
5 - 14B	5143	Closet	Duct Seam Sealer	NAD	-	-	-	-
5 - 14C	5158	Closet	Duct Seam Sealer	NAD	-	-	-	-
5 - 15A	5143	Closet	Duct Lagging	NAD	-	-	-	-
5 - 15B	5143	Closet	Duct Lagging	NAD	-	-	-	-
5 - 15C	5158	Closet	Duct Lagging	NAD	-	-	-	-
5 - 16A	5151A	Conference	Glue w/6" Gray Cove Base	NAD	-	-	-	-
5 - 16B	5216A	Restroom	Glue w/6" Gray Cove Base	NAD	-	-	-	-
5 - 16C	5159	Work	Glue w/6" Gray Cove Base	NAD	-	-	-	-
5 - 17A	5154	Lounge	Sink Undercoating Gray	NAD	-	-	-	-
5 - 17B	5216	Lab	Sink Undercoating Gray	NAD	-	-	-	-
5 - 17C	5216	Lab	Sink Undercoating Gray	NAD	-	-	-	-
5 - 18A	5206A	Mechanical	Fireproofing Spray - On	NAD	-	-	-	-
5 - 18B	5206A	Mechanical	Fireproofing Spray - On	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
5 - 18C	5206A	Mechanical	Fireproofing Spray - On	NAD	-	-	-	-
5 - 19A	5205	On Call	Glue w/6" Blue Cove Base	NAD	-	-	-	-
5 - 19B	5205	On Call	Glue w/6" Blue Cove Base	NAD	-	-	-	-
5 - 19C	5205	On Call	Glue w/6" Blue Cove Base	NAD	-	-	-	-
5 - 20A	5202	Mechanical	Glue w/6" Brown Cove Base	NAD	-	-	-	-
5 - 20B	5200F	Office	Glue w/6" Brown Cove Base	NAD	-	-	-	-
5 - 20C	5200F	Office	Glue w/6" Brown Cove Base	NAD	-	-	-	-
5 - 21A	5200B	Office	2'x4' Suspended Ceiling Tile Big & Small Holes	NAD	-	-	-	-
5 - 21B	5200B	Office	2'x4' Suspended Ceiling Tile Big & Small Holes	NAD	-	-	-	-
5 - 21C	5200B	Office	2'x4' Suspended Ceiling Tile Big & Small Holes	NAD	-	-	-	-
5 - 22A	Hall at 5131	Corridor	Door Core Insulation	NAD	-	-	-	-
5 - 22B	Hall at 5131	Corridor	Door Core Insulation	NAD	-	-	-	-
5 - 22C	Hall at 5131	Corridor	Door Core Insulation	NAD	-	-	-	-
5 - 23A	5104	SPD	Glue w/Blue Carpet	NAD	-	-	-	-
5 - 23B	5104	SPD	Glue w/Blue Carpet	NAD	-	-	-	-
5 - 23C	5104	SPD	Glue w/Blue Carpet	NAD	-	-	-	-
5 - 24A	5100	Waiting	Glue w/Multicolor Carpet	NAD	-	-	-	-
5 - 24B	5152	Office	Glue w/Multicolor Carpet	NAD	-	-	-	-
5 - 24C	5100	Waiting	Glue w/Multicolor Carpet	NAD	-	-	-	-
5 - 25A	5150	Mechanical	Exposed Black Floor Mastic	NAD	-	-	-	-
5 - 25B	5150	Mechanical	Exposed Black Floor Mastic	NAD	-	-	-	-
5 - 25C	5150	Mechanical	Exposed Black Floor Mastic	NAD	-	-	-	-
5 - 26A	5-C-6	Corridor	12"x12" White Vinyl Floor Tile w/Blue & Red Specks	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
5 - 26B	5196	Storage	12"x12" White Vinyl Floor Tile w/Blue & Red Specks	NAD	-	-	-	-
5 - 26C	5162	Bed	12"x12" White Vinyl Floor Tile w/Blue & Red Specks	NAD	-	-	-	-
5 - 27A	5-C-6	Corridor	Mastic w/12"x12" White Vinyl Floor Tile w/Blue & Red Specks	NAD	-	-	-	-
5 - 27B	5196	Storage	Mastic w/12"x12" White Vinyl Floor Tile w/Blue & Red Specks	NAD	-	-	-	-
5 - 27C	5162	Bed	Mastic w/12"x12" White Vinyl Floor Tile w/Blue & Red Specks	NAD	-	-	-	-
5 - 28A	Hall at 5200	Corridor	12"x12" Cream Vinyl Floor Tile w/Gray Specks	NAD	-	-	-	-
5 - 28B	Hall at 5206	Corridor	12"x12" Cream Vinyl Floor Tile w/Gray Specks	NAD	-	-	-	-
5 - 28C	5216	Lab	12"x12" Cream Vinyl Floor Tile w/Gray Specks	NAD	-	-	-	-
5 - 29A	Corridor 5-1	5205A, 5208 5202, 5209, 5211, 5215 5216, 5203 5203B, 5200E, 5200C, 5212 5201, Corridor 5-1, Corridor AA	Mastic w/12"x12" Cream Vinyl Floor Tile w/Gray Specks	4% Chrysotile	Good	3020	SF	4
5 - 29B	Corridor AA			Stop Positive – See 5 - 29A				
5 - 29C	5215			Stop Positive – See 5 - 29A				
5 - 30A	Elevator Lobby	Lobby	12"x12" Green Vinyl Floor Tile	NAD	-	-	-	-
5 - 30B	Hall at 5187	Corridor	12"x12" Green Vinyl Floor Tile	NAD	-	-	-	-
5 - 30C	5-C-6	Corridor	12"x12" Green Vinyl Floor Tile	NAD	-	-	-	-
5 - 31A	Elevator Lobby	Lobby	12" x12" Blue Vinyl Floor Tile	NAD	-	-	-	-
5 - 31B	Hall at 5187	Corridor	12" x12" Blue Vinyl Floor Tile	NAD	-	-	-	-
5 - 31C	5-C-6	Corridor	12" x12" Blue Vinyl Floor Tile	NAD	-	-	-	-
5 - 32A	Hall at 5109	Corridor	White Seamless Flooring w/Gray Specks	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
5 - 32B	5113	Medication	White Seamless Flooring w/Gray Specks	NAD	-	-	-	-
5 - 32C	5140	Bed	White Seamless Flooring w/Gray Specks	NAD	-	-	-	-
5 - 33A	Hall at 5109	Corridor	Glue w/White Seamless Flooring w/Gray Specks	NAD	-	-	-	-
5 - 33B	5113	Medication	Glue w/White Seamless Flooring w/Gray Specks	NAD	-	-	-	-
5 - 33C	5140	Bed	Glue w/White Seamless Flooring w/Gray Specks	NAD	-	-	-	-
6 - 1A	6117	Corridor	2'X4' Suspended Ceiling Tile Pock & Pinholes	NAD	-	-	-	-
6 - 1B	6119	Office	2'X4' Suspended Ceiling Tile Pock & Pinholes	NAD	-	-	-	-
6 - 1C	6219	Office	2'X4' Suspended Ceiling Tile Pock & Pinholes	NAD	-	-	-	-
6 - 2A	6147	Corridor	2'X4' Suspended Ceiling Tile Bird Feet	NAD	-	-	-	-
6 - 2B	6117	Corridor	2'X4' Suspended Ceiling Tile Bird Feet	NAD	-	-	-	-
6 - 2C	6180	Mechanical	2'X4' Suspended Ceiling Tile Bird Feet	NAD	-	-	-	-
6 - 3A	6128	Storage	2'X4' Suspended Ceiling Tile Big & Small Pinholes	NAD	-	-	-	-
6 - 3B	6115	Corridor	2'X4' Suspended Ceiling Tile Big & Small Pinholes	NAD	-	-	-	-
6 - 3C	6191	Break	2'X4' Suspended Ceiling Tile Big & Small Pinholes	NAD	-	-	-	-
6 - 4A	6164A	Toilet	Plaster Ceiling Skim Coat	NAD	-	-	-	-
6 - 4B	6163	Closet	Plaster Ceiling Skim Coat	NAD	-	-	-	-
6 - 4C	6127	Storage	Plaster Ceiling Skim Coat	NAD	-	-	-	-
6 - 5A	6180	Storage	Plaster Ceiling Base Coat	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
6 - 5B	6163	Closet	Plaster Ceiling Base Coat	NAD	-	-	-	-
6 - 5C	6127	Storage	Plaster Ceiling Base Coat	NAD	-	-	-	-
6 - 6A	6218	Office	Wallboard	NAD	-	-	-	-
6 - 6B	6127	Storage	Wallboard	NAD	-	-	-	-
6 - 6C	6218	Office	Wallboard	NAD	-	-	-	-
6 - 7A	6218	Office	Wallboard Compound	NAD	-	-	-	-
6 - 7B	6127	Storage	Wallboard Compound	NAD	-	-	-	-
6 - 7C	6218	Office	Wallboard Compound	NAD	-	-	-	-
6 - 8A	Hall at 6127	Corridor	Wall Plaster Skim Coat	NAD	-	-	-	-
6 - 8B	Hall at 6182	Corridor	Wall Plaster Skim Coat	NAD	-	-	-	-
6 - 8C	Hall at 6130	Corridor	Wall Plaster Skim Coat	NAD	-	-	-	-
6 - 9A	Hall at 6127	Corridor	Wall Plaster Base Coat	NAD	-	-	-	-
6 - 9B	Hall at 6182	Corridor	Wall Plaster Base Coat	NAD	-	-	-	-
6 - 9C	Hall at 6130	Corridor	Wall Plaster Base Coat	NAD	-	-	-	-
6 - 10A	6115C	Office	Window Sill Caulk	NAD	-	-	-	-
6 - 10B	6151	Office	Window Sill Caulk	NAD	-	-	-	-
6 - 10C	6192	Office	Window Sill Caulk	NAD	-	-	-	-
6 - 11A	6190	6190 6149	Sink Undercoating Black	3% Chrysotile	Good	2	Sinks	4
6 - 11B	6149			3% Chrysotile				
6 - 11C	6149			3% Chrysotile				
6 - 12A	6180	Mechanical	Red Fire Caulk	NAD	-	-	-	-
6 - 12B	6148	Mechanical	Red Fire Caulk	NAD	-	-	-	-
6 - 12C	6144	Closet	Red Fire Caulk	NAD	-	-	-	-
6 - 13A	Stair 2	Stair	Pipe Caulk Gray	NAD	-	-	-	-
6 - 13B	Stair 2	Stair	Pipe Caulk Gray	NAD	-	-	-	-
6 - 13C	Stair 3	Stair	Pipe Caulk Gray	NAD	-	-	-	-
6 - 14A	Hall at 6217	Corridor	2'x4' Suspended Ceiling Tile w/Squiggles & Pinholes	NAD	-	-	-	-
6 - 14B	Hall at 6217	Corridor	2'x4' Suspended Ceiling Tile w/Squiggles & Pinholes	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
6 - 14C	Hall at 6217	Corridor	2'x4' Suspended Ceiling Tile w/Squiggles & Pinholes	NAD	-	-	-	-
6 - 15A	6001	Stair	Door Glass Panel Putty	NAD	-	-	-	-
6 - 15B	6003	Stair	Door Glass Panel Putty	NAD	-	-	-	-
6 - 15C	6002	Stair	Door Glass Panel Putty	NAD	-	-	-	-
6 - 16A	6159	Kitchen	Sink Undercoating Gray	NAD	-	-	-	-
6 - 16B	6159	Kitchen	Sink Undercoating Gray	NAD	-	-	-	-
6 - 16C	6159	Kitchen	Sink Undercoating Gray	NAD	-	-	-	-
6 - 17A	6163	6163	Glue Daubs on Ducts	15% Chrysotile	Damaged	15	SF	4
6 - 17B	6163			Stop Positive See 6 - 17A				
6 - 17C	6163			Stop Positive See 6 - 17A				
6 - 18A	6110	Office	Glue w/Blue Carpet	NAD	-	-	-	-
6 - 18B	6118	Reception	Glue w/Blue Carpet	NAD	-	-	-	-
6 - 18C	6187	Office	Glue w/Blue Carpet	NAD	-	-	-	-
6 - 19A	6151	Office	Glue w/6" Black Cove Base Coat	NAD	-	-	-	-
6 - 19B	6190	Break	Glue w/6" Black Cove Base Coat	NAD	-	-	-	-
6 - 19C	6164	Lounge	Glue w/6" Black Cove Base Coat	NAD	-	-	-	-
6 - 20A	6114	Office	12"x12" Cream Vinyl Floor Tile w/Gray Streaks	NAD	-	-	-	-
6 - 20B	6110	Office	12"x12" Cream Vinyl Floor Tile w/Gray Streaks	NAD	-	-	-	-
6 - 20C	6102	Exam	12"x12" Cream Vinyl Floor Tile w/Gray Streaks	NAD	-	-	-	-
6 - 21A	6114	Office	Mastic w/12"x12" Cream Vinyl Floor Tile w/Gray Streaks	NAD	-	-	-	-
6 - 21B	6110	Office	Mastic w/12"x12" Cream Vinyl Floor Tile w/Gray Streaks	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
6 - 21C	6102	Exam	Mastic w/12"x12" Cream Vinyl Floor Tile w/Gray Streaks	NAD	-	-	-	-
6 - 22A	Alcove at 6155	Alcove	9" White Vinyl Floor Tile w/Green Specks	1% Chrysotile	-	-	-	-
6 - 22B	Hall at 6129	Corridor	9" White Vinyl Floor Tile w/Green Specks	1% Chrysotile	-	-	-	-
6 - 22C	Hall at 6114	Corridor	9" White Vinyl Floor Tile w/Green Specks	1% Chrysotile	-	-	-	-
6 - 23A	Alcove at 6155	Alcove	Mastic w/9" White Vinyl Floor Tile w/Green Specks	NAD	-	-	-	-
6 - 23B	Hall at 6129	Corridor	Mastic w/9" White Vinyl Floor Tile w/Green Specks	NAD	-	-	-	-
6 - 23C	Hall at 6114	Corridor	Mastic w/9" White Vinyl Floor Tile w/Green Specks	NAD	-	-	-	-
6 - 24A	6190	Break	12"x12" White Vinyl Floor Tile w/Blue Red Specks	NAD	-	-	-	-
6 - 24B	6155	Office	12"x12" White Vinyl Floor Tile w/Blue Red Specks	NAD	-	-	-	-
6 - 24C	6179	Closet	12"x12" White Vinyl Floor Tile w/Blue Red Specks	NAD	-	-	-	-
6 - 25A	6190	Break	Mastic w/12"x12" White Vinyl Floor Tile w/Blue Red Specks	<1% Chrysotile	-	-	-	-
6 - 25B	6155	Office	Mastic w/12"x12" White Vinyl Floor Tile w/Blue Red Specks	<1% Chrysotile	-	-	-	-
6 - 25C	6179	Closet	Mastic w/12"x12" White Vinyl Floor Tile w/Blue Red Specks	<1% Chrysotile	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
6 - 26A	6139	6137, 6138 6139, 6140 6141, 6142 6107	9"x9" Dark Brown Vinyl Floor Tile w/White Streaks	5% Chrysotile	Good	857	SF	4
6 - 26B	6137			5% Chrysotile				
6 - 26C	6140			5% Chrysotile				
6 - 27A	6139	6137, 6138 6139, 6140 6141, 6142 6107	Mastic w/9"x9" Dark Brown Vinyl Floor Tile w/White Streaks	3% Chrysotile	Good	857	SF	4
6 - 27B	6137			3% Chrysotile				
6 - 27C	6140			3% Chrysotile				
6 - 28A	6140	Office	Glue w/Purple Carpet	NAD	-	-	-	-
6 - 28B	6136	Office	Glue w/Purple Carpet	NAD	-	-	-	-
6 - 28C	6169	Bed	Glue w/Purple Carpet	NAD	-	-	-	-
6 - 29A	6210A	Office	Glue w/Green Carpet	NAD	-	-	-	-
6 - 29B	6140	Office	Glue w/Green Carpet	NAD	-	-	-	-
6 - 29C	6139	Office	Glue w/Green Carpet	NAD	-	-	-	-
6 - 30A	6210	6149, 6150 6153, 6154 6208, 6209 6210, 6210A	9"x9" Green Vinyl Floor Tile w/White Streaks	6% Chrysotile	Good	1282	SF	4
6 - 30B	6208			6% Chrysotile				
6 - 30C	6150			6% Chrysotile				
6 - 31A	6210	Office	Glue w/Multicolor Carpet	NAD	-	-	-	-
6 - 31B	6208	Mechanical	Glue w/Multicolor Carpet	NAD	-	-	-	-
6 - 31C	6150	Lab	Glue w/Multicolor Carpet	NAD	-	-	-	-
6 - 32A	6208	Corridor	Glue w/Brown Carpet	NAD	-	-	-	-
6 - 32B	6208	Corridor	Glue w/Brown Carpet	NAD	-	-	-	-
6 - 32C	6208	Corridor	Glue w/Brown Carpet	NAD	-	-	-	-
6 - 33A	6207	Storage	Glue w/6" Pink Cove Base Coat	NAD	-	-	-	-
6 - 33B	6207	Storage	Glue w/6" Pink Cove Base Coat	NAD	-	-	-	-
6 - 33C	6207	Storage	Glue w/6" Pink Cove Base Coat	NAD	-	-	-	-
6 - 34A	6207	Storage	Glue w/Orange Carpet	NAD	-	-	-	-
6 - 34B	6207	Storage	Glue w/Orange Carpet	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
6 - 34C	6207	Storage	Glue w/Orange Carpet	NAD	-	-	-	-
6 - 35A	6210	Office	Glue w/6" Green Cove Base Coat	NAD	-	-	-	-
6 - 35B	6210A	Office	Glue w/6" Green Cove Base Coat	NAD	-	-	-	-
6 - 35C	6210A	Office	Glue w/6" Green Cove Base Coat	NAD	-	-	-	-
6 - 36A	6210	Office	Glue w/6" Brown Cove Base Coat	NAD	-	-	-	-
6 - 36B	6211	Office	Glue w/6" Brown Cove Base Coat	NAD	-	-	-	-
6 - 36C	6211	Office	Glue w/6" Brown Cove Base Coat	NAD	-	-	-	-
6 - 37A	6211	Office	Glue w/Pink Carpet	NAD	-	-	-	-
6 - 37B	6211	Office	Glue w/Pink Carpet	NAD	-	-	-	-
6 - 37C	6211	Office	Glue w/Pink Carpet	NAD	-	-	-	-
6 - 38A	6210	Office	Mastic w/9"x9" Green Vinyl Floor Tile w/White Streaks	VOID	-	-	-	-
6 - 38B	6208	Mechanical	Mastic w/9"x9" Green Vinyl Floor Tile w/White Streaks	VOID	-	-	-	-
6 - 38C	6150	Lab	Mastic w/9"x9" Green Vinyl Floor Tile w/White Streaks	VOID	-	-	-	-
7 - 1A	Freight Elevator Lobby	Lobby	12"x12" White Vinyl Floor Tile w/Blue & Red Streaks	NAD	-	-	-	-
7 - 1B	Freight Elevator Lobby	Lobby	12"x12" White Vinyl Floor Tile w/Blue & Red Streaks	NAD	-	-	-	-
7 - 1C	Dumbwaiter Lobby	Lobby	12"x12" White Vinyl Floor Tile w/Blue & Red Streaks	NAD	-	-	-	-
7 - 2A	Freight Elevator Lobby	Lobby	Mastic w/12"x12" White Vinyl Floor Tile w/Blue & Red Streaks	NAD	-	-	-	-
7 - 2B	Freight Elevator Lobby	Lobby	Mastic w/12"x12" White Vinyl Floor Tile w/Blue & Red Streaks	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
7 - 2C	Dumbwaiter Lobby	Lobby	Mastic w/12"x12" White Vinyl Floor Tile w/Blue & Red Streaks	NAD	-	-	-	-
7 - 3A	Freight Elevator Lobby	Lobby	12"x12" Light Green Vinyl Floor Tile w/Tan Specks	NAD	-	-	-	-
7 - 3B	Freight Elevator Lobby	Lobby	12"x12" Light Green Vinyl Floor Tile w/Tan Specks	NAD	-	-	-	-
7 - 3C	Freight Elevator Lobby	Lobby	12"x12" Light Green Vinyl Floor Tile w/Tan Specks	NAD	-	-	-	-
7 - 4A	Freight Elevator Lobby	Lobby	Mastic w/12"x12" Light Green Vinyl Floor Tile w/Tan Specks	NAD	-	-	-	-
7 - 4B	Freight Elevator Lobby	Lobby	Mastic w/12"x12" Light Green Vinyl Floor Tile w/Tan Specks	NAD	-	-	-	-
7 - 4C	Freight Elevator Lobby	Lobby	Mastic w/12"x12" Light Green Vinyl Floor Tile w/Tan Specks	NAD	-	-	-	-
7 - 5A	Corridor 7154	Corridor 7154 Corridor 7-1	9"x9" Light Brown Vinyl Floor Tile w/Black Streaks	23% Chrysotile	Good	5237	SF	4
7 - 5B	Corridor 7-1	Corridor 7154B Corridor 7154C 7-118-C 7-118-D 7164, 7166 7167, 7174		Stop Positive See 7 - 5A				
7 - 5C	7203	7176A, 7202 7203		Stop Positive See 7 - 5A				
7 - 6A	Corridor 7154	Corridor 7154 Corridor 7-1	Mastic w/9"x9" Light Brown Vinyl Floor Tile w/Black Streaks	3% Chrysotile	Good	5237	SF	4
7 - 6B	Corridor 7-1	Corridor 7154B Corridor 7154C 7-118-C 7-118-D 7164, 7166 7167, 7174		<1% Chrysotile	-	-	-	-
7 - 6C	7203	7176A, 7202 7203		<1% Chrysotile	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
7 - 7A	7186B	7155, 7186E 1756, 7194	9"x9" Dark Green Vinyl Floor Tile w/White Streaks	22% Chrysotile	Good	4415	SF	4
7 - 7B	7186B	7156A, 7196 7185, 7196C 7186, 7183		Stop Positive See 7 - 7A				
7 - 7C	7186	7186A, 7186B 7186D, 7201 7192, 7200 7198, 7199 Corridor 7-1		Stop Positive See 7 - 7A				
7 - 8A	7186B	Group Room	Mastic w/9"x9" Dark Green Vinyl Floor Tile w/White Streaks	NAD	-	-	-	-
7 - 8B	7186B	Group Room	Mastic w/9"x9" Dark Green Vinyl Floor Tile w/White Streaks	NAD	-	-	-	-
7 - 8C	7186	Waiting	Mastic w/9"x9" Dark Green Vinyl Floor Tile w/White Streaks	NAD	-	-	-	-
7 - 9A	7152	Clinic	Glue w/Blue Gray Carpet	NAD	-	-	-	-
7 - 9B	7154	Clinic	Glue w/Blue Gray Carpet	NAD	-	-	-	-
7 - 9C	7151	Clinic	Glue w/Blue Gray Carpet	NAD	-	-	-	-
7 - 10A	7155	Office	Glue w/Light Brown Carpet	NAD	-	-	-	-
7 - 10B	7155	Office	Glue w/Light Brown Carpet	NAD	-	-	-	-
7 - 10C	7155	Office	Glue w/Light Brown Carpet	NAD	-	-	-	-
7 - 11A	7208H	7208H	Glue w/Blue Carpet	3% Chrysotile	Good	152	SF	4
7 - 11B	7159	Office	Glue w/Blue Carpet	NAD	-	-	-	-
7 - 11C	7164	Office	Glue w/Blue Carpet	NAD	-	-	-	-
7 - 12A	Stair 1	Stairway	Yellow Poured Flooring	NAD	-	-	-	-
7 - 12B	Stair 2	Stairway	Yellow Poured Flooring	NAD	-	-	-	-
7 - 12C	Stair 3	Stairway	Yellow Poured Flooring	NAD	-	-	-	-
7 - 13A	7185	Group Room	Glue w/Pink Carpet w/Purple Diamonds	NAD	-	-	-	-
7 - 13B	7185	Group Room	Glue w/Pink Carpet w/Purple Diamonds	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
7 - 13C	7185	Group Room	Glue w/Pink Carpet w/Purple Diamonds	NAD	-	-	-	-
7 - 14A	7-118-D	7-118-D 7215	9"x9" Brown Vinyl Floor Tile w/White & Dark Brown Streaks	<1% Chrysotile	-	-	-	-
7 - 14B	7-118-D			2% Chrysotile	Good	205	SF	4
7 - 14C	7-118-D			1% Chrysotile	-	-	-	-
7 - 15A	7-118-D	7-118-D 7215	Mastic w/9"x9" Brown Vinyl Floor Tile w/White & Dark Brown Streaks	8% Chrysotile	Good	205	SF	4
7 - 15B	7-118-D			Stop Positive See 7 - 15A				
7 - 15C	7-118-D			Stop Positive See 7 - 15A				
7 - 16A	Freight Elevator Lobby	Lobby	Glue w/6" Gray Cove Base	NAD	-	-	-	-
7 - 16B	Dumbwaiter Lobby	Lobby	Glue w/6" Gray Cove Base	NAD	-	-	-	-
7 - 16C	7161	Utility	Glue w/6" Gray Cove Base	NAD	-	-	-	-
7 - 17A	Freight Elevator Lobby	Lobby	Glue w/6" Black Cove Base	NAD	-	-	-	-
7 - 17B	Hall at 7211	Corridor	Glue w/6" Black Cove Base	NAD	-	-	-	-
7 - 17C	7165	Office	Glue w/6" Black Cove Base	NAD	-	-	-	-
7 - 18A	7155	Office	Glue w/6" Dark Brown Cove Base	NAD	-	-	-	-
7 - 18B	7155	Office	Glue w/6" Dark Brown Cove Base	NAD	-	-	-	-
7 - 18C	7155	Office	Glue w/6" Dark Brown Cove Base	NAD	-	-	-	-
7 - 19A	Hall at 7208	Corridor	Glue w/6" Light Blue Cove Base	NAD	-	-	-	-
7 - 19B	7163	Closet	Glue w/6" Light Blue Cove Base	NAD	-	-	-	-
7 - 19C	7163	Closet	Glue w/6" Light Blue Cove Base	NAD	-	-	-	-
7 - 20A	7185	Group Room	Glue w/6" Light Brown Cove Base	NAD	-	-	-	-
7 - 20B	7185	Group Room	Glue w/6" Light Brown Cove Base	NAD	-	-	-	-
7 - 20C	7185	Group Room	Glue w/6" Light Brown Cove Base	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
7 - 21A	Dumbwaiter Lobby	Lobby	2'x4' Suspended Ceiling Tile Bird Track	NAD	-	-	-	-
7 - 21B	7141	Exam	2'x4' Suspended Ceiling Tile Bird Track	NAD	-	-	-	-
7 - 21C	Hall at 181	Corridor	2'x4' Suspended Ceiling Tile Bird Track	NAD	-	-	-	-
7 - 22A	7211	Corridor	2'x2' Suspended Ceiling Tile Slots & Pinholes	NAD	-	-	-	-
7 - 22B	7163	Closet	2'x2' Suspended Ceiling Tile Slots & Pinholes	NAD	-	-	-	-
7 - 22C	7163	Closet	2'x2' Suspended Ceiling Tile Slots & Pinholes	NAD	-	-	-	-
7 - 23A	Hall at 7208	Corridor	2'x2' Suspended Ceiling Tile Bird Track	NAD	-	-	-	-
7 - 23B	Hall at 7208	Corridor	2'x2' Suspended Ceiling Tile Bird Track	NAD	-	-	-	-
7 - 23C	Hall at 7210	Corridor	2'x2' Suspended Ceiling Tile Bird Track	NAD	-	-	-	-
7 - 24A	7163	Closet	Ceiling Plaster Skim	NAD	-	-	-	-
7 - 24B	Hall at 7181	Corridor	Ceiling Plaster Skim	NAD	-	-	-	-
7 - 24C	Pass. Services Elevator	Elevator	Ceiling Plaster Skim	NAD	-	-	-	-
7 - 25A	7163	Closet	Ceiling Plaster Base	NAD	-	-	-	-
7 - 25B	Hall at 7181	Corridor	Ceiling Plaster Base	NAD	-	-	-	-
7 - 25C	Pass. Services Elevator	Elevator	Ceiling Plaster Base	NAD	-	-	-	-
7 - 26A	Dumbwaiter Lobby	Lobby	Wall Plaster Skim	NAD	-	-	-	-
7 - 26B	7185	Group Room	Wall Plaster Skim	NAD	-	-	-	-
7 - 26C	Fire Closet at 7130	Closet	Wall Plaster Skim	NAD	-	-	-	-
7 - 27A	Dumbwaiter Lobby	Lobby	Wall Plaster Base	NAD	-	-	-	-
7 - 27B	7185	Group Room	Wall Plaster Base	NAD	-	-	-	-
7 - 27C	Fire Closet at 7130	Closet	Wall Plaster Base	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*					
						Value	Units						
7 - 28A	7125	Corridor 7154 Corridor 7-1 Corridor 7154B Corridor 7154C 7-118-C 7-118-D 7164, 7166 7167, 7174 7176A, 7202 7203	Dark Brown Flooring Border	15% Chrysotile	Good	1173	SF	4					
7 - 28B	Corridor 7-1								Stop Positive See 7 – 28A				
7 - 28C	Corridor 7154								Stop Positive See 7 – 28A				
7 - 29A	7186A	7155, 7186E 1756, 7194 7156A, 7196, 7185, 7196C 7186, 7183 7186A, 7186B 7186D, 7201 7192, 7200 7198, 7199 Corridor 7-1	Black Flooring Border	10% Chrysotile	Good	343	SF	4					
7 - 29B	7198								Stop Positive See 7 – 29A				
7 - 29C	7199								Stop Positive See 7 – 29A				
7 - 30A	Freight Elevator	Elevator	Door Glass Panel Black Putty	NAD	-	-	-	-					
7 - 30B	Stair 1	Stairway	Door Glass Panel Black Putty	NAD	-	-	-	-					
7 - 30C	Stair 1	Stairway	Door Glass Panel Black Putty	NAD	-	-	-	-					
7 - 31A	7126	Office	12"x12" White Suspended Ceiling Tile w/Gray Specks	NAD	-	-	-	-					
7 - 31B	7128	Office	12"x12" White Suspended Ceiling Tile w/Gray Specks	NAD	-	-	-	-					
7 - 31C	7135	Office	12"x12" White Suspended Ceiling Tile w/Gray Specks	NAD	-	-	-	-					
7 - 32A	7126	Office	Mastic w/12"x12" White Suspended Ceiling Tile w/Gray Specks	NAD	-	-	-	-					
7 - 32B	7128	Office	Mastic w/12"x12" White Suspended Ceiling Tile w/Gray Specks	NAD	-	-	-	-					

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
7 - 32C	7135	Office	Mastic w/12"12" White Suspended Ceiling Tile w/Gray Specks	NAD	-	-	-	-
7 - 33A	7119	Group Room	12"x12" Cream w/Gold Specks	NAD	-	-	-	-
7 - 33B	7116	Bed	12"x12" Cream w/Gold Specks	NAD	-	-	-	-
7 - 33C	7132	Bed	12"x12" Cream w/Gold Specks	NAD	-	-	-	-
7 - 34A	7119	Group Room	Mastic w/12"x12" Cream w/Gold Specks	NAD	-	-	-	-
7 - 34B	7116	Bed	Mastic w/12"x12" Cream w/Gold Specks	NAD	-	-	-	-
7 - 34C	7132	Bed	Mastic w/12"x12" Cream w/Gold Specks	NAD	-	-	-	-
7 - 35A	7132	Bed	Window Sill Caulk	NAD	-	-	-	-
7 - 35B	7174	Office	Window Sill Caulk	NAD	-	-	-	-
7 - 35C	7199	Office	Window Sill Caulk	NAD	-	-	-	-
7 - 36A	7144	Closet	Red Fire Stop Caulk	NAD	-	-	-	-
7 - 36B	7124	Bathroom	Red Fire Stop Caulk	NAD	-	-	-	-
7 - 36C	7129	Utility	Red Fire Stop Caulk	NAD	-	-	-	-
7 - 37A	7128	Office	Sink Under - coating	NAD	-	-	-	-
7 - 37B	7128	Office	Sink Under - coating	NAD	-	-	-	-
7 - 37C	7128	Office	Sink Under - coating	NAD	-	-	-	-
7 - 38A	7100	7100	Yellow Linoleum w/Gold Spots	10% Chrysotile	Good	51	SF	4
7 - 38B	7100			Stop Positive See 7 - 38A				
7 - 38C	7100			Stop Positive See 7 - 38A				
7 - 39A	7100	7100	Mastic w/Yellow Linoleum w/Gold Spots	30% Chrysotile	Good	51	SF	4
7 - 39B	7100			Stop Positive See 7 - 39A				
7 - 39C	7100			Stop Positive See 7 - 39A				
7 - 40A	7168	7168	Glue w/Pink Carpet	12% Chrysotile	Good	315	SF	4
7 - 40B	7168			Stop Positive See 7 - 40A				
7 - 40C	7168			Stop Positive See 7 - 40A				

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
8 - 1A	8110	Restroom	Ceiling Plaster Skim Coat	NAD	-	-	-	-
8 - 1B	8107	Exam	Ceiling Plaster Skim Coat	NAD	-	-	-	-
8 - 1C	8118	Group	Ceiling Plaster Skim Coat	NAD	-	-	-	-
8 - 1D	8118	Group	Ceiling Plaster Skim Coat	NAD	-	-	-	-
8 - 1E	8118	Group	Ceiling Plaster Skim Coat	NAD	-	-	-	-
8 - 2A	8110	Restroom	Ceiling Plaster Base Coat	NAD	-	-	-	-
8 - 2B	8107	Exam	Ceiling Plaster Base Coat	NAD	-	-	-	-
8 - 2C	8118	Group	Ceiling Plaster Base Coat	NAD	-	-	-	-
8 - 2D	8118	Group	Ceiling Plaster Base Coat	NAD	-	-	-	-
8 - 2E	8118	Group	Ceiling Plaster Base Coat	NAD	-	-	-	-
8 - 3A	8110	Restroom	Wall Plaster Skim Coat	NAD	-	-	-	-
8 - 3B	8107	Exam	Wall Plaster Skim Coat	NAD	-	-	-	-
8 - 3C	8105	Nurse's Station	Wall Plaster Skim Coat	NAD	-	-	-	-
8 - 3D	8125	Office	Wall Plaster Skim Coat	NAD	-	-	-	-
8 - 3E	8118	Group	Wall Plaster Skim Coat	NAD	-	-	-	-
8 - 3F	8119	Office	Wall Plaster Skim Coat	NAD	-	-	-	-
8 - 3G	Hallway	Corridor	Wall Plaster Skim Coat	NAD	-	-	-	-
8 - 4A	8110	Restroom	Wall Plaster Base Coat	NAD	-	-	-	-
8 - 4B	8107	Exam	Wall Plaster Base Coat	NAD	-	-	-	-
8 - 4C	8105	Nurse's Station	Wall Plaster Base Coat	NAD	-	-	-	-
8 - 4D	8125	Office	Wall Plaster Base Coat	NAD	-	-	-	-
8 - 4E	8118	Group	Wall Plaster Base Coat	NAD	-	-	-	-
8 - 4F	8119	Office	Wall Plaster Base Coat	NAD	-	-	-	-
8 - 4G	Hallway	Corridor	Wall Plaster Base Coat	NAD	-	-	-	-
8 - 5A	8121	Office	Glue w/6" Brown Cove Base Coat	NAD	-	-	-	-
8 - 5B	8121	Office	Glue w/6" Brown Cove Base Coat	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
8 - 5C	8105	Nurse's Station	Glue w/6" Brown Cove Base Coat	NAD	-	-	-	-
8 - 6A	8122	Office	Glue w/6" Black Cove Base Coat	NAD	-	-	-	-
8 - 6B	8122	Office	Glue w/6" Black Cove Base Coat	NAD	-	-	-	-
8 - 6C	8134	Day Room	Glue w/6" Black Cove Base Coat	NAD	-	-	-	-
8 - 7A	8105	Nurse's Station	Window Ledge White Caulk	NAD	-	-	-	-
8 - 7B	8134	Day Room	Window Ledge White Caulk	NAD	-	-	-	-
8 - 7C	8209	Conference	Window Ledge White Caulk	NAD	-	-	-	-
8 - 8A	8116	Group	12"x12" Tan Dapple Vinyl Floor Tile	NAD	-	-	-	-
8 - 8B	8118	Group	12"x12" Tan Dapple Vinyl Floor Tile	NAD	-	-	-	-
8 - 8C	8118	Group	12"x12" Tan Dapple Vinyl Floor Tile	NAD	-	-	-	-
8 - 9A	8116	Group	Mastic w/12"12" Tan Dapple Vinyl Floor Tile	NAD	-	-	-	-
8 - 9B	8118	Group	Mastic w/12"12" Tan Dapple Vinyl Floor Tile	NAD	-	-	-	-
8 - 9C	8118	Group	Mastic w/12"12" Tan Dapple Vinyl Floor Tile	NAD	-	-	-	-
8 - 10A	Hallway	Corridor	12"x12" Beige Dapple Vinyl Floor Tile	NAD	-	-	-	-
8 - 10B	Hallway	Corridor	12"x12" Beige Dapple Vinyl Floor Tile	NAD	-	-	-	-
8 - 10C	Hallway	Corridor	12"x12" Beige Dapple Vinyl Floor Tile	NAD	-	-	-	-
8 - 11A	Hallway	Corridor	Mastic w/12"12" Beige Dapple Vinyl Floor Tile	NAD	-	-	-	-
8 - 11B	Hallway	Corridor	Mastic w/12"12" Beige Dapple Vinyl Floor Tile	NAD	-	-	-	-
8 - 11C	Hallway	Corridor	Mastic w/12"12" Beige Dapple Vinyl Floor Tile	NAD	-	-	-	-
8 - 12A	8116	Group	Glue w/Blue Carpet	NAD	-	-	-	-
8 - 12B	8122	Office	Glue w/Blue Carpet	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
8 - 12C	8134	Day Room	Glue w/Blue Carpet	NAD	-	-	-	-
8 - 13A	Hallway at 8116	Corridor	2'x2' Textured Suspended Ceiling Tile	NAD	-	-	-	-
8 - 13B	Hallway at 8116	Corridor	2'x2' Textured Suspended Ceiling Tile	NAD	-	-	-	-
8 - 13C	Hallway at 8116	Corridor	2'x2' Textured Suspended Ceiling Tile	NAD	-	-	-	-
8 - 14A	8209A	Conference	2'x4' Suspended Ceiling Tile Bird Track	NAD	-	-	-	-
8 - 14B	8209A	Conference	2'x4' Suspended Ceiling Tile Bird Track	NAD	-	-	-	-
8 - 14C	8209A	Conference	2'x4' Suspended Ceiling Tile Bird Track	NAD	-	-	-	-
8 - 15A	8113	8113	9"x9" Green Vinyl Floor Tile w/White	6% Chrysotile	Good	299	SF	4
8 - 15B	8113			6% Chrysotile				
8 - 15C	8113			6% Chrysotile				
8 - 16A	8113	Therapy	Mastic w/9"9" Green Vinyl Floor Tile w/White	NAD	-	-	-	-
8 - 16B	8113	Therapy	Mastic w/9"9" Green Vinyl Floor Tile w/White	NAD	-	-	-	-
8 - 16C	8113	Therapy	Mastic w/9"9" Green Vinyl Floor Tile w/White	NAD	-	-	-	-
8 - 17A	8113	8113	Black Border Vinyl Floor Tile	9% Chrysotile	Good	53	SF	4
8 - 17B	8113			9% Chrysotile				
8 - 17C	8113			9% Chrysotile				
8 - 18A	8113	Therapy	Mastic w/Black Border Vinyl Floor Tile	NAD	-	-	-	-
8 - 18B	8113	Therapy	Mastic w/Black Border Vinyl Floor Tile	NAD	-	-	-	-
8 - 18C	8113	Therapy	Mastic w/Black Border Vinyl Floor Tile	NAD	-	-	-	-
8 - 19A	8143	Closet	Wallboard	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
8 - 19B	8143	Closet	Wallboard	NAD	-	-	-	-
8 - 19C	8168	Day Room	Wallboard	NAD	-	-	-	-
8 - 20A	8143	Closet	Wallboard Compound	NAD	-	-	-	-
8 - 20B	8143	Closet	Wallboard Compound	NAD	-	-	-	-
8 - 20C	8168	Day Room	Wallboard Compound	NAD	-	-	-	-
8 - 21A	Hallway	Corridor	Door Frame Caulk	NAD	-	-	-	-
8 - 21B	Hallway	Corridor	Door Frame Caulk	NAD	-	-	-	-
8 - 21C	Hallway	Corridor	Door Frame Caulk	NAD	-	-	-	-
8 - 22A	8105B	8105B	Sink Under - Coating Thick Black	4% Chrysotile	Good	1	Sink	4
8 - 22B	8105B			4% Chrysotile				
8 - 22C	8105B			4% Chrysotile				
8 - 23A	8143	Closet	12"x12" White Vinyl Floor Tile w/Small Blue Streaks	NAD	-	-	-	-
8 - 23B	8143	Closet	12"x12" White Vinyl Floor Tile w/Small Blue Streaks	NAD	-	-	-	-
8 - 23C	8127	Kitchen	12"x12" White Vinyl Floor Tile w/Small Blue Streaks	NAD	-	-	-	-
8 - 24A	8143	Closet	Mastic w/12"x12" White Vinyl Floor Tile w/Small Blue Streaks	NAD	-	-	-	-
8 - 24B	8143	Closet	Mastic w/12"x12" White Vinyl Floor Tile w/Small Blue Streaks	NAD	-	-	-	-
8 - 24C	8127	Kitchen	Mastic w/12"x12" White Vinyl Floor Tile w/Small Blue Streaks	NAD	-	-	-	-
8 - 25A	8127	Kitchen	Glue w/4" Black Cove Base Coat	NAD	-	-	-	-
8 - 25B	8127	Kitchen	Glue w/4" Black Cove Base Coat	NAD	-	-	-	-
8 - 25C	8127	Kitchen	Glue w/4" Black Cove Base Coat	NAD	-	-	-	-
8 - 26A	8133	Office	Door Panel Black Putty	NAD	-	-	-	-
8 - 26B	8133	Office	Door Panel Black Putty	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
8 - 26C	8133	Office	Door Panel Black Putty	NAD	-	-	-	-
8 - 27A	8144	8144 8160	9"x9" Tan Vinyl Floor Tile w/Brown Streaks	6% Chrysotile	Good	77	SF	4
8 - 27B	8144			6% Chrysotile				
8 - 27C	8144			6% Chrysotile				
8 - 28A	8144	Linen	Mastic w/9"x9" Tan Vinyl Floor Tile w/Brown Streaks	NAD	-	-	-	-
8 - 28B	8144	Linen	Mastic w/9"x9" Tan Vinyl Floor Tile w/Brown Streaks	NAD	-	-	-	-
8 - 28C	8144	Linen	Mastic w/9"x9" Tan Vinyl Floor Tile w/Brown Streaks	NAD	-	-	-	-
8 - 29A	8143	Closet	Fire Stop Red Caulk	NAD	-	-	-	-
8 - 29B	8143	Closet	Fire Stop Red Caulk	NAD	-	-	-	-
8 - 29C	8003	Stairway	Fire Stop Red Caulk	NAD	-	-	-	-
8 - 30A	8131	Office	12"x12" White Vinyl Floor Tile w/Gray	NAD	-	-	-	-
8 - 30B	8131	Office	12"x12" White Vinyl Floor Tile w/Gray	NAD	-	-	-	-
8 - 30C	8131	Office	12"x12" White Vinyl Floor Tile w/Gray	NAD	-	-	-	-
8 - 31A	8131	Office	Mastic w/12"x12" White Vinyl Floor Tile w/Gray	NAD	-	-	-	-
8 - 31B	8131	Office	Mastic w/12"x12" White Vinyl Floor Tile w/Gray	NAD	-	-	-	-
8 - 31C	8131	Office	Mastic w/12"x12" White Vinyl Floor Tile w/Gray	NAD	-	-	-	-
8 - 32A	Hallway at 8139	Corridor	Window Black Compound	NAD	-	-	-	-
8 - 32B	Hallway at 8140	Corridor	Window Black Compound	NAD	-	-	-	-
8 - 32C	Hallway at 8141	Corridor	Window Black Compound	NAD	-	-	-	-
8 - 33A	8139	On - Duty Quarters	Sink Undercoating Gray	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
8 - 33B	8139	On - Duty Quarters	Sink Undercoating Gray	NAD	-	-	-	-
8 - 33C	8139	On - Duty Quarters	Sink Undercoating Gray	NAD	-	-	-	-
8 - 34A	VOID	VOID	VOID	VOID	-	-	-	-
8 - 34B	VOID	VOID	VOID	VOID	-	-	-	-
8 - 34C	VOID	VOID	VOID	VOID	-	-	-	-
8 - 35A	8003	Stairway	Epoxy Flooring	NAD	-	-	-	-
8 - 35B	8003	Stairway	Epoxy Flooring	NAD	-	-	-	-
8 - 35C	8003	Stairway	Epoxy Flooring	NAD	-	-	-	-
8 - 36A	8209A	Conference	12"x12" White Vinyl Floor Tile w/Gold Streaks	NAD	-	-	-	-
8 - 36B	8209A	Conference	12"x12" White Vinyl Floor Tile w/Gold Streaks	NAD	-	-	-	-
8 - 36C	8209A	Conference	12"x12" White Vinyl Floor Tile w/Gold Streaks	NAD	-	-	-	-
8 - 37A	8209A	Conference	Mastic w/12"x12" White Vinyl Floor Tile w/Gold Streaks	NAD	-	-	-	-
8 - 37B	8209A	Conference	Mastic w/12"x12" White Vinyl Floor Tile w/Gold Streaks	NAD	-	-	-	-
8 - 37C	8209A	Conference	Mastic w/12"x12" White Vinyl Floor Tile w/Gold Streaks	NAD	-	-	-	-
8 - 38A	8209A	Conference	Sink Undercoating Black	NAD	-	-	-	-
8 - 38B	8209A	Conference	Sink Undercoating Black	NAD	-	-	-	-
8 - 38C	8209A	Conference	Sink Undercoating Black	NAD	-	-	-	-
8 - 39A	8209	Therapy	12"x12" Green Vinyl Floor Tile	NAD	-	-	-	-
8 - 39B	8209	Therapy	12"x12" Green Vinyl Floor Tile	NAD	-	-	-	-
8 - 39C	8209	Therapy	12"x12" Green Vinyl Floor Tile	NAD	-	-	-	-
8 - 40A	8209	Therapy	Mastic w/12"x12" Green Vinyl Floor Tile	NAD	-	-	-	-
8 - 40B	8209	Therapy	Mastic w/12"x12" Green Vinyl Floor Tile	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
8 - 40C	8209	Therapy	Mastic w/12"x12" Green Vinyl Floor Tile	NAD	-	-	-	-
8 - 41A	8167	Day Room	12"x12" Beige Vinyl Floor Tile w/Green Streaks	NAD	-	-	-	-
8 - 41B	8167	Day Room	12"x12" Beige Vinyl Floor Tile w/Green Streaks	NAD	-	-	-	-
8 - 41C	8167	Day Room	12"x12" Beige Vinyl Floor Tile w/Green Streaks	NAD	-	-	-	-
8 - 42A	8167	Day Room	Mastic w/12"x12" Beige Vinyl Floor Tile w/Green Streaks	NAD	-	-	-	-
8 - 42B	8167	Day Room	Mastic w/12"x12" Beige Vinyl Floor Tile w/Green Streaks	NAD	-	-	-	-
8 - 42C	8167	Day Room	Mastic w/12"x12" Beige Vinyl Floor Tile w/Green Streaks	NAD	-	-	-	-
8 - 43A	8167	Day Room	Glue w/6" Gray Cove Base Coat	NAD	-	-	-	-
8 - 43B	8167	Day Room	Glue w/6" Gray Cove Base Coat	NAD	-	-	-	-
8 - 43C	8167	Day Room	Glue w/6" Gray Cove Base Coat	NAD	-	-	-	-
8 - 44A	8173	8173, 8107 8175, behind 8210, by SG021, G305, Corridor G-3, by 1193A, by 1010L, behind 2223, 2208, behind 3130, 3207, 3210, 4207, 4262, 5218, 5192, 6220A, 6207A, 7222, by 7208, 9175, by 9-68-C	Pipe Insulation	25% Chrysotile	Damaged	195	LF	2
8 - 44B	8173			Stop Positive See 8 - 44A				
8 - 44C	8107			Stop Positive See 8 - 44A				

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
8 - 45A	8173	8173, 8107 8175, behind 8210, by SG021, G305, Corridor G-3, by 1193A, by 1010L, behind 2223, 2208, behind 3130, 3207, 3210, 4207, 4262, 5218, 5192, 6220A, 6207A, 7222, by 7208, 9175, by 9-68-C	Pipe Fitting Insulation	50% Chrysotile	Damaged	20	LF	2
8 - 45B	8173			Stop Positive See 8 – 45A				
8 - 45C	8107			Stop Positive See 8 – 45A				
8 - 46A	8177	Office	Glue w/Brown Carpet	NAD	-	-	-	-
8 - 46B	8177	Office	Glue w/Brown Carpet	NAD	-	-	-	-
8 - 46C	8177	Office	Glue w/Brown Carpet	NAD	-	-	-	-
9 - 18B	9 - 77 - C	Lobby	12"x12" White Vinyl Floor Tiles Blue/ Red Specks	NAD	-	-	-	-
9 - 18C	9 - 77 - C	Lobby	12"x12" White Vinyl Floor Tiles Blue/ Red Specks	NAD	-	-	-	-
9 - 19A	9 - 77 - C	Lobby	Glue Under 12" White Vinyl Floor Tiles	NAD	-	-	-	-
9 - 19B	9 - 77 - C	Lobby	Glue Under 12" White Vinyl Floor Tiles	NAD	-	-	-	-
9 - 19C	9 - 77 - C	Lobby	Glue Under 12" White Vinyl Floor Tiles	NAD	-	-	-	-
9 - 20A	Corridor 9-75-M	Corridor 9-76-A Corridor 9-75-M , 9-77-C, 9-1-M 9164, 9-76-M, 9- 77-M 9-78-M	9"x9" Light Brown Vinyl Acrylic Tile with Black Streaks	4% Chrysotile	Good	2466	SF	4
9 - 20B	Corridor 9-75-M			4% Chrysotile				
9 - 20C	Corridor 9-76-M			4% Chrysotile				
9 - 21A	Hallway	Corridor	Mastic Under 9"x9" Light Brown	NAD	-	-	-	-
9 - 21B	Hallway	Corridor	Mastic Under 9"x9" Light Brown	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
9 - 21C	Hallway	Corridor	Mastic Under 9"x9' Light Brown	NAD	-	-	-	-
9 - 22A	Hallway	Corridor	12"x12" Light Green Vinyl Floor Tiles w Tan Specks	NAD	-	-	-	-
9 - 22B	Hallway	Corridor	12"x12" Light Green Vinyl Floor Tiles w Tan Specks	NAD	-	-	-	-
9 - 22C	Hallway	Corridor	12"x12" Light Green Vinyl Floor Tiles w Tan Specks	NAD	-	-	-	-
9 - 23A	Hallway	Corridor	Glue Under 12 Light Green	NAD	-	-	-	-
9 - 23B	Hallway	Corridor	Glue Under 12 Light Green	NAD	-	-	-	-
9 - 23C	Hallway	Corridor	Glue Under 12 Light Green	NAD	-	-	-	-
9 - 24A	Corridor 9-76-A	Corridor 9-76-A, Corridor 9-75-M, 9-77-C	Dark Brown Boarder Vinyl Acrylic Tile	3% Chrysotile	Good	434	SF	4
9 - 24B	Corridor 9-75-M			3% Chrysotile				
9 - 24C	9-1-M			3% Chrysotile				
9 - 25A	9-156	9151, 9143, 9136, 9152, 9158, 9156	12"x12" Cream Vinyl Floor Tile w Tan Specks 12"x12"	2% Chrysotile	Good	2231	SF	4
9 - 25B	9-152			2% Chrysotile				
9 - 25C	9-152			2% Chrysotile				
9 - 26A	9-156	Room	Glue Under 12" Cream	NAD	-	-	-	-
9 - 26B	9-156	Room	Glue Under 12" Cream	NAD	-	-	-	-
9 - 26C	9-152	Room	Glue Under 12" Cream	NAD	-	-	-	-
9 - 27A	9-160	9160 9162	9"x9" Gray Vinyl Acrylic Tile w Black & White Streaks	7% Chrysotile	Good	589	SF	4
9 - 27B	9-162			7% Chrysotile				
9 - 27C	9-162			7% Chrysotile				
9 - 28A	9-160	9160 9162	Mastic Under 9"x9" Gray Vinyl Acrylic Tile w Black & White Streaks	3% Chrysotile	Good	589	SF	4
9 - 28B	9-162			3% Chrysotile				
9 - 28C	9-162			3% Chrysotile				

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
9 - 29A	9-160	9160, 9162, Corridor 9-78-M, 9108, 9106, 9109, 9104, 9101, 9116	Black Boarder Vinyl Acrylic Tile	5% Chrysotile	Good	259	4	4
9 - 29B	9-162			5% Chrysotile				
9 - 29C	9-162			5% Chrysotile				
9 - 30A	9-129	Office	12"x12" Cream Vinyl Floor Tiles w Gray Specks	NAD	-	-	-	-
9 - 30B	9-129	Office	12"x12" Cream Vinyl Floor Tiles w Gray Specks	NAD	-	-	-	-
9 - 30C	9-129	Office	12"x12" Cream Vinyl Floor Tiles w Gray Specks	NAD	-	-	-	-
9 - 31A	9-129	9131, 9129, 9128, 9175, 9170, 9171	Glue Under 12" Cream VFT w/ Gray Specks	3% Chrysotile	Good	860	SF	4
9 - 31B	9-175			3% Chrysotile				
9 - 31C	9-129			3% Chrysotile				
9 - 32A	9-120	Office	Blue Gray Carpet Squares Glue	NAD	-	-	-	-
9 - 32B	9-162	Lab	Blue Gray Carpet Squares Glue	NAD	-	-	-	-
9 - 32C	9-168	Lab	Blue Gray Carpet Squares Glue	NAD	-	-	-	-
9 - 33A	Stair 1	Stairway	Yellow Poured Flooring	NAD	-	-	-	-
9 - 33B	Stair 1	Stairway	Yellow Poured Flooring	NAD	-	-	-	-
9 - 33C	Stair 3	Stairway	Yellow Poured Flooring	NAD	-	-	-	-
9 - 34A	9-171	Office	Glue w/Dark Blue Carpet	NAD	-	-	-	-
9 - 34B	9-122	Office	Glue w/Dark Blue Carpet	NAD	-	-	-	-
9 - 34C	9-122B	Storage	Glue w/Dark Blue Carpet	NAD	-	-	-	-
9 - 35A	Stair 2	Stairway	Glue w/Light Blue Carpet	NAD	-	-	-	-
9 - 35B	Hallway	Corridor	Glue w/Light Blue Carpet	NAD	-	-	-	-
9 - 35C	Hallway	Corridor	Glue w/Light Blue Carpet	NAD	-	-	-	-
9 - 36A	9-106	Office	Glue w/Purple Carpet	NAD	-	-	-	-
9 - 36B	9-108	Office	Glue w/Purple Carpet	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
9 - 36C	9-174	Exam	Glue w/Purple Carpet	NAD	-	-	-	-
9 - 37A	Elevator Lobby	Lobby	Glue w/6" Gray Cove Base	NAD	-	-	-	-
9 - 37B	Elevator Lobby	Lobby	Glue w/6" Gray Cove Base	NAD	-	-	-	-
9 - 37C	Elevator Lobby	Lobby	Glue w/6" Gray Cove Base	NAD	-	-	-	-
9 - 38A	Hallway	Corridor	Glue w/6" Black Cove Base	NAD	-	-	-	-
9 - 38B	Hallway	Corridor	Glue w/6" Black Cove Base	NAD	-	-	-	-
9 - 38C	Hallway	Corridor	Glue w/6" Black Cove Base	NAD	-	-	-	-
9 - 39A	9-165	Office	Glue w/6" Brown Cove Base	NAD	-	-	-	-
9 - 39B	9-165	Office	Glue w/6" Brown Cove Base	NAD	-	-	-	-
9 - 39C	9-165	Office	Glue w/6" Brown Cove Base	NAD	-	-	-	-
9 - 40A	9-171	Office	Glue w/6" Light Blue Cove Base	NAD	-	-	-	-
9 - 40B	9-170	Office	Glue w/6" Light Blue Cove Base	NAD	-	-	-	-
9 - 40C	9-170	Office	Glue w/6" Light Blue Cove Base	NAD	-	-	-	-
9 - 41A	9-116	Office	Glue w/Brown Carpet	NAD	-	-	-	-
9 - 41B	9-116	Office	Glue w/Brown Carpet	NAD	-	-	-	-
9 - 41C	9-116	Office	Glue w/Brown Carpet	NAD	-	-	-	-
9 - 42A	9-108	Corridor 9-78-M, 9108, 9106, 9109, 9104, 9101, 9116	9"x9" Green Vinyl Floor Tiles	7% Chrysotile	Good	1583	SF	4
9 - 42B	9-108		9"x9" Green Vinyl Floor Tiles	7% Chrysotile				
9 - 42C	9-108		9"x9" Green Vinyl Floor Tiles	7% Chrysotile				
9 - 43A	9-108	Office	Mastic w/9"x9" Green Vinyl Floor Tiles	NAD	-	-	-	-
9 - 43B	9-108	Office	Mastic w/9"x9" Green Vinyl Floor Tiles	NAD	-	-	-	-
9 - 43C	9-108	Office	Mastic w/9"x9" Green Vinyl Floor Tiles	NAD	-	-	-	-
9 - 44A	Stair 1	Stairway	Red Fire Stop Putty	NAD	-	-	-	-
9 - 44B	Stair 2	Stairway	Red Fire Stop Putty	NAD	-	-	-	-
9 - 44C	Stair 3	Stairway	Red Fire Stop Putty	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
9 - 45A	9-112	Mechanical	Wallboard	NAD	-	-	-	-
9 - 45B	9-1-M	Corridor	Wallboard	NAD	-	-	-	-
9 - 45C	9-1-M	Corridor	Wallboard	NAD	-	-	-	-
9 - 46A	9-112	Mechanical	Wallboard Compound	NAD	-	-	-	-
9 - 46B	9-1-M	Corridor	Wallboard Compound	NAD	-	-	-	-
9 - 46C	9-1-M	Corridor	Wallboard Compound	NAD	-	-	-	-
9 - 47A	9-111	Toilet	2'x4' Suspended Ceiling Tile Bird Track	NAD	-	-	-	-
9 - 47B	Elevator Lobby	Lobby	2'x4' Suspended Ceiling Tile Bird Track	NAD	-	-	-	-
9 - 47C	9-76-A	Corridor	2'x4' Suspended Ceiling Tile Bird Track	NAD	-	-	-	-
9 - 48A	Ladies' BR	Toilet	2'x4' Suspended Ceiling Tile Pinholes	NAD	-	-	-	-
9 - 48B	Ladies BR	Toilet	2'x4' Suspended Ceiling Tile Pinholes	NAD	-	-	-	-
9 - 48C	9-124A	Lab	2'x4' Suspended Ceiling Tile Pinholes	NAD	-	-	-	-
9 - 49A	9-133	Laundry	Plaster Ceiling Skim Coat	NAD	-	-	-	-
9 - 49B	Hallway at 9-147	Corridor	Plaster Ceiling Skim Coat	NAD	-	-	-	-
9 - 49C	Hallway at 9-115	Corridor	Plaster Ceiling Skim Coat	NAD	-	-	-	-
9 - 50A	9-133	Laundry	Plaster Ceiling Base Coat	NAD	-	-	-	-
9 - 50B	Hallway at 9-147	Corridor	Plaster Ceiling Base Coat	NAD	-	-	-	-
9 - 50C	Hallway at 9-115	Corridor	Plaster Ceiling Base Coat	NAD	-	-	-	-
9 - 51A	9-115	Office	12"x12" Fixed Ceiling Tile	NAD	-	-	-	-
9 - 51B	9-115	Office	12"x12" Fixed Ceiling Tile	NAD	-	-	-	-
9 - 51C	9-115	Office	12"x12" Fixed Ceiling Tile	NAD	-	-	-	-
9 - 52A	9-106	Office	Wall Plaster Skim Coat	NAD	-	-	-	-
9 - 52B	9-117	Conference	Wall Plaster Skim Coat	NAD	-	-	-	-
9 - 52C	Stair 1	Stairway	Wall Plaster Skim Coat	NAD	-	-	-	-
9 - 53A	9-106	Office	Wall Plaster Base Coat	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
9 - 53B	9-117	Conference	Wall Plaster Base Coat	NAD	-	-	-	-
9 - 53C	Stair 1	Stairway	Wall Plaster Base Coat	NAD	-	-	-	-
9 - 54A	9-115	Office	Glue Dots w/12"x12" Fixed Ceiling Tile	NAD	-	-	-	-
9 - 54B	9-115	Office	Glue Dots w/12"x12" Fixed Ceiling Tile	NAD	-	-	-	-
9 - 54C	9-115	Office	Glue Dots w/12"x12" Fixed Ceiling Tile	NAD	-	-	-	-
11 - Penthouse - 1A	Penthouse	Mechanical	Window Caulk	NAD	-	-	-	-
11 - Penthouse - 1B	Penthouse	Mechanical	Window Caulk	NAD	-	-	-	-
11 - Penthouse - 1C	Penthouse	Mechanical	Window Caulk	NAD	-	-	-	-
11 - Penthouse - 2A	Penthouse	Mechanical	Red Putty Fire Stop	NAD	-	-	-	-
11 - Penthouse - 2B	Penthouse	Mechanical	Red Putty Fire Stop	NAD	-	-	-	-
11 - Penthouse - 2C	Penthouse	Mechanical	Red Putty Fire Stop	NAD	-	-	-	-
11 - Penthouse - 3A	Penthouse	Mechanical	Wallboard	NAD	-	-	-	-
11 - Penthouse - 3B	Penthouse	Mechanical	Wallboard	NAD	-	-	-	-
11 - Penthouse - 3C	Penthouse	Mechanical	Wallboard	NAD	-	-	-	-
11 - Penthouse - 3D	Penthouse	Mechanical	Wallboard	NAD	-	-	-	-
11 - Penthouse - 4A	Penthouse	Mechanical	Wallboard Compound	NAD	-	-	-	-
11 - Penthouse - 4B	Penthouse	Mechanical	Wallboard Compound	NAD	-	-	-	-
11 - Penthouse - 4C	Penthouse	Mechanical	Wallboard Compound	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
11-Penthouse - 4D	Penthouse	Mechanical	Wallboard Compound	NAD	-	-	-	-
11 - Penthouse - 5A	Penthouse	Mechanical	Fireproofing Insulation	NAD	-	-	-	-
10 - Penthouse - 5B	Penthouse	Mechanical	Fireproofing Insulation	NAD	-	-	-	-
11 - Penthouse - 5C	Penthouse	Mechanical	Fireproofing Insulation	NAD	-	-	-	-
10 - Penthouse - 6A	Penthouse	Mechanical	Wallboard	NAD	-	-	-	-
10 - Penthouse - 6B	Penthouse	Mechanical	Wallboard	NAD	-	-	-	-
10 - Penthouse - 6C	Penthouse	Mechanical	Wallboard	NAD	-	-	-	-
10 - Penthouse - 7A	Penthouse	Mechanical	Wallboard Compound	NAD	-	-	-	-
10 - Penthouse - 7B	Penthouse	Mechanical	Wallboard Compound	NAD	-	-	-	-
10 - Penthouse - 7C	Penthouse	Mechanical	Wallboard Compound	NAD	-	-	-	-
10 - Penthouse - 8A	Penthouse	Mechanical	Black Cement w/Rubber Flooring	NAD	-	-	-	-
10 - Penthouse - 8B	Penthouse	Mechanical	Black Cement w/Rubber Flooring	NAD	-	-	-	-
10 - Penthouse - 8C	Penthouse	Mechanical	Black Cement w/Rubber Flooring	NAD	-	-	-	-
10 - Penthouse - 9A	Penthouse	Mechanical	Black Caulk on Ducts	NAD	-	-	-	-
10 - Penthouse - 9B	Penthouse	Mechanical	Black Caulk on Ducts	NAD	-	-	-	-
10 - Penthouse - 9C	Penthouse	Mechanical	Black Caulk on Ducts	NAD	-	-	-	-
10 - Penthouse - 10A	Penthouse	Mechanical	Red Putty Fire Stop	NAD	-	-	-	-
10 - Penthouse - 10B	Penthouse	Mechanical	Red Putty Fire Stop	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*	
						Value	Units		
10 - Penthouse - 10C	Penthouse	Mechanical	Red Putty Fire Stop	NAD	-	-	-	-	
10 - Penthouse - 11A	Penthouse	Mechanical	Spray - on Fireproofing	NAD	-	-	-	-	
10 - Penthouse - 11B	Penthouse	Mechanical	Spray - on Fireproofing	NAD	-	-	-	-	
10 - Penthouse - 11C	Penthouse	Mechanical	Spray - on Fireproofing	NAD	-	-	-	-	
10 - Penthouse - 12A	Penthouse	Mechanical	Water Tank Insulation	70% Chrysotile	Good	2775	SF	4	
10 - Penthouse - 12B	Penthouse			Stop Positive See 10 – Penthouse - 12A					
10 - Penthouse - 12C	Penthouse			Stop Positive See 10 – Penthouse - 12A					
10 - Penthouse - 13A	Penthouse	Mechanical	Door Glass Panel Black Putty	NAD	-	-	-	-	
10 - Penthouse - 13B	Penthouse	Mechanical	Door Glass Panel Black Putty	NAD	-	-	-	-	
10 - Penthouse - 13C	Penthouse	Mechanical	Door Glass Panel Black Putty	NAD	-	-	-	-	
10 - Penthouse - 14A	Penthouse	Mechanical	2"x4" Suspended Ceiling Tile Slots & Pinholes	NAD	-	-	-	-	
10 - Penthouse - 14B	Penthouse	Mechanical	2"x4" Suspended Ceiling Tile Slots & Pinholes	NAD	-	-	-	-	
10 - Penthouse - 14C	Penthouse	Mechanical	2"x4" Suspended Ceiling Tile Slots & Pinholes	NAD	-	-	-	-	
10 - Penthouse - 15A	Penthouse	Mechanical	Elevator Door Frame Caulk	NAD	-	-	-	-	
10 - Penthouse - 15B	Penthouse	Mechanical	Elevator Door Frame Caulk	NAD	-	-	-	-	
10 - Penthouse - 15C	Penthouse	Mechanical	Elevator Door Frame Caulk	NAD	-	-	-	-	
10 - Penthouse - 16A	Penthouse	Mechanical	Rubber Sheet Flooring	NAD	-	-	-	-	
10 - Penthouse - 16B	Penthouse	Mechanical	Rubber Sheet Flooring	NAD	-	-	-	-	

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
10 - Penthouse - 16C	Penthouse	Mechanical	Rubber Sheet Flooring	NAD	-	-	-	-
10 - Penthouse - 17A	Penthouse	Mechanical	Seam Sealer w/Rubber Sheet Flooring	NAD	-	-	-	-
10 - Penthouse - 17B	Penthouse	Mechanical	Seam Sealer w/Rubber Sheet Flooring	NAD	-	-	-	-
10 - Penthouse - 17C	Penthouse	Mechanical	Seam Sealer w/Rubber Sheet Flooring	NAD	-	-	-	-
E - 1A	Exterior	Exterior	Door Frame White Caulk	10% Chrysotile	Good	60	LF	4
E - 1B	Exterior			Stop Positive See E - 1A				
E - 1C	Exterior			Stop Positive See E - 1A				
E - 2A	Exterior	Exterior	Window Frame Brown Caulk	NAD	-	-	-	-
E - 2B	Exterior	Exterior	Window Frame Brown Caulk	NAD	-	-	-	-
E - 2C	Exterior	Exterior	Window Frame Brown Caulk	NAD	-	-	-	-
E - 3A	Exterior	Exterior	Wall Panel Gray Caulk	NAD	-	-	-	-
E - 3B	Exterior	Exterior	Wall Panel Gray Caulk	NAD	-	-	-	-
E - 3C	Exterior	Exterior	Wall Panel Gray Caulk	NAD	-	-	-	-
E - 4A	Exterior	Exterior	Louver Hard White Caulk	7% Amosite 5% Chrysotile	Good	1365	LF	4
E - 4B	Exterior			Stop Positive See E - 4A				
E - 4C	Exterior			Stop Positive See E - 4A				
E - 5A	Exterior	Exterior	Expansion Joint Dark Brown	NAD	-	-	-	-
E - 5B	Exterior	Exterior	Expansion Joint Dark Brown	NAD	-	-	-	-
E - 5C	Exterior	Exterior	Expansion Joint Dark Brown	NAD	-	-	-	-
E - 6A	Exterior	Exterior	Window Frame Soft White Caulk	NAD	-	-	-	-
E - 6B	Exterior	Exterior	Window Frame Soft White Caulk	NAD	-	-	-	-
E - 6C	Exterior	Exterior	Window Frame Soft White Caulk	NAD	-	-	-	-
E - 7A	Exterior	Exterior	Door Frame Soft Gray Caulk	NAD	-	-	-	-
E - 7B	Exterior	Exterior	Door Frame Soft Gray Caulk	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
E - 7C	Exterior	Exterior	Door Frame Soft Gray Caulk	NAD	-	-	-	-
E - 8A	Exterior	Exterior	Expansion Joint Hard White	4% Chrysotile	Good	24	LF	4
E - 8B	Exterior			Stop Positive See E - 8A				
E - 8C	Exterior			Stop Positive See E - 8A				
E - 9A	Exterior	Exterior	Stucco	NAD	-	-	-	-
E - 9B	Exterior	Exterior	Stucco	NAD	-	-	-	-
E - 9C	Exterior	Exterior	Stucco	NAD	-	-	-	-
E - 10A	Exterior	Exterior	Expansion Joint Gray Caulk	NAD	-	-	-	-
E - 10B	Exterior	Exterior	Expansion Joint Gray Caulk	NAD	-	-	-	-
E - 10C	Exterior	Exterior	Expansion Joint Gray Caulk	NAD	-	-	-	-
AC - 9 - 1A	Elevator Lobby	Elevator Lobby	Spray - On Fire Proofing	NAD	-	-	-	-
AC - 9 - 1B	Elevator Lobby	Elevator Lobby	Spray - On Fire Proofing	NAD	-	-	-	-
AC - 9 - 1C	Elevator Lobby	Elevator Lobby	Spray - On Fire Proofing	NAD	-	-	-	-
AC - 8 - 1D	Elevator Lobby	Elevator Lobby	Spray - On Fire Proofing	NAD	-	-	-	-
AC - 7 - 1E	Elevator Lobby	Elevator Lobby	Spray - On Fire Proofing	NAD	-	-	-	-
AC - 6 - 1F	Elevator Lobby	Elevator Lobby	Spray - On Fire Proofing	NAD	-	-	-	-
AC - 2 - 1G	2212	Dining Room	Spray - On Fire Proofing	NAD	-	-	-	-
AC - G - 1H	G157	Corridor	Spray - On Fire Proofing	NAD	-	-	-	-
AC - 8 - 2A	8155	Hallway Outside 8155	Cork Duct Insulation	NAD	-	-	-	-
AC - 8 - 2B	8155	Hallway Outside 8155	Cork Duct Insulation	NAD	-	-	-	-
AC - 8 - 2C	8155	Hallway Outside 8155	Cork Duct Insulation	NAD	-	-	-	-
AC - 7 - 3A	7154	Corridor	Duct Seal or Glue (Yellow)	NAD	-	-	-	-
AC - 7 - 3B	7154	Corridor	Duct Seal or Glue (Yellow)	NAD	-	-	-	-
AC - 7 - 3C	7138	Corridor Outside 7138	Duct Seal or Glue (Yellow)	NAD	-	-	-	-
AC - 5 - 4A	5157	Corridor Outside 5157	Duct Seal or Glue (Gray)	NAD	-	-	-	-
AC - 5 - 4B	5128	Corridor Outside 5128	Duct Seal or Glue (Gray)	NAD	-	-	-	-
AC - 5 - 4C	5132	Corridor Outside 5132	Duct Seal or Glue (Gray)	NAD	-	-	-	-

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
AC - 6 - 5A	6130A	Sub-Ground: Corridor SG-1, SG 170 Ground: G210, G206, G205, 205A, G- 117-E, 275,G-1, Corridor 252, Corridor 250, Corridor G-2, Corridor 288, Ramp First: 1163, 1146, 1147, 1148, 1149, 1150, 1151,152A,,1155 Second: 2132 Third: 3142, 3141, 3140, 3139, 3134, 3133, 3130 bed#1, 3130 bed#2 Fourth: 4220B, 4222, Corridor B3, Corridor B2, 4213, 4212, 4210, 4210, 4245, 4208, 4258, 4259, Elevator Lobby, Corridor 1-1, 4151, 4150, 4113 Fifth: 5203A, 204, 5203, 203B, Corridor AA, 5211, 214, 5215, 5216 Sixth: 6130A, 132, 6138, 6139, 6140, 6141, 6170, 6170, 6171, 6172, 6173, 6174, 6175,	Pipe Insulation	60% Chrysotile & 3% Amosite	Damaged	3275	LF	2
AC - 6 - 5B	6130A				Stop Positive See AC - 6 - 5A			

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
AC - 6 - 5C	6130A	6176, 174A, 6169, 6168A, 6167, 6166, 6165, 6164, 6163, 6180, 6180RR, 6204, 6205, 6210, 6210A, 6104, 6105A, 6127A, 6127, 6148, Corridor 6-1 Seventh: 7208, Corridor 7154C, Corridor 7-2 Eighth: 8209A, 8150, Corridor 8-1, Corridor 8-2, Corridor 8-3, Corridor 8-3, Elevator Lobby				Stop Positive See AC - 6 - 5A		
AC - 2 - 6A	2162	Hallway Outside 2162	Duct Seal or (Gray)	NAD	-	-	-	-
AC - 2 - 6B	2182B	Hallway Outside 2182B	Duct Seal or (Gray)	NAD	-	-	-	-
AC - 2 - 6C	2176	Hallway Outside 2176	Duct Seal or (Gray)	NAD	-	-	-	-
AC - 2 - 7A	2-56-M	Hallway Outside 2-56-M	Cork Debris Laying On Suspending Ceiling Tiles	NAD	-	-	-	-
AC - G - 8A	Corridor 288	Sub Sub-Ground:	Pipe Fitting	25% Chrysotile	Damaged	330	LF	2
AC - G - 8B	Corridor 288	SS-4-M, SS-2-M, Corridor SS-9-M						

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*
						Value	Units	
AC - G - 8C	Corridor 288				Stop Positive See AC - G - 8A			

**Table 4 - Summary of ACM Building Results
West Haven VA Medical Center, Building 1**

Sample No.	Sample Location	ACM Location	Description of Material	Percent and Type of Asbestos	Condition	Estimated Quantity		VISN 1 RISK Hazard Category 1 - 4*	
						Value	Units		
AC - SG - 9A	SG139	Corridor	Spray - On Fire Proofing	NAD	-	-	-	-	
AC - SG - 9B	SG125	Corridor	Spray - On Fire Proofing	NAD	-	-	-	-	
AC - SG - 9C	SG130	Waiting	Spray - On Fire Proofing	NAD	-	-	-	-	
AC - SG - 10A	Corridor SG024	Corridor SG024	Black Wall Mastic	10% Chrysotile	Damaged	63	LF	3	
AC - SG - 10B	Corridor SG024			Stop Positive See AC- SG - 10A					
AC - SG - 10C	Corridor SG024			Stop Positive See AC- SG - 10A					
<p>Footnotes:</p> <p>1 - Analyzed by TEM</p> <p>NAD - No Asbestos Detected (PLM) ND - None Detected (TEM)</p> <p>TR - Trace SF - Square Feet LF - Linear Feet EA - Each CF - Cubic Feet</p> <p>* - The VISN 1 hazard assessment scale 1 – 4 is a relative indicator of the risk and need for response/remediation. (1) represents the highest priority (e.g. removal or encapsulation) whereas a (4) represents the lowest priority (monitor as part of 6 month O&M program). The rating, assigned by an Asbestos Management Planner, takes into account the following criteria: condition, friable vs. non - friable, accessibility, occupancy (e.g. continuous, intermittent or occasional, patients/staff/visitors), potential for air erosion, potential for vibration damage, potential for disturbance/damage (e.g. exposed and in an accessible location), and potential for water damage.</p>									

Appendix B

Table 5 Summary of XRF Measurements

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
68	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE FLOOR	SOUTH - C	INTACT	GRAY	0.03
69	ELEVENTH	PENTHOUSE MAIN RM 1	METAL DOOR CASING	NORTH - A	Not Intact - POOR	RED	2.7
70	ELEVENTH	PENTHOUSE MAIN RM 1	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	RED	0
71	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE BLOCK WALL	SOUTH - C	INTACT	WHITE	0.01
72	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE BLOCK WALL	SOUTH - C	INTACT	WHITE	0.01
73	ELEVENTH	PENTHOUSE MAIN RM 1	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0
74	ELEVENTH	PENTHOUSE MAIN RM 1	METAL PIPE	SOUTH - C	INTACT	WHITE	0.4
78	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE LOUVER CASING	SOUTH - C	INTACT	WHITE	0.6
79	ELEVENTH	PENTHOUSE MAIN RM 1	METAL LOUVER LINTEL	SOUTH - C	INTACT	WHITE	8.6
80	ELEVENTH	PENTHOUSE MAIN RM 1	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
81	ELEVENTH	PENTHOUSE MAIN RM 1	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0.01
82	ELEVENTH	PENTHOUSE MAIN RM 1	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	TAN	0.02
83	ELEVENTH	PENTHOUSE MAIN RM 1	METAL DOOR	SOUTH - C	Not Intact - POOR	GRAY	0
84	ELEVENTH	PENTHOUSE MAIN RM 1	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	WHITE	1.3
85	ELEVENTH	PENTHOUSE MAIN RM 1	METAL DOOR LINTEL	SOUTH - C	INTACT	WHITE	14.7
86	ELEVENTH	PENTHOUSE MAIN RM 1	METAL THRESHOLD	SOUTH - C	Not Intact - POOR	GRAY	30.6
89	ELEVENTH	PENTHOUSE MAIN RM 1	METAL CAGE	SOUTH - C	INTACT	GRAY	0
90	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE COLUMN	EAST - B	INTACT	WHITE	0.01
91	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE COLUMN	SOUTH - C	INTACT	WHITE	0.5
92	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE COLUMN	WEST - D	INTACT	WHITE	0.01
94	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE COLUMN	NORTH - A	INTACT	WHITE	0
95	ELEVENTH	PENTHOUSE MAIN RM 1	WOOD PANEL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
97	ELEVENTH	PENTHOUSE MAIN RM 1	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
98	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE WINDOW CASING	SOUTH - C	INTACT	WHITE	0.03
99	ELEVENTH	PENTHOUSE MAIN RM 1	WOOD BOARD	SOUTH - C	INTACT	BLACK	0
100	ELEVENTH	PENTHOUSE MAIN RM 1	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0
102	ELEVENTH	PENTHOUSE MAIN RM 1	METAL PIPE	WEST - D	INTACT	WHITE	0.06
103	ELEVENTH	PENTHOUSE MAIN RM 1	METAL PIPE	WEST - D	INTACT	WHITE	0.27
104	ELEVENTH	PENTHOUSE MAIN RM 1	METAL PIPE	WEST - D	INTACT	WHITE	0.08

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
105	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE FLOOR	WEST - D	Not Intact - POOR	GRAY	0.06
106	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE BLOCK WALL	WEST - D	INTACT	WHITE	0
107	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE BLOCK WALL	NORTH - A	INTACT	WHITE	0.01
108	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE BLOCK WALL	EAST - B	INTACT	WHITE	0
109	ELEVENTH	PENTHOUSE MAIN RM 1	METAL CONDUIT	EAST - B	INTACT	WHITE	0
110	ELEVENTH	PENTHOUSE MAIN RM 1	METAL ELECTRICAL BOX MOUNT	EAST - B	INTACT	GRAY	0.05
111	ELEVENTH	PENTHOUSE MAIN RM 1	METAL ELECTRICAL BOX MOUNT	EAST - B	INTACT	GRAY	0.02
112	ELEVENTH	PENTHOUSE MAIN RM 1	METAL ELECTRICAL BOX MOUNT	EAST - B	INTACT	GRAY	0
114	ELEVENTH	PENTHOUSE MAIN RM 1	METAL CONDUIT	NORTH - A	INTACT	WHITE	0
115	ELEVENTH	PENTHOUSE MAIN RM 1	METAL WINDOW CASING	NORTH - A	Not Intact - POOR	WHITE	0
117	ELEVENTH	PENTHOUSE MAIN RM 1	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
118	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	GRAY	0.06
119	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE FLOOR	EAST - B	Not Intact - POOR	GRAY	0.01
121	ELEVENTH	PENTHOUSE MAIN RM 1	METAL COMPRESSOR	EAST - B	Not Intact - POOR	GREEN	0.07
122	ELEVENTH	PENTHOUSE MAIN RM 1	METAL CAGE	NORTH - A	INTACT	GRAY	0.01
123	ELEVENTH	PENTHOUSE MAIN RM 1	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.02
124	ELEVENTH	PENTHOUSE MAIN RM 1	METAL DOOR	NORTH - A	Not Intact - POOR	GRAY	0
125	ELEVENTH	PENTHOUSE MAIN RM 1	METAL DOOR CASING	NORTH - A	Not Intact - POOR	WHITE	2.2
126	ELEVENTH	PENTHOUSE MAIN RM 1	METAL DOOR LINTEL	NORTH - A	INTACT	WHITE	8.8
127	ELEVENTH	PENTHOUSE MAIN RM 1	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0
128	ELEVENTH	PENTHOUSE MAIN RM 1	METAL THRESHOLD	NORTH - A	Not Intact - POOR	GRAY	23.7
129	ELEVENTH	PENTHOUSE MAIN RM 1	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
130	ELEVENTH	PENTHOUSE MAIN RM 1	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.01
132	ELEVENTH	PENTHOUSE MAIN RM 1	CONCRETE WINDOW CASING	NORTH - A	INTACT	WHITE	0
133	ELEVENTH	PENTHOUSE MAIN RM 1	METAL PIPE	WEST - D	INTACT	WHITE	0.04
134	ELEVENTH	PENTHOUSE MAIN RM 1	METAL HATCH	WEST - D	Not Intact - POOR	YELLOW	12.5
135	ELEVENTH	PENTHOUSE MAIN RM 1	METAL I - BEAM	WEST - D	Not Intact - POOR	GRAY	12
136	ELEVENTH	PENTHOUSE MAIN RM 1	METAL FIRE SPRINKLER PIPE	WEST - D	INTACT	RED	0.15
137	ELEVENTH	PENTHOUSE SIDE ROOM	METAL STAIR STRINGER	EAST - B	INTACT	GRAY	0.01

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
138	ELEVENTH	PENTHOUSE SIDE ROOM	METAL STAIR HANDRAIL	EAST - B	INTACT	GRAY	0
139	ELEVENTH	PENTHOUSE SIDE ROOM	METAL MOTOR	WEST - D	INTACT	BLUE	0.04
140	ELEVENTH	PENTHOUSE SIDE ROOM	METAL I - BEAM	WEST - D	INTACT	RED	0.02
142	ELEVENTH	PENTHOUSE SIDE ROOM	METAL I - BEAM	WEST - D	INTACT	RED	0
144	ELEVENTH	PENTHOUSE SIDE ROOM	METAL BEAM	WEST - D	INTACT	RED	0
145	ELEVENTH	PENTHOUSE SIDE ROOM	METAL FAN	WEST - D	INTACT	TAN	0
146	ELEVENTH	PENTHOUSE SIDE ROOM	METAL BEAM	SOUTH - C	INTACT	RED	0
147	ELEVENTH	PENTHOUSE SIDE ROOM	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0
149	ELEVENTH	PENTHOUSE SIDE ROOM	METAL MOTOR	SOUTH - C	INTACT	BLUE	4.4
150	ELEVENTH	PENTHOUSE SIDE ROOM	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
151	ELEVENTH	PENTHOUSE SIDE ROOM	CONCRETE FLOOR	WEST - D	INTACT	GRAY	0
152	ELEVENTH	PENTHOUSE SIDE ROOM	METAL COLUMN	EAST - B	INTACT	RED	0
153	ELEVENTH	PENTHOUSE SIDE ROOM	METAL DOOR	EAST - B	INTACT	GRAY	0
154	ELEVENTH	PENTHOUSE SIDE ROOM	METAL DOOR CASING	EAST - B	INTACT	GRAY	0
155	ELEVENTH	ELEVATOR MECH. RM 2	METAL DOOR CASING	WEST - D	INTACT	GRAY	0
156	ELEVENTH	ELEVATOR MECH. RM 2	METAL DOOR	WEST - D	INTACT	GRAY	0
157	ELEVENTH	ELEVATOR MECH. RM 2	METAL DOOR LINTEL	WEST - D	Not Intact - POOR	RED	0
158	ELEVENTH	ELEVATOR MECH. RM 2	METAL I - BEAM	EAST - B	INTACT	RED	0.01
159	ELEVENTH	ELEVATOR MECH. RM 2	METAL I - BEAM	EAST - B	INTACT	RED	0.01
160	ELEVENTH	ELEVATOR MECH. RM 2	METAL BEAM	EAST - B	INTACT	RED	0
161	ELEVENTH	ELEVATOR MECH. RM 2	METAL BEAM	NORTH - A	INTACT	RED	0
162	ELEVENTH	ELEVATOR MECH. RM 2	METAL ELEVATOR MOTOR	NORTH - A	INTACT	BLUE	0
163	ELEVENTH	ELEVATOR MECH. RM 2	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
165	ELEVENTH	ELEVATOR MECH. RM 2	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
166	ELEVENTH	ELEVATOR MECH. RM 2	CONCRETE FLOOR	EAST - B	INTACT	GRAY	0
167	ELEVENTH	ELEVATOR MECH. RM 2	METAL MOTOR	EAST - B	INTACT	GRAY	4.2
168	ELEVENTH	ELEVATOR MECH. RM 2	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0
169	ELEVENTH	ELEVATOR MECH. RM 2	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0
170	ELEVENTH	ELEVATOR MECH. RM 2	METAL ELECTRICAL BOX MOUNT	EAST - B	INTACT	GRAY	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
171	ELEVENTH	ELEVATOR MECH. RM 2	METAL ELECTRICAL BOX MOUNT	EAST - B	INTACT	GRAY	0.01
173	ELEVENTH	ELEVATOR MECH. RM 2	METAL TRANSFORMER	WEST - D	INTACT	GRAY	0
174	TENTH	MAIN RM 1	METAL STAIR TREAD	WEST - D	INTACT	GRAY	0
175	TENTH	MAIN RM 1	METAL STAIR STRINGER	WEST - D	INTACT	GRAY	0
176	TENTH	MAIN RM 1	METAL STAIR HANDRAIL	WEST - D	INTACT	GRAY	0.01
177	TENTH	MAIN RM 1	METAL DOOR	WEST - D	INTACT	GRAY	0
178	TENTH	MAIN RM 1	METAL DOOR CASING	WEST - D	INTACT	GRAY	0
179	TENTH	MAIN RM 1	METAL WALL	WEST - D	INTACT	GREEN	0
180	TENTH	MAIN RM 1	METAL WALL	WEST - D	INTACT	GREEN	0
181	TENTH	MAIN RM 1	METAL FIRE SPRINKLER PIPE	WEST - D	INTACT	RED	0
182	TENTH	MAIN RM 1	METAL FIRE SPRINKLER PIPE	WEST - D	INTACT	RED	0.04
184	TENTH	MAIN RM 1	METAL BEAM	WEST - D	INTACT	RED	0
185	TENTH	MAIN RM 1	METAL FIRE EXTINGUISHER CASING	WEST - D	INTACT	WHITE	0
186	TENTH	MAIN RM 1	METAL I - BEAM	SOUTH - C	Not Intact - POOR	RED	0
187	TENTH	MAIN RM 1	METAL I - BEAM	SOUTH - C	Not Intact - POOR	RED	0
188	TENTH	MAIN RM 1	METAL I - BEAM	SOUTH - C	Not Intact - POOR	RED	0.01
189	TENTH	MAIN RM 1	METAL BEAM	SOUTH - C	Not Intact - POOR	RED	0
190	TENTH	MAIN RM 1	METAL WALL	SOUTH - C	INTACT	GREEN	0
191	TENTH	MAIN RM 1	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0
192	TENTH	MAIN RM 1	METAL HVAC UNIT	SOUTH - C	INTACT	GRAY	0.01
193	TENTH	MAIN RM 1	METAL HVAC UNIT	SOUTH - C	INTACT	GRAY	0
194	TENTH	MAIN RM 1	METAL TRANSFORMER	NORTH - A	INTACT	GRAY	0.02
195	TENTH	MAIN RM 1	METAL TRANSFORMER	NORTH - A	INTACT	GRAY	0.02
196	TENTH	MAIN RM 1	METAL WALL	NORTH - A	INTACT	GREEN	0
197	TENTH	MAIN RM 1	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	TAN	0
198	TENTH	MAIN RM 1	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
199	TENTH	MAIN RM 1	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
200	TENTH	MAIN RM 1	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
201	TENTH	MAIN RM 1	METAL FIRE EXTINGUISHER CASING	WEST - D	INTACT	WHITE	0
202	TENTH	MAIN RM 1	METAL DOOR	WEST - D	Not Intact - POOR	GRAY	0
203	TENTH	MAIN RM 1	METAL DOOR CASING	WEST - D	Not Intact - POOR	GRAY	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
204	TENTH	MAIN RM 1	METAL TRANSFORMER	WEST - D	INTACT	GRAY	0
205	TENTH	MAIN RM 1	METAL THRESHOLD	WEST - D	Not Intact - POOR	GRAY	20.7
206	TENTH	MAIN RM 2	METAL DOOR CASING	NORTH - A	INTACT	RED	3.9
207	TENTH	MAIN RM 2	CONCRETE BLOCK WALL	EAST - B	Not Intact - POOR	TAN	0.3
208	TENTH	MAIN RM 2	CONCRETE BLOCK WALL	NORTH - A	Not Intact - POOR	TAN	0.01
210	TENTH	MAIN RM 2	CONCRETE COLUMN	EAST - B	Not Intact - POOR	BEIGE	0.02
211	TENTH	MAIN RM 2	CONCRETE COLUMN	EAST - B	Not Intact - POOR	TAN	0.02
212	TENTH	MAIN RM 2	METAL STAIR STRINGER	EAST - B	INTACT	RED	0
213	TENTH	MAIN RM 2	METAL STAIR TREAD	EAST - B	Not Intact - POOR	RED	0
214	TENTH	MAIN RM 2	METAL STAIR HANDRAIL	EAST - B	Not Intact - POOR	RED	0.03
215	TENTH	MAIN RM 2	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.03
216	TENTH	MAIN RM 2	METAL CONDUIT	NORTH - A	Not Intact - POOR	BEIGE	0.1
217	TENTH	MAIN RM 2	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
218	TENTH	MAIN RM 2	WALLBOARD WINDOW CASING	NORTH - A	Not Intact - POOR	WHITE	0
219	TENTH	MAIN RM 2	CONCRETE WINDOW CASING	NORTH - A	INTACT	WHITE	0.03
220	TENTH	MAIN RM 2	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	GRAY	0
223	TENTH	MAIN RM 2	CONCRETE BLOCK WALL	NORTH - A	Not Intact - POOR	BROWN	0.01
224	TENTH	MAIN RM 2	CONCRETE BLOCK WALL	WEST - D	Not Intact - POOR	BROWN	0.02
227	TENTH	MAIN RM 2	CONCRETE BLOCK WALL	EAST - B	Not Intact - POOR	BROWN	0.7
228	TENTH	MAIN RM 2	CONCRETE COLUMN	EAST - B	Not Intact - POOR	BROWN	0.03
229	TENTH	MAIN RM 2	CONCRETE COLUMN	EAST - B	Not Intact - POOR	BROWN	0.02
9	TENTH	MAIN RM 2	METAL LADDER	SOUTH - C	Not Intact - POOR	SILVER	3.4
10	TENTH	MAIN RM 2	METAL HATCH	SOUTH - C	INTACT	GRAY	0
11	TENTH	MAIN RM 2	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0
12	TENTH	MAIN RM 2	PLASTER WALL	WEST - D	INTACT	WHITE	0
13	TENTH	MAIN RM 2	WALLBOARD WALL	SOUTH - C	Not Intact - POOR	WHITE	0
14	TENTH	MAIN RM 2	WALLBOARD WALL	NORTH - A	Not Intact - POOR	WHITE	0
15	TENTH	MAIN RM 2	WALLBOARD WALL	EAST - B	Not Intact - POOR	WHITE	0
16	TENTH	MAIN RM 2	METAL HATCH	WEST - D	Not Intact - POOR	YELLOW	1.7
17	TENTH	MAIN RM 2	METAL HATCH CASING	WEST - D	Not Intact - POOR	RED	1.6

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
18	TENTH	MAIN RM 2	CONCRETE FLOOR	WEST - D	Not Intact - POOR	GRAY	0.01
19	TENTH	MAIN RM 2	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0
20	TENTH	MAIN RM 2	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0
21	TENTH	MAIN RM 2	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0.02
22	TENTH	MAIN RM 2	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0.01
23	TENTH	MAIN RM 2	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0.03
24	TENTH	MAIN RM 2	METAL DUCT	WEST - D	Not Intact - POOR	GRAY	0.17
25	TENTH	MAIN RM 2	METAL DUCT	WEST - D	Not Intact - POOR	GRAY	0.11
26	TENTH	MAIN RM 2	METAL DUCT	WEST - D	Not Intact - POOR	GRAY	0.12
27	TENTH	MAIN RM 2	METAL DUCT	WEST - D	Not Intact - POOR	GRAY	0.15
28	TENTH	MAIN RM 2	METAL DUCT	WEST - D	Not Intact - POOR	GRAY	0.22
29	TENTH	MAIN RM 2	METAL PIPE	WEST - D	INTACT	GRAY	0.08
30	TENTH	MAIN RM 2	METAL PIPE	WEST - D	Not Intact - POOR	GRAY	0.24
31	TENTH	MAIN RM 2	METAL PIPE	WEST - D	Not Intact - POOR	BLACK	0
32	TENTH	MAIN RM 2	METAL CONDUIT	WEST - D	Not Intact - POOR	WHITE	0.01
33	TENTH	MAIN RM 2	METAL CONDUIT	WEST - D	Not Intact - POOR	WHITE	0.4
34	TENTH	MAIN RM 2	METAL CONDUIT	WEST - D	Not Intact - POOR	WHITE	0.07
35	TENTH	MAIN RM 2	METAL CONDUIT	WEST - D	Not Intact - POOR	WHITE	0.4
39	TENTH	MAIN RM 2	CONCRETE COLUMN	WEST - D	Not Intact - POOR	WHITE	0.02
40	TENTH	MAIN RM 2	CONCRETE COLUMN	WEST - D	INTACT	WHITE	0.05
41	TENTH	MAIN RM 2	CONCRETE COLUMN	WEST - D	INTACT	TAN	0.05
42	TENTH	MAIN RM 2	METAL MOTOR	WEST - D	Not Intact - POOR	GRAY	0.15
43	TENTH	MAIN RM 2	METAL MOTOR	WEST - D	Not Intact - POOR	GRAY	0.11
44	TENTH	MAIN RM 2	METAL MOTOR	WEST - D	Not Intact - POOR	GRAY	0.24
45	TENTH	MAIN RM 2	METAL MOTOR	WEST - D	Not Intact - POOR	GRAY	0.16
47	TENTH	MAIN RM 2	CONCRETE BLOCK WALL	WEST - D	INTACT	WHITE	0.04
48	TENTH	MAIN RM 2	CONCRETE BLOCK WALL	WEST - D	INTACT	WHITE	0.5
53	TENTH	MAIN RM 2	CONCRETE COLUMN	WEST - D	Not Intact - POOR	WHITE	0.27
54	TENTH	MAIN RM 2	METAL DOOR	WEST - D	INTACT	GRAY	0
55	TENTH	MAIN RM 2	METAL DOOR CASING	WEST - D	INTACT	GRAY	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
56	TENTH	MAIN RM 2	METAL THRESHOLD	WEST - D	Not Intact - POOR	GRAY	26.6
57	TENTH	MAIN RM 2	METAL DOOR LINTEL	WEST - D	Not Intact - POOR	WHITE	13.5
58	TENTH	MAIN RM 2	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	GRAY	0
59	TENTH	MAIN RM 2	METAL PIPE	SOUTH - C	Not Intact - POOR	GRAY	0.08
60	TENTH	MAIN RM 2	METAL DOOR	WEST - D	INTACT	GRAY	0
61	TENTH	MAIN RM 2	METAL DOOR CASING	WEST - D	INTACT	GRAY	0
62	TENTH	MAIN RM 2	METAL STAIR HANDRAIL	WEST - D	Not Intact - POOR	GRAY	0
63	TENTH	MAIN RM 2	METAL STAIR STRINGER	WEST - D	Not Intact - POOR	GRAY	0
64	TENTH	MAIN RM 2	METAL STAIR TREAD	WEST - D	Not Intact - POOR	GRAY	0
65	TENTH	MAIN RM 2	METAL BEAM	WEST - D	Not Intact - POOR	RED	0
66	TENTH	MAIN RM 2	METAL OVERHEAD DOOR	WEST - D	INTACT	GRAY	0
67	TENTH	MAIN RM 2	METAL OVERHEAD DOOR CASING	WEST - D	Not Intact - POOR	GRAY	0
68	TENTH	MAIN RM 2	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	WHITE	0
69	TENTH	MAIN RM 2	METAL I - BEAM	SOUTH - C	Not Intact - POOR	RED	0
70	TENTH	MAIN RM 2	METAL MOTOR	SOUTH - C	INTACT	BLUE	0
71	TENTH	MAIN RM 2	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0
72	TENTH	MAIN RM 2	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0
74	TENTH	MAIN RM 2	METAL AC UNIT	NORTH - A	INTACT	GRAY	0
75	TENTH	MAIN RM 2	METAL AC UNIT BASE	NORTH - A	INTACT	GRAY	3.4
76	TENTH	MAIN RM 2	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0
77	TENTH	MAIN RM 2	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	WHITE	0
78	TENTH	MAIN RM 2	METAL THRESHOLD	EAST - B	Not Intact - POOR	BLACK	17.1
79	TENTH	MAIN RM 2	METAL FAN	EAST - B	INTACT	GRAY	0
80	TENTH	MAIN RM 2	METAL I - BEAM	EAST - B	Not Intact - POOR	RED	0
81	TENTH	MAIN RM 2	METAL I - BEAM	EAST - B	INTACT	RED	0
82	ELEVENTH	STAIR 3	PLASTER WALL	EAST - B	INTACT	WHITE	0.17
84	ELEVENTH	STAIR 3	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.3
85	ELEVENTH	STAIR 3	PLASTER WALL	WEST - D	INTACT	WHITE	0.17
86	ELEVENTH	STAIR 3	PLASTER WALL	NORTH - A	INTACT	WHITE	0
89	ELEVENTH	STAIR 3	PLASTER CEILING	EAST - B	INTACT	WHITE	0.03
90	ELEVENTH	STAIR 3	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0.01

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
91	ELEVENTH	STAIR 3	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	YELLOW	0.03
94	ELEVENTH	STAIR 3	METAL STAIR RISER	WEST - D	Not Intact - POOR	YELLOW	1.7
95	ELEVENTH	STAIR 3	CONCRETE STAIR TREAD	WEST - D	Not Intact - POOR	YELLOW	0.06
96	ELEVENTH	STAIR 3	METAL STAIR TREAD	WEST - D	Not Intact - POOR	BLACK	0.04
97	ELEVENTH	STAIR 3	METAL STAIR HANDRAIL	WEST - D	Not Intact - POOR	TAN	2.6
98	ELEVENTH	STAIR 3	METAL STAIR NEWEL POST	WEST - D	Not Intact - POOR	TAN	3
99	ELEVENTH	STAIR 3	METAL BASEBOARD	SOUTH - C	Not Intact - POOR	YELLOW	0.18
102	ELEVENTH	STAIR 3	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	RED	2.4
103	ELEVENTH	STAIR 3	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0.01
104	ELEVENTH	STAIR 3	METAL STAIR STRINGER	WEST - D	INTACT	TAN	3
105	TENTH	STAIR 3	METAL STAIR STRINGER	WEST - D	Not Intact - POOR	TAN	3.2
106	TENTH	STAIR 3	METAL STAIR HANDRAIL	WEST - D	Not Intact - POOR	TAN	0.7
108	TENTH	STAIR 3	METAL STAIR NEWEL POST	SOUTH - C	Not Intact - POOR	TAN	2.1
109	TENTH	STAIR 3	CONCRETE STAIR TREAD	WEST - D	Not Intact - POOR	YELLOW	0.05
110	TENTH	STAIR 3	METAL STAIR RISER	WEST - D	Not Intact - POOR	YELLOW	2.2
111	TENTH	STAIR 3	METAL STAIR TREAD	WEST - D	Not Intact - POOR	BLACK	0.05
112	TENTH	STAIR 3	METAL STAIR STRINGER	SOUTH - C	Not Intact - POOR	YELLOW	5.9
113	TENTH	STAIR 3	METAL BASEBOARD	WEST - D	Not Intact - POOR	YELLOW	0.2
114	TENTH	STAIR 3	METAL FLOOR	SOUTH - C	Not Intact - POOR	YELLOW	0.07
115	TENTH	STAIR 3	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	RED	1.8
116	TENTH	STAIR 3	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0
117	TENTH	STAIR 3	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.7
121	TENTH	STAIR 3	PLASTER WALL	WEST - D	INTACT	WHITE	0.22
122	NINTH	STAIR 3	PLASTER WALL	NORTH - A	INTACT	WHITE	0
128	NINTH	STAIR 3	PLASTER WALL	EAST - B	INTACT	WHITE	0
129	NINTH	STAIR 3	METAL FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0.08
130	NINTH	STAIR 3	METAL STAIR RISER	NORTH - A	Not Intact - POOR	YELLOW	2.3
131	NINTH	STAIR 3	CONCRETE STAIR TREAD	NORTH - A	Not Intact - POOR	YELLOW	0.03
132	NINTH	STAIR 3	METAL STAIR TREAD	NORTH - A	Not Intact - POOR	BLACK	0.01
133	NINTH	STAIR 3	METAL BASEBOARD	NORTH - A	Not Intact - POOR	YELLOW	1.4

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
134	NINTH	STAIR 3	METAL STAIR HANDRAIL	EAST - B	Not Intact - POOR	TAN	1
135	NINTH	STAIR 3	METAL GATE DOOR	SOUTH - C	Not Intact - POOR	TAN	4.8
136	NINTH	STAIR 3	METAL GATE	SOUTH - C	Not Intact - POOR	TAN	5.4
137	NINTH	STAIR 3	METAL TRIM	SOUTH - C	Not Intact - POOR	TAN	4.2
138	NINTH	STAIR 3	METAL FIRE SPRINKLER PIPE	SOUTH - C	Not Intact - POOR	RED	0.6
140	NINTH	STAIR 3	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	RED	2.3
141	FIFTH	5151A	METAL WINDOW CASING	SOUTH - C	INTACT	BLACK	0
142	FIFTH	5151A	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
144	FIFTH	5151A	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
145	FIFTH	5151A	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0
148	FIFTH	5151A	METAL AC UNIT	NORTH - A	INTACT	TAN	0
149	FIFTH	5151A	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
151	FIFTH	5150	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
152	FIFTH	5150	METAL WINDOW CASING	SOUTH - C	INTACT	BLACK	0
154	FIFTH	5150	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.4
156	FIFTH	5150	WALLBOARD WALL	NORTH - A	INTACT	BLUE	0
157	FIFTH	5150	METAL DOOR CASING	NORTH - A	INTACT	WHITE	0
158	FIFTH	5150	METAL FIRE SPRINKLER PIPE	NORTH - A	Not Intact - POOR	BLACK	0
159	FIFTH	5150	METAL ELECTRICAL BOX MOUNT	EAST - B	INTACT	GRAY	0
160	FIFTH	5150	METAL ELECTRICAL BOX MOUNT	EAST - B	INTACT	GRAY	0
161	FIFTH	5150	METAL ELECTRICAL BOX MOUNT	EAST - B	INTACT	GRAY	0
162	FIFTH	5129	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
164	FIFTH	5129	CERAMIC BLOCK WALL	EAST - B	INTACT	TAN	0.02
166	FIFTH	5129	CERAMIC BLOCK WALL	NORTH - A	INTACT	TAN	0.02
167	FIFTH	5129	CERAMIC BLOCK WALL	SOUTH - C	INTACT	TAN	0.01
168	FIFTH	5129	METAL DOOR CASING	WEST - D	Not Intact - POOR	WHITE	0
170	FIFTH	5143	METAL DOOR CASING	WEST - D	INTACT	WHITE	0
171	FIFTH	5143	WALLBOARD WALL	SOUTH - C	Not Intact - POOR	BLUE	0
172	FIFTH	5143	METAL AIR VENT - CEILING	EAST - B	INTACT	BEIGE	0
173	FIFTH	5143	METAL BOARD	NORTH - A	Not Intact - POOR	BEIGE	0
174	FIFTH	5143	METAL DOOR	WEST - D	INTACT	BLUE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
175	FIFTH	5143	METAL WALL	WEST - D	Not Intact - POOR	BLUE	3.4
176	FIFTH	CORR. 1	METAL FIRE EXTINGUISHER CASING	WEST - D	INTACT	BLUE	0
177	FIFTH	CORR. 1	METAL FIRE SPRINKLER PIPE	WEST - D	INTACT	RED	0.02
178	FIFTH	CORR. 1	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
180	FIFTH	CORR. 1	METAL AIR VENT - CEILING	WEST - D	INTACT	WHITE	0
181	FIFTH	5134	METAL AIR VENT - CEILING	WEST - D	INTACT	WHITE	0
182	FIFTH	5134	WALLBOARD WALL	WEST - D	INTACT	BLUE	0
183	FIFTH	5134	METAL HATCH	WEST - D	INTACT	GRAY	0
184	FIFTH	5134	METAL HATCH	NORTH - A	INTACT	GRAY	0
185	FIFTH	5134	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
187	FIFTH	5134	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.02
188	FIFTH	5140	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.02
189	FIFTH	5140	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
190	FIFTH	5140	WALLBOARD WALL	SOUTH - C	INTACT	BLUE	0
191	FIFTH	5140	METAL AIR VENT - CEILING	EAST - B	INTACT	TAN	- 0.24
192	FIFTH	5140	METAL DOOR CASING	EAST - B	Not Intact - POOR	WHITE	0
193	FIFTH	CORR. 2	METAL DOOR CASING	EAST - B	INTACT	BLACK	0
196	FIFTH	CORR. 2	METAL DOOR	EAST - B	INTACT	BLACK	0
197	FIFTH	CORR. 2	PLASTER WALL	SOUTH - C	INTACT	WHITE	1.9
198	FIFTH	CORR. 2	PLASTER WALL	NORTH - A	INTACT	WHITE	0
199	FIFTH	CORR. 2	METAL DOOR CASING	WEST - D	INTACT	RED	0
200	FIFTH	5100	PLASTER WALL	NORTH - A	INTACT	WHITE	0
202	FIFTH	5100	METAL WINDOW CASING	EAST - B	INTACT	WHITE	- 0.12
205	FIFTH	5100	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
208	FIFTH	5100	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
209	FIFTH	5100	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
210	FIFTH	5100	METAL DOOR CASING	SOUTH - C	INTACT	BLUE	0
211	FIFTH	5003	CONCRETE STAIR TREAD	SOUTH - C	Not Intact - POOR	YELLOW	0.06
212	FIFTH	5003	METAL STAIR RISER	WEST - D	Not Intact - POOR	YELLOW	1.4
214	FIFTH	5003	METAL STAIR TREAD	WEST - D	Not Intact - POOR	BLACK	0
215	FIFTH	5003	METAL STAIR STRINGER	SOUTH - C	INTACT	TAN	3.3
218	FIFTH	5003	METAL BASEBOARD	SOUTH - C	Not Intact - POOR	YELLOW	0.29
219	FIFTH	5003	METAL FLOOR	SOUTH - C	Not Intact - POOR	YELLOW	0.12

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
220	FIFTH	5003	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	1
223	FIFTH	5003	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	RED	1.6
226	FIFTH	5003	METAL CEILING	NORTH - A	INTACT	WHITE	0.1
227	FIFTH	5003	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.23
228	FIFTH	5002	PLASTER WALL	NORTH - A	INTACT	WHITE	0.3
231	FIFTH	5002	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.5
233	FIFTH	5002	METAL DOOR CASING	NORTH - A	INTACT	RED	1.5
234	FIFTH	5002	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.3
236	FIFTH	5002	METAL CONDUIT	WEST - D	INTACT	WHITE	0.25
238	FIFTH	5002	METAL STAIR RISER	WEST - D	INTACT	YELLOW	1.6
239	FIFTH	5002	CONCRETE STAIR TREAD	WEST - D	INTACT	YELLOW	0.02
240	FIFTH	5002	METAL STAIR TREAD	WEST - D	INTACT	BLACK	0
241	FIFTH	5002	METAL STAIR STRINGER	WEST - D	INTACT	TAN	3.6
242	FIFTH	5115	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
243	FIFTH	5115	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.02
244	FIFTH	5115	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
245	FIFTH	5115	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
246	FIFTH	5118	METAL DOOR CASING	WEST - D	Not Intact - POOR	BLUE	0
247	FIFTH	5109	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	BLUE	0
248	FIFTH	5109	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
250	FIFTH	5109	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.16
251	FIFTH	5109	PLASTER WALL	NORTH - A	Not Intact - POOR	WHITE	0.04
260	SUB SUB GROUND	SS - 4 - M	CERAMIC BLOCK WALL	NORTH - A	INTACT	WHITE	0.01
261	SUB SUB GROUND	SS - 4 - M	CERAMIC BLOCK WALL	EAST - B	INTACT	WHITE	0
262	SUB SUB GROUND	SS - 4 - M	CERAMIC BLOCK WALL	SOUTH - C	INTACT	WHITE	0.01
264	SUB SUB GROUND	SS - 4 - M	CONCRETE BLOCK WALL	WEST - D	INTACT	WHITE	0.01
265	SUB SUB GROUND	SS - 4 - M	METAL ELECTRICAL BOX MOUNT	EAST - B	INTACT	GRAY	0
266	SUB SUB GROUND	SS - 4 - M	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0.02
268	SUB SUB GROUND	SS - 4 - M	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.02
269	SUB SUB GROUND	SS - 4 - M	METAL CONDUIT	WEST - D	INTACT	BLACK	0.3
270	SUB SUB GROUND	SS - 4 - M	METAL ELEVATOR MOTOR	WEST - D	Not Intact - POOR	GRAY	0.04
271	SUB SUB GROUND	SS - 4 - M	METAL ELEVATOR MOTOR	WEST - D	Not Intact - POOR	GRAY	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
272	SUB SUB GROUND	SS - 4 - M	METAL DOOR CASING	NORTH - A	Not Intact - POOR	BEIGE	2.8
273	SUB SUB GROUND	SS - 4 - M	METAL DOOR	NORTH - A	Not Intact - POOR	BEIGE	0.06
277	SUB SUB GROUND	SS - 3 - M	METAL AIR VENT - CEILING	WEST - D	INTACT	BEIGE	0
278	SUB SUB GROUND	SS - 3 - M	METAL AIR VENT - CEILING	WEST - D	INTACT	BEIGE	0
279	SUB SUB GROUND	SS - 3 - M	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.6
280	SUB SUB GROUND	SS - 3 - M	PLASTER WALL	WEST - D	INTACT	WHITE	0
282	SUB SUB GROUND	SS - 3 - M	METAL DOOR CASING	WEST - D	INTACT	BLUE	2.6
284	SUB SUB GROUND	SS - 3 - M	PLASTER WALL	NORTH - A	Not Intact - POOR	WHITE	0.3
285	SUB SUB GROUND	SS - 3 - M	WALLBOARD CEILING	NORTH - A	Not Intact - POOR	WHITE	0
286	SUB SUB GROUND	SS - 3 - M	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0
287	SUB SUB GROUND	SS - 9 - M	METAL ELEVATOR DOOR	EAST - B	INTACT	GRAY	0.13
288	SUB SUB GROUND	SS - 9 - M	METAL ELEVATOR DOOR CASING	EAST - B	Not Intact - POOR	GRAY	0.4
289	SUB SUB GROUND	SS - 9 - M	METAL ELECTRICAL BOX MOUNT	NORTH - A	Not Intact - POOR	GRAY	0
290	SUB SUB GROUND	SS - 9 - M	METAL ELECTRICAL BOX MOUNT	NORTH - A	Not Intact - POOR	GRAY	0.02
291	SUB SUB GROUND	SS - 9 - M	PLASTER WALL	NORTH - A	INTACT	WHITE	0.04
292	SUB SUB GROUND	SS - 9 - M	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	RED	0
293	SUB SUB GROUND	SS - 9 - M	METAL DOOR CASING	NORTH - A	Not Intact - POOR	RED	2.2
294	SUB SUB GROUND	SS - 9 - M	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	Not Intact - POOR	GRAY	0.04
295	SUB SUB GROUND	SS - 9 - M	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	WHITE	2.8
296	SUB SUB GROUND	SS - 9 - M	METAL HATCH	SOUTH - C	INTACT	BLACK	0
297	SUB SUB GROUND	SS - 9 - M	METAL HATCH	NORTH - A	INTACT	WHITE	- 0.84
298	SUB SUB GROUND	SS - 5 - M	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.12
299	SUB SUB GROUND	SS - 5 - M	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.02
300	SUB SUB GROUND	SS - 5 - M	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0
302	SUB SUB GROUND	SS - 5 - M	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0.3
303	SUB SUB GROUND	SS - 5 - M	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	RED	0.13
306	SUB SUB GROUND	SS - 5 - M	CONCRETE FIRE SPRINKLER PIPE	EAST - B	Not Intact - POOR	RED	0
307	SUB SUB GROUND	SS - 5 - M	METAL HATCH	WEST - D	INTACT	WHITE	0.07

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
308	SUB SUB GROUND	SS - 8 - M	PLASTER WALL	WEST - D	INTACT	WHITE	0.08
309	SUB SUB GROUND	SS - 8 - M	METAL FIRE SPRINKLER PIPE	WEST - D	INTACT	RED	0
311	SUB SUB GROUND	SS - 8 - M	PLASTER CEILING	WEST - D	Not Intact - POOR	WHITE	0
312	SUB SUB GROUND	SS - 8 - M	METAL RADIATOR COVER	WEST - D	Not Intact - POOR	BEIGE	0.21
313	SUB SUB GROUND	SS - 8 - M	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	RED	0.08
314	SUB SUB GROUND	SS - 8 - M	METAL PRIVACY PARTITION	EAST - B	INTACT	BEIGE	0.05
318	SUB SUB GROUND	SS - 8 - M	METAL DOOR CASING	SOUTH - C	INTACT	BLUE	1.7
319	SUB SUB GROUND	SS - 6 - M	METAL DOOR CASING	WEST - D	INTACT	WHITE	0
320	SUB SUB GROUND	SS - 6 - M	METAL DOOR	WEST - D	INTACT	WHITE	0
321	SUB SUB GROUND	SS - 6 - M	WALLBOARD WALL	WEST - D	Not Intact - POOR	WHITE	0
322	SUB SUB GROUND	SS - 6 - M	PLASTER WALL	EAST - B	Not Intact - POOR	WHITE	0
323	SUB SUB GROUND	SS - 6 - M	PLASTER WALL	NORTH - A	Not Intact - POOR	WHITE	0.04
324	SUB SUB GROUND	SS - 6 - M	METAL CONDUIT	NORTH - A	INTACT	WHITE	0.02
325	SUB SUB GROUND	SS - 6 - M	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0.06
326	SUB SUB GROUND	SS - 6 - M	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	RED	0.16
327	SUB SUB GROUND	SS - 6 - M	METAL BASEBOARD	NORTH - A	INTACT	RED	1.8
329	SUB SUB GROUND	SS - 6 - M	METAL BASEBOARD	WEST - D	INTACT	RED	1.9
332	SUB SUB GROUND	SS - 6 - M	METAL BASEBOARD	SOUTH - C	INTACT	RED	1.8
333	SUB SUB GROUND	SS - 2 - M	METAL BASEBOARD	WEST - D	INTACT	RED	1.9
334	SUB SUB GROUND	SS - 2 - M	CONCRETE FLOOR	WEST - D	Not Intact - POOR	RED	0.15
335	SUB SUB GROUND	SS - 2 - M	PLASTER WALL	WEST - D	INTACT	WHITE	0
336	SUB SUB GROUND	SS - 2 - M	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
337	SUB SUB GROUND	SS - 2 - M	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0.01
338	SUB SUB GROUND	SS - 2 - M	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
339	SUB SUB GROUND	SS - 7 - M	METAL AIR VENT - CEILING	NORTH - A	INTACT	BEIGE	0.02
342	SUB SUB GROUND	SS - 7 - M	WALLBOARD CEILING	NORTH - A	Not Intact - POOR	WHITE	0
343	SUB SUB GROUND	SS - 7 - M	METAL DOOR	NORTH - A	Not Intact - POOR	GREEN	0.09
344	SUB SUB GROUND	SS - 7 - M	METAL DOOR CASING	NORTH - A	Not Intact - POOR	WHITE	2.4
346	SUB SUB GROUND	SS - 7 - M	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	WHITE	1.4

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
347	SUB SUB GROUND	SS - 7 - M	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	RED	0.11
349	SUB SUB GROUND	SS - 7 - M	METAL BASEBOARD	WEST - D	INTACT	RED	2.5
350	SUB SUB GROUND	CS - 6	METAL LADDER	NORTH - A	Not Intact - POOR	GRAY	5.5
351	SUB SUB GROUND	STAIR 5	PLASTER WALL	NORTH - A	INTACT	GRAY	0.4
352	SUB SUB GROUND	STAIR 5	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
353	SUB SUB GROUND	STAIR 5	PLASTER WALL	WEST - D	INTACT	WHITE	0.18
354	SUB SUB GROUND	STAIR 5	METAL STAIR STRINGER	NORTH - A	INTACT	TAN	2
355	SUB SUB GROUND	STAIR 5	METAL STAIR NEWEL POST	NORTH - A	INTACT	TAN	4.5
356	SUB SUB GROUND	STAIR 5	METAL DOOR	EAST - B	INTACT	TAN	0
357	SUB SUB GROUND	STAIR 5	METAL DOOR CASING	EAST - B	INTACT	TAN	0
358	SUB SUB GROUND	STAIR 5	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0.26
359	SUB SUB GROUND	STAIR 5	METAL DOOR CASING	SOUTH - C	INTACT	RED	2.4
360	SUB SUB GROUND	STAIR 5	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	YELLOW	0.03
361	SUB SUB GROUND	STAIR 5	CONCRETE STAIR TREAD	SOUTH - C	INTACT	YELLOW	0.04
362	SUB SUB GROUND	STAIR 5	METAL STAIR TREAD	SOUTH - C	INTACT	BLACK	0.01
363	SUB SUB GROUND	STAIR 5	METAL STAIR BASEBOARD	WEST - D	Not Intact - POOR	YELLOW	3.4
364	SUB SUB GROUND	STAIR 5	METAL STAIR RISER	WEST - D	INTACT	YELLOW	1.5
365	FIFTH	5 - C - 6	PLASTER WALL	EAST - B	INTACT	YELLOW	2.5
366	FIFTH	5 - C - 6	CONCRETE FIREHOSE CLOSET	WEST - D	Not Intact - POOR	GRAY	0.06
367	FIFTH	5 - C - 6	WALLBOARD WALL	WEST - D	Not Intact - POOR	WHITE	0
368	FIFTH	5 - C - 6	METAL AC UNIT	SOUTH - C	INTACT	TAN	0
369	FIFTH	5 - C - 6	METAL DOOR CASING	EAST - B	INTACT	BLUE	0
370	FIFTH	5 - C - 6	METAL HATCH	WEST - D	INTACT	WHITE	0
371	FIFTH	5 - C - 6	WALLBOARD CEILING	SOUTH - C	INTACT	WHITE	0.01
372	FIFTH	5160	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.02
373	FIFTH	5160	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0.01
374	FIFTH	5160	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0
375	FIFTH	5160	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
378	FIFTH	5160	WALLBOARD CEILING	WEST - D	INTACT	WHITE	0
379	FIFTH	5160	METAL AC UNIT	WEST - D	INTACT	TAN	0
380	FIFTH	5160	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
381	FIFTH	5162	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
382	FIFTH	5162	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.01
383	FIFTH	5162	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
384	FIFTH	5162	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.03
385	FIFTH	5164	METAL AC UNIT	NORTH - A	INTACT	TAN	0
386	FIFTH	5164	METAL AC UNIT	WEST - D	INTACT	WHITE	0
388	FIFTH	5164	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
390	FIFTH	5164	METAL AC UNIT	WEST - D	INTACT	WHITE	0
399	FIFTH	5 - C - 6	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
400	FIFTH	5 - C - 6	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
402	FIFTH	5 - C - 6	PLASTER WALL	SOUTH - C	INTACT	WHITE	2.3
403	FIFTH	5 - C - 6	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0
404	FIFTH	5 - C - 6	METAL AC UNIT	SOUTH - C	INTACT	TAN	0
405	FIFTH	5 - C - 6	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
406	FIFTH	5187	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
407	FIFTH	5187	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
408	FIFTH	5187	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
409	FIFTH	5187	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0
410	FIFTH	5187	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0
412	FIFTH	5187	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.02
413	FIFTH	5187	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.5
414	FIFTH	5187	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
415	FIFTH	5187	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
416	FIFTH	STAIR 1	PLASTER WALL	NORTH - A	INTACT	WHITE	0.04
417	FIFTH	STAIR 1	PLASTER WALL	WEST - D	INTACT	WHITE	0.13
420	FIFTH	STAIR 1	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.12
422	FIFTH	STAIR 1	METAL STAIR STRINGER	EAST - B	INTACT	TAN	3.6
423	FIFTH	STAIR 1	METAL STAIR BASEBOARD	EAST - B	Not Intact - POOR	YELLOW	5.6
424	FIFTH	STAIR 1	METAL STAIR RISER	EAST - B	INTACT	YELLOW	1.3
425	FIFTH	STAIR 1	CONCRETE STAIR TREAD	EAST - B	Not Intact - POOR	YELLOW	0.17
426	FIFTH	STAIR 1	METAL STAIR TREAD	EAST - B	Not Intact - POOR	BLACK	0
427	FIFTH	STAIR 1	CONCRETE FLOOR	EAST - B	Not Intact - POOR	YELLOW	0.02
428	FIFTH	STAIR 1	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.05
429	FIFTH	STAIR 1	METAL DOOR CASING	NORTH - A	Not Intact - POOR	RED	2

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
430	FIFTH	STAIR 1	METAL CONDUIT	EAST - B	INTACT	WHITE	0.3
431	FIFTH	5-C-4A	PLASTER WALL	WEST - D	INTACT	WHITE	3.2
432	FIFTH	5-C-4A	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
433	FIFTH	5-C-4A	CONCRETE FIRE EXTINGUISHER CASING	NORTH - A	INTACT	GRAY	0.03
434	FIFTH	5-C-4A	METAL AC UNIT	NORTH - A	INTACT	TAN	0
435	FIFTH	5-C-4A	METAL AC UNIT	WEST - D	INTACT	TAN	0
437	FIFTH	5-C-4A	METAL DOOR CASING	WEST - D	Not Intact - POOR	BLUE	0
438	FIFTH	5-C-4A	WALLBOARD CEILING	WEST - D	INTACT	WHITE	0
439	FIFTH	ELEVATOR LOBBY STAFF	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
440	FIFTH	ELEVATOR LOBBY STAFF	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
442	FIFTH	NORTH CORRIDOR	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
443	FIFTH	NORTH CORRIDOR	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
444	FIFTH	NORTH CORRIDOR	METAL DOOR	SOUTH - C	INTACT	BLACK	- 0.55
445	FIFTH	NORTH CORRIDOR	METAL DOOR	WEST - D	INTACT	GRAY	0
446	FIFTH	NORTH CORRIDOR	METAL DOOR CASING	WEST - D	INTACT	GRAY	0
447	FIFTH	NORTH CORRIDOR	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
448	FIFTH	NORTH CORRIDOR	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
449	FIFTH	NORTH CORRIDOR	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.02
450	FIFTH	NORTH CORRIDOR	PLASTER WALL	EAST - B	INTACT	WHITE	0
451	FIFTH	NORTH CORRIDOR	METAL FIREHOSE CLOSET	EAST - B	INTACT	WHITE	0
452	FIFTH	NORTH CORRIDOR	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0.12
453	FIFTH	5201	CERAMIC BLOCK WALL	SOUTH - C	INTACT	TAN	0.02
454	FIFTH	5201	CERAMIC BLOCK WALL	WEST - D	INTACT	TAN	0.02
457	FIFTH	5201	CERAMIC BLOCK WALL	NORTH - A	INTACT	TAN	0.06
458	FIFTH	5201	CONCRETE WALL	EAST - B	INTACT	TAN	1.9
459	FIFTH	5201	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0.03
460	FIFTH	5201	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0
461	FIFTH	5201	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0.02
462	FIFTH	5201	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.01

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
463	FIFTH	5201	METAL CONDUIT	NORTH - A	INTACT	TAN	0.11
465	FIFTH	5201	METAL CONDUIT	NORTH - A	INTACT	TAN	0.2
466	FIFTH	5201	METAL CONDUIT	NORTH - A	INTACT	TAN	0.13
467	FIFTH	5201	METAL DOOR CASING	NORTH - A	Not Intact - POOR	GREEN	2.7
468	FIFTH	5201	METAL DOOR	NORTH - A	INTACT	WHITE	0.15
469	FIFTH	5004	METAL DOOR CASING	EAST - B	Not Intact - POOR	RED	2
470	FIFTH	STAIR 5004	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.01
471	FIFTH	STAIR 5004	METAL FIREHOSE CLOSET	NORTH - A	Not Intact - POOR	BEIGE	0
473	FIFTH	STAIR 5004	METAL STAIR HANDRAIL	NORTH - A	INTACT	WHITE	3.7
474	FIFTH	STAIR 5004	METAL STAIR STRINGER	WEST - D	INTACT	TAN	3.7
475	FIFTH	STAIR 5004	METAL BASEBOARD	SOUTH - C	INTACT	YELLOW	2.3
476	FIFTH	STAIR 5004	CONCRETE STAIR TREAD	SOUTH - C	INTACT	YELLOW	0.05
477	FIFTH	STAIR 5004	METAL STAIR TREAD	SOUTH - C	INTACT	BLACK	0
481	FIFTH	STAIR 5004	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.17
482	FIFTH	STAIR 5004	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
483	FIFTH	STAIR 5004	METAL WINDOW CASING	WEST - D	INTACT	BLACK	0
484	FIFTH	STAIR 5004	CONCRETE FLOOR	WEST - D	INTACT	YELLOW	0.08
485	FIFTH	STAIR 5004	METAL STAIR RISER	SOUTH - C	INTACT	YELLOW	2.6
486	FIFTH	5206	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
487	FIFTH	5206	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
490	FIFTH	5206	METAL HATCH	EAST - B	INTACT	WHITE	0
491	FIFTH	5206	WOOD WINDOW CASING	NORTH - A	INTACT	WHITE	0
492	FIFTH	5205a	METAL DOOR	WEST - D	INTACT	GRAY	0
493	FIFTH	5205a	METAL DOOR CASING	WEST - D	INTACT	GRAY	0
494	FIFTH	5205a	METAL DOOR LINTEL	WEST - D	Not Intact - POOR	GRAY	8.4
495	FIFTH	5205a	METAL THRESHOLD	WEST - D	Not Intact - POOR	GRAY	0
496	FIFTH	5205a	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
497	FIFTH	5205a	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
498	FIFTH	5205a	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
499	FIFTH	5205a	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
500	FIFTH	5205a	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
501	FIFTH	5205a	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
502	FIFTH	5205a	METAL TRANSFORMER	NORTH - A	INTACT	GRAY	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
503	FIFTH	5205a	METAL PIPE	NORTH - A	Not Intact - POOR	GRAY	0
504	FIFTH	5205a	METAL PIPE	WEST - D	Not Intact - POOR	BLACK	0
505	FIFTH	5205a	METAL PIPE	SOUTH - C	Not Intact - POOR	BLACK	0
506	FIFTH	5205a	METAL FIRE SPRINKLER PIPE	SOUTH - C	Not Intact - POOR	BLACK	0
507	FIFTH	5205a	METAL MOTOR	WEST - D	INTACT	RED	3.5
508	FIFTH	5205a	METAL MOTOR	WEST - D	INTACT	RED	0
509	FIFTH	5205a	METAL MOTOR	WEST - D	INTACT	RED	0
510	FIFTH	5205a	METAL MOTOR BASE	WEST - D	INTACT	BLACK	0
512	FIFTH	5205a	METAL MOTOR BASE	WEST - D	INTACT	BLACK	0
513	FIFTH	5205a	METAL TANK	WEST - D	INTACT	GREEN	0
514	FIFTH	5205a	METAL TANK	WEST - D	INTACT	GREEN	0
515	FIFTH	5205a	METAL COMPRESSOR	NORTH - A	INTACT	BLUE	3.4
517	FIFTH	5205a	METAL COMPRESSOR	NORTH - A	INTACT	BLUE	0
519	FIFTH	5205a	METAL COMPRESSOR	WEST - D	INTACT	GRAY	3
520	FIFTH	5205a	METAL PIPE	NORTH - A	Not Intact - POOR	BLACK	0.01
521	FIFTH	5205a	METAL DOOR	NORTH - A	INTACT	GRAY	0
522	FIFTH	5205a	METAL DOOR CASING	NORTH - A	INTACT	GRAY	0
523	FIFTH	5205a	METAL HATCH	SOUTH - C	Not Intact - POOR	MAROON	0
524	FIFTH	5205a	METAL HATCH CASING	SOUTH - C	INTACT	MAROON	0
525	NINTH	ELEVATOR LOBBY STAFF	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
526	NINTH	ELEVATOR LOBBY STAFF	METAL WINDOW CASING	EAST - B	INTACT	BLACK	0.3
527	NINTH	ELEVATOR LOBBY STAFF	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
528	NINTH	ELEVATOR LOBBY STAFF	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
529	NINTH	ELEVATOR LOBBY STAFF	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
530	NINTH	9 - 77 - c	WALLBOARD CEILING	SOUTH - C	INTACT	WHITE	0.01
531	NINTH	9 - 77 - c	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
532	NINTH	9 - 77 - c	CONCRETE FIRE EXTINGUISHER CASING	NORTH - A	Not Intact - POOR	GRAY	0.08
533	NINTH	9 - 68 - c	METAL FIRE EXTINGUISHER CASING	NORTH - A	INTACT	WHITE	3.9
534	NINTH	9 - 77 - c	METAL HATCH	NORTH - A	INTACT	GRAY	0
536	NINTH	9 - 77 - c	PLASTIC WALL	NORTH - A	INTACT	WHITE	0.03

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
538	NINTH	9125	METAL PRIVACY PARTITION	EAST - B	INTACT	BEIGE	0.15
539	NINTH	9125	METAL CONDUIT	EAST - B	INTACT	BEIGE	0.01
541	NINTH	9125	METAL TRIM	NORTH - A	INTACT	BEIGE	0
545	NINTH	9125	PLASTER WALL	SOUTH - C	INTACT	BEIGE	0.13
546	NINTH	9125	METAL WALL	NORTH - A	Not Intact - POOR	BEIGE	3.8
547	NINTH	9 - 78 - M	METAL DOOR	EAST - B	Not Intact - POOR	GRAY	0
548	NINTH	9 - 78 - M	METAL THRESHOLD	EAST - B	Not Intact - POOR	GRAY	20.5
549	NINTH	9 - 78 - M	METAL DOOR CASING	EAST - B	INTACT	WHITE	1.8
550	NINTH	9 - 78 - M	METAL DOOR LINTEL	EAST - B	Not Intact - POOR	WHITE	3.3
551	NINTH	9 - 78 - M	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
552	NINTH	9 - 78 - M	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
553	NINTH	9 - 78 - M	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
554	NINTH	9 - 78 - M	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
555	NINTH	9 - 78 - M	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
556	NINTH	9 - 78 - M	METAL AIR VENT - CEILING	WEST - D	INTACT	WHITE	0
558	NINTH	9 - 78 - M	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	4
559	NINTH	9 - 78 - M	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	0.11
560	NINTH	9 - 78 - M	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.05
561	NINTH	9111	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
562	NINTH	9111	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0
563	NINTH	9111	PLASTER WALL	NORTH - A	INTACT	WHITE	0.06
564	NINTH	9111	PLASTER WALL	WEST - D	INTACT	WHITE	0.12
565	NINTH	9111	METAL HATCH	NORTH - A	INTACT	BLUE	0.01
566	NINTH	9111	METAL PRIVACY PARTITION	WEST - D	INTACT	BLUE	0.17
567	NINTH	9111	METAL RADIATOR	EAST - B	INTACT	BLUE	0
570	NINTH	9111	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	BLUE	1.1
574	NINTH	9108	METAL DOOR CASING	SOUTH - C	INTACT	WHITE	1.8
575	NINTH	9108	METAL PRIVACY PARTITION	SOUTH - C	INTACT	BEIGE	0.04
576	NINTH	9108	PLASTER WALL	WEST - D	INTACT	BEIGE	0.16
577	NINTH	9108	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.13
579	NINTH	9108	METAL HATCH	SOUTH - C	INTACT	WHITE	0.05
580	NINTH	9108	METAL HATCH	NORTH - A	INTACT	BEIGE	0.4
581	NINTH	9118	CERAMIC BLOCK WALL	NORTH - A	INTACT	TAN	0.5

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
582	NINTH	9118	CERAMIC BLOCK WALL	EAST - B	INTACT	TAN	0.4
583	NINTH	9118	CERAMIC BLOCK WALL	SOUTH - C	INTACT	TAN	0.01
584	NINTH	9118	CERAMIC BLOCK WALL	WEST - D	INTACT	TAN	0.02
590	NINTH	9118	CONCRETE WALL	NORTH - A	INTACT	TAN	0.02
591	NINTH	9118	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	GRAY	0.14
593	NINTH	9118	METAL CONDUIT	EAST - B	Not Intact - POOR	TAN	0.5
595	NINTH	9118	METAL CONDUIT	WEST - D	Not Intact - POOR	TAN	0.13
597	NINTH	9118	METAL CONDUIT	WEST - D	Not Intact - POOR	TAN	0.5
599	NINTH	9118	METAL CONDUIT	WEST - D	Not Intact - POOR	TAN	0.09
600	NINTH	9118	METAL DOOR	NORTH - A	Not Intact - POOR	ORANGE	0.14
601	NINTH	9118	METAL DOOR CASING	NORTH - A	Not Intact - POOR	GREEN	2.5
602	NINTH	9118	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0.02
603	NINTH	9118	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0.03
604	NINTH	9118	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
606	NINTH	9118	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
611	NINTH	9112	PLASTER WALL	SOUTH - C	Not Intact - POOR	BLUE	1.5
612	NINTH	9112	CONCRETE BLOCK WALL	EAST - B	INTACT	BLUE	0.01
613	NINTH	9112	PLASTER WALL	NORTH - A	Not Intact - POOR	BLUE	0.05
614	NINTH	9112	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	GRAY	0.03
616	NINTH	9112	METAL CONDUIT	SOUTH - C	Not Intact - POOR	BLUE	0.24
617	NINTH	9112	METAL PIPE	NORTH - A	Not Intact - POOR	BLACK	0.27
618	NINTH	9112	CERAMIC BLOCK WALL	NORTH - A	Not Intact - POOR	BLUE	0.02
619	NINTH	9112	CERAMIC BLOCK WALL	NORTH - A	Not Intact - POOR	BLUE	0.5
620	NINTH	9112	CONCRETE WALL	WEST - D	Not Intact - POOR	BLUE	0.01
622	NINTH	9112	CONCRETE WALL	SOUTH - C	Not Intact - POOR	BLUE	0.01
623	NINTH	9112	METAL FIRE SPRINKLER PIPE	WEST - D	INTACT	RED	0
624	NINTH	9112	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	RED	0
625	NINTH	9112	METAL PIPE	NORTH - A	Not Intact - POOR	BLACK	0
626	NINTH	9112	METAL DOOR	NORTH - A	Not Intact - POOR	PEACH	0.14

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
627	NINTH	9112	METAL DOOR CASING	NORTH - A	Not Intact - POOR	BLUE	1.6
629	NINTH	STAIR 2	METAL DOOR CASING	NORTH - A	INTACT	RED	2.1
630	NINTH	STAIR 2	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.04
632	NINTH	STAIR 2	PLASTER WALL	WEST - D	INTACT	WHITE	0.21
633	NINTH	STAIR 2	PLASTER WALL	EAST - B	INTACT	WHITE	0.13
634	NINTH	STAIR 2	METAL CONDUIT	WEST - D	INTACT	WHITE	0.6
635	NINTH	STAIR 2	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0.04
636	NINTH	STAIR 2	METAL BASEBOARD	EAST - B	Not Intact - POOR	YELLOW	0.1
637	NINTH	STAIR 2	CONCRETE STAIR TREAD	SOUTH - C	Not Intact - POOR	YELLOW	0.01
640	NINTH	STAIR 2	METAL STAIR RISER	SOUTH - C	INTACT	YELLOW	1.5
641	NINTH	STAIR 2	METAL STAIR TREAD	SOUTH - C	INTACT	GRAY	0
642	NINTH	STAIR 2	METAL STAIR STRINGER	SOUTH - C	INTACT	TAN	2.4
643	NINTH	STAIR 2	METAL STAIR HANDRAIL	SOUTH - C	INTACT	GRAY	0
644	NINTH	STAIR 2	METAL TRIM	WEST - D	INTACT	WHITE	0
645	NINTH	STAIR 2	METAL DOOR CASING	WEST - D	INTACT	GRAY	0
646	NINTH	STAIR 2	METAL DOOR	WEST - D	INTACT	GRAY	0
649	NINTH	9106	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.5
650	NINTH	9106	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
651	NINTH	9106	METAL AC UNIT	SOUTH - C	Not Intact - POOR	WHITE	0
653	NINTH	9120	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
654	NINTH	9120	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
655	NINTH	9120	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.9
656	NINTH	9120	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0
657	NINTH	9120	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.01
658	NINTH	9120	METAL PIPE	NORTH - A	INTACT	WHITE	0.21
659	NINTH	9124	METAL AC UNIT	EAST - B	INTACT	TAN	0
660	NINTH	9124	METAL DOOR CASING	NORTH - A	INTACT	BLUE	5.1
661	NINTH	9127	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
662	NINTH	9127	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
663	NINTH	9127	WOOD CHAIR RAIL	EAST - B	INTACT	WHITE	0
664	NINTH	9127	WOOD CHAIR RAIL	EAST - B	Not Intact - POOR	WHITE	0.01
665	NINTH	9127	WOOD CHAIR RAIL	WEST - D	INTACT	WHITE	0.03
666	NINTH	9127	METAL AC UNIT	NORTH - A	INTACT	TAN	0
667	NINTH	9127	METAL PIPE	EAST - B	INTACT	WHITE	0
671	NINTH	9127	PLASTER CEILING	EAST - B	Not Intact - POOR	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
672	NINTH	9127	METAL CONDUIT	WEST - D	INTACT	WHITE	0.01
673	NINTH	9127	METAL DOOR CASING	NORTH - A	INTACT	WHITE	3.5
674	NINTH	9 - 75 - M	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0
675	NINTH	9 - 75 - M	METAL HATCH	NORTH - A	INTACT	WHITE	0
676	NINTH	9 - 75 - M	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
677	NINTH	9 - 75 - M	PLASTER WALL	SOUTH - C	INTACT	WHITE	1.6
679	NINTH	9 - 75 - M	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	2.3
680	NINTH	9 - 75 - M	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	Not Intact - POOR	RED	0.09
682	NINTH	9 - 75 - M	METAL PIPE	SOUTH - C	Not Intact - POOR	WHITE	0.02
683	NINTH	9 - 75 - M	METAL AIR VENT - CEILING	WEST - D	INTACT	WHITE	- 0.1
684	NINTH	WEST CORR.	PLASTER WALL	NORTH - A	INTACT	WHITE	0
685	NINTH	WEST CORR.	METAL DOOR CASING	EAST - B	INTACT	BLUE	2
686	NINTH	WEST CORR.	METAL HATCH	NORTH - A	INTACT	WHITE	0.21
687	NINTH	WEST CORR.	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0
688	NINTH	WEST CORR.	METAL TRIM	WEST - D	INTACT	WHITE	0.6
689	NINTH	WEST CORR.	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.01
690	NINTH	WEST CORR.	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
691	NINTH	WEST CORR.	WALLBOARD CEILING	WEST - D	INTACT	WHITE	0
693	NINTH	9152	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
694	NINTH	9152	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
695	NINTH	9152	METAL AC UNIT	NORTH - A	Not Intact - POOR	WHITE	0.04
696	NINTH	9158	METAL DOOR CASING	SOUTH - C	INTACT	BLUE	0
697	NINTH	9160	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.5
698	NINTH	9160	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
700	NINTH	9160	METAL AC UNIT	SOUTH - C	Not Intact - POOR	WHITE	0.04
702	NINTH	9160	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.04
706	NINTH	9160	METAL HATCH	SOUTH - C	INTACT	WHITE	- 0.1
714	NINTH	STAIR 1	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0.07
715	NINTH	STAIR 1	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	YELLOW	0.07
716	NINTH	STAIR 1	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.04
717	NINTH	STAIR 1	METAL CONDUIT	EAST - B	INTACT	WHITE	0.27

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
718	NINTH	STAIR 1	METAL STAIR STRINGER	SOUTH - C	INTACT	BEIGE	7
719	NINTH	STAIR 1	METAL BASEBOARD	WEST - D	INTACT	YELLOW	4.9
720	NINTH	STAIR 1	CONCRETE STAIR TREAD	NORTH - A	INTACT	YELLOW	1.6
721	NINTH	STAIR 1	METAL STAIR TREAD	NORTH - A	INTACT	BLACK	0.02
722	NINTH	STAIR 1	METAL STAIR RISER	NORTH - A	INTACT	YELLOW	2.1
723	NINTH	9130	METAL PRIVACY PARTITION	EAST - B	Not Intact - POOR	BEIGE	0.12
724	NINTH	9130	METAL CONDUIT	SOUTH - C	Not Intact - POOR	BEIGE	0.01
728	NINTH	9130	PLASTER CEILING	NORTH - A	INTACT	WHITE	1.3
729	NINTH	9130	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0.07
730	NINTH	9149	METAL WINDOW CASING	SOUTH - C	Not Intact - POOR	GRAY	0.21
731	NINTH	9149	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
732	NINTH	9149	METAL AC UNIT	NORTH - A	Not Intact - POOR	BEIGE	0.11
733	NINTH	9149	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.01
734	NINTH	9149	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	RED	0
736	NINTH	9149	METAL PRIVACY PARTITION	WEST - D	INTACT	BEIGE	0
737	NINTH	9149	METAL HATCH	SOUTH - C	INTACT	WHITE	0.04
738	NINTH	9149	METAL HATCH	WEST - D	INTACT	WHITE	0
739	NINTH	9149	WALLBOARD CEILING	WEST - D	INTACT	WHITE	0
740	NINTH	9149	WALLBOARD CEILING	SOUTH - C	INTACT	WHITE	0
741	NINTH	9149	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.01
742	NINTH	9149	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
743	NINTH	CORR. 9-76-A	METAL DOOR	WEST - D	INTACT	GRAY	0.15
744	NINTH	CORR. 9-76-A	CONCRETE FIREHOSE CLOSET	WEST - D	Not Intact - POOR	RED	0.05
745	NINTH	CORR. 9-76-A	METAL DOOR CASING	WEST - D	INTACT	GRAY	2.5
747	NINTH	9144	CERAMIC BLOCK WALL	SOUTH - C	INTACT	ORANGE	0.03
748	NINTH	9144	CERAMIC BLOCK WALL	WEST - D	INTACT	ORANGE	0.02
749	NINTH	9144	CERAMIC BLOCK WALL	NORTH - A	INTACT	ORANGE	0.01
750	NINTH	9144	CERAMIC BLOCK WALL	EAST - B	INTACT	ORANGE	0
751	NINTH	9144	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	GRAY	1.7
752	NINTH	9144	METAL CONDUIT	NORTH - A	INTACT	ORANGE	0.1
753	NINTH	9144	METAL CONDUIT	NORTH - A	INTACT	ORANGE	0.06
754	NINTH	9144	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
755	NINTH	9144	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
756	NINTH	9144	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
757	NINTH	9144	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.02
758	NINTH	9144	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0
759	NINTH	9138	METAL AC UNIT	NORTH - A	Not Intact - POOR	WHITE	0.03
761	NINTH	9138	PLASTER CEILING	NORTH - A	Not Intact - POOR	WHITE	0.01
762	NINTH	9138	METAL DOOR CASING	NORTH - A	INTACT	WHITE	0.01
763	NINTH	9138	METAL AC UNIT	EAST - B	Not Intact - POOR	GRAY	0
764	NINTH	9177	METAL AC UNIT	EAST - B	INTACT	WHITE	0.04
765	NINTH	9177	METAL PIPE	EAST - B	INTACT	WHITE	0.02
766	NINTH	9177	METAL CEILING	EAST - B	INTACT	WHITE	0.02
767	NINTH	9177	METAL CEILING	WEST - D	INTACT	WHITE	0.02
770	NINTH	9177	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0.24
771	NINTH	9177	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.4
772	NINTH	9177	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.4
773	NINTH	9174	METAL CEILING	SOUTH - C	INTACT	WHITE	- 0.02
774	NINTH	9174	METAL CEILING	NORTH - A	INTACT	WHITE	0.02
776	NINTH	9174	METAL AC UNIT	SOUTH - C	Not Intact - POOR	BEIGE	0
777	NINTH	9174	METAL PIPE	SOUTH - C	Not Intact - POOR	WHITE	0.01
778	NINTH	9174	METAL RADIATOR COVER	WEST - D	Not Intact - POOR	WHITE	0.2
779	NINTH	9174	METAL CEILING	WEST - D	Not Intact - POOR	WHITE	0.09
780	NINTH	9174	METAL CEILING	WEST - D	INTACT	WHITE	0
781	EIGHTH	ELEVATOR LOBBY 1	PLASTER WALL	NORTH - A	INTACT	WHITE	2.7
782	EIGHTH	ELEVATOR LOBBY 1	PLASTER WALL	WEST - D	INTACT	WHITE	1.9
783	EIGHTH	ELEVATOR LOBBY 1	CONCRETE FIREHOSE CLOSET	NORTH - A	INTACT	GRAY	0.06
784	EIGHTH	ELEVATOR LOBBY 1	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	GRAY	2.4
786	EIGHTH	ELEVATOR LOBBY 2	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
787	EIGHTH	ELEVATOR LOBBY 2	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
790	EIGHTH	ELEVATOR LOBBY 2	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
791	EIGHTH	ELEVATOR LOBBY 2	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
792	EIGHTH	ELEVATOR LOBBY 2	METAL DOOR CASING	SOUTH - C	INTACT	GRAY	0
793	EIGHTH	8209	METAL DOOR CASING	SOUTH - C	INTACT	GRAY	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
794	EIGHTH	8209	METAL DOOR	SOUTH - C	INTACT	GRAY	0
795	EIGHTH	8209	METAL CEILING	SOUTH - C	Not Intact - POOR	WHITE	0.02
797	EIGHTH	8209	METAL CEILING	NORTH - A	Not Intact - POOR	WHITE	0
798	EIGHTH	8209	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0
799	EIGHTH	8209	METAL AIR VENT - WALL	SOUTH - C	INTACT	WHITE	0.01
800	EIGHTH	8209	METAL WINDOW SASH	NORTH - A	INTACT	WHITE	0.4
801	EIGHTH	8209	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0.4
802	EIGHTH	8209	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
803	EIGHTH	8209	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.5
804	EIGHTH	8209	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	0.3
805	EIGHTH	8209	METAL FIRE SPRINKLER PIPE	WEST - D	INTACT	RED	0
806	EIGHTH	CORR. 1	PLASTER WALL	NORTH - A	INTACT	WHITE	2.3
807	EIGHTH	CORR. 1	PLASTER WALL	SOUTH - C	INTACT	WHITE	2.1
808	EIGHTH	CORR. 1	METAL DOOR CASING	SOUTH - C	INTACT	GRAY	0
811	EIGHTH	CORR. 1	METAL DOOR CASING	EAST - B	INTACT	RED	1.8
812	EIGHTH	CORR. 1	METAL CONDUIT	EAST - B	INTACT	WHITE	0.15
813	EIGHTH	ELEVATOR LOBBY 3	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
814	EIGHTH	ELEVATOR LOBBY 3	WALLBOARD WALL	WEST - D	INTACT	WHITE	3.2
815	EIGHTH	ELEVATOR LOBBY 3	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0
818	EIGHTH	ELEVATOR LOBBY 3	METAL DOOR CASING	SOUTH - C	INTACT	GRAY	1.6
819	EIGHTH	STAIR 8003	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	YELLOW	0.06
820	EIGHTH	STAIR 8003	METAL BASEBOARD	EAST - B	INTACT	YELLOW	1.8
821	EIGHTH	STAIR 8003	CONCRETE STAIR TREAD	NORTH - A	Not Intact - POOR	YELLOW	0.02
822	EIGHTH	STAIR 8003	METAL STAIR TREAD	NORTH - A	INTACT	BLACK	0.08
823	EIGHTH	STAIR 8003	METAL STAIR RISER	NORTH - A	Not Intact - POOR	YELLOW	1.8
824	EIGHTH	STAIR 8003	METAL STAIR STRINGER	EAST - B	Not Intact - POOR	TAN	2.6
825	EIGHTH	STAIR 8003	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0.5
827	EIGHTH	STAIR 8003	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.02
828	EIGHTH	STAIR 8003	METAL DOOR CASING	SOUTH - C	INTACT	RED	2.5
829	EIGHTH	CORR. 2	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
830	EIGHTH	CORR. 2	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
834	EIGHTH	CORR. 2	PLASTER WALL	EAST - B	INTACT	WHITE	0.11
835	EIGHTH	CORR. 2	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.6

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
836	EIGHTH	CORR. 2	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
837	EIGHTH	8116	PLASTER WALL	SOUTH - C	INTACT	WHITE	0
838	EIGHTH	8116	METAL DOOR CASING	SOUTH - C	INTACT	GRAY	0
840	EIGHTH	8116	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.12
841	EIGHTH	8116	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
842	EIGHTH	8116	METAL AC UNIT	WEST - D	Not Intact - POOR	WHITE	0.05
844	EIGHTH	8116	METAL CEILING	WEST - D	Not Intact - POOR	WHITE	0.05
847	EIGHTH	8118	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.17
848	EIGHTH	8118	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
849	EIGHTH	8118	PLASTER WALL	EAST - B	INTACT	WHITE	0.06
851	EIGHTH	8118	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.01
852	EIGHTH	8118	METAL AC UNIT	SOUTH - C	Not Intact - POOR	WHITE	0.18
853	EIGHTH	8118	METAL DOOR CASING	NORTH - A	INTACT	WHITE	0.24
854	EIGHTH	8114	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.4
855	EIGHTH	8114	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
856	EIGHTH	8114	METAL AC UNIT	SOUTH - C	Not Intact - POOR	WHITE	0
857	EIGHTH	8114	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0
858	EIGHTH	CORR. 3	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
859	EIGHTH	CORR. 3	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
862	EIGHTH	CORR. 3	METAL DOOR CASING	SOUTH - C	INTACT	GRAY	0.04
863	EIGHTH	CORR. 3	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
866	EIGHTH	8113	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.5
867	EIGHTH	8113	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
868	EIGHTH	8113	METAL AC UNIT	SOUTH - C	Not Intact - POOR	WHITE	0.01
872	EIGHTH	8113	PLASTER CEILING	NORTH - A	Not Intact - POOR	WHITE	0.03
873	EIGHTH	8113	METAL DUCT	NORTH - A	INTACT	WHITE	0.04
874	EIGHTH	8116	METAL DUCT	NORTH - A	INTACT	WHITE	0.04
875	EIGHTH	8114	METAL DUCT	NORTH - A	INTACT	WHITE	0.04
876	EIGHTH	8118	METAL DUCT	NORTH - A	INTACT	WHITE	0.25
877	EIGHTH	CORR. 3	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
878	EIGHTH	CORR. 3	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
879	EIGHTH	CORR. 3	METAL AIR VENT - CEILING	WEST - D	INTACT	WHITE	0.01
880	EIGHTH	CORR. 3	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	GRAY	2.9

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
881	EIGHTH	CORR. 3	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	Not Intact - POOR	RED	0.11
882	EIGHTH	8110	METAL WINDOW SASH	NORTH - A	INTACT	WHITE	0
883	EIGHTH	8110	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.2
884	EIGHTH	8110	WALLBOARD CEILING	SOUTH - C	INTACT	WHITE	0.01
885	EIGHTH	8110	METAL DUCT	WEST - D	Not Intact - POOR	WHITE	0.05
886	EIGHTH	8002	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	YELLOW	0.04
887	EIGHTH	8002	METAL BASEBOARD	WEST - D	INTACT	YELLOW	1.7
888	EIGHTH	8002	CONCRETE STAIR TREAD	WEST - D	INTACT	YELLOW	0.05
889	EIGHTH	8002	METAL STAIR TREAD	SOUTH - C	INTACT	BLACK	0.07
890	EIGHTH	8002	METAL STAIR RISER	SOUTH - C	INTACT	YELLOW	1.3
892	EIGHTH	8002	METAL STAIR STRINGER	WEST - D	INTACT	TAN	3.2
893	EIGHTH	8002	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.06
894	EIGHTH	8002	METAL CONDUIT	WEST - D	INTACT	WHITE	0.18
895	EIGHTH	8002	PLASTER CEILING	NORTH - A	INTACT	WHITE	2.3
896	EIGHTH	8002	METAL DOOR CASING	NORTH - A	INTACT	RED	2.5
907	EIGHTH	8129	METAL DOOR	WEST - D	INTACT	TAN	0.08
908	EIGHTH	8129	METAL DOOR CASING	WEST - D	INTACT	TAN	2.5
909	EIGHTH	8129	CERAMIC BLOCK WALL	NORTH - A	INTACT	TAN	0.01
910	EIGHTH	8129	CERAMIC BLOCK WALL	WEST - D	INTACT	TAN	0.02
911	EIGHTH	8129	CERAMIC BLOCK WALL	SOUTH - C	INTACT	TAN	0.02
913	EIGHTH	8129	CERAMIC BLOCK WALL	EAST - B	INTACT	TAN	0.07
914	EIGHTH	8129	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	GRAY	0.09
916	EIGHTH	8129	METAL CONDUIT	NORTH - A	INTACT	TAN	0.12
918	EIGHTH	8129	METAL CONDUIT	NORTH - A	INTACT	TAN	0.06
919	EIGHTH	8129	METAL CONDUIT	SOUTH - C	INTACT	TAN	0.16
921	EIGHTH	8129	METAL CONDUIT	NORTH - A	INTACT	GRAY	0.5
922	EIGHTH	8129	CONCRETE WALL	SOUTH - C	INTACT	TAN	0.05
923	EIGHTH	8129	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
924	EIGHTH	8129	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
925	EIGHTH	8129	METAL ELECTRICAL BOX MOUNT	NORTH - A	Not Intact - POOR	GRAY	0.04
926	EIGHTH	8129	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0.02
927	EIGHTH	8129	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
928	EIGHTH	CORR. 4	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	TAN	1.7
929	EIGHTH	CORR. 4	CONCRETE FIRE EXTINGUISHER CASING	EAST - B	Not Intact - POOR	RED	0.08
930	EIGHTH	CORR. 4	WALLBOARD WALL	WEST - D	Not Intact - POOR	WHITE	0
931	EIGHTH	CORR. 4	METAL WINDOW CASING	WEST - D	INTACT	TAN	0
932	EIGHTH	8140	WALLBOARD WINDOW CASING	NORTH - A	INTACT	WHITE	0
933	EIGHTH	8140	METAL AIR VENT - CEILING	SOUTH - C	INTACT	TAN	0
934	EIGHTH	8140	METAL HATCH	SOUTH - C	INTACT	TAN	0
935	EIGHTH	PIPE CHASE	METAL WALL	SOUTH - C	INTACT	BEIGE	0.4
936	EIGHTH	PIPE CHASE	METAL WALL	NORTH - A	INTACT	BEIGE	0.02
937	EIGHTH	PIPE CHASE	METAL PIPE	WEST - D	Not Intact - POOR	BEIGE	0.22
938	EIGHTH	8132	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
939	EIGHTH	8132	METAL PRIVACY PARTITION	NORTH - A	INTACT	GRAY	0
940	EIGHTH	8132	METAL PRIVACY PARTITION	SOUTH - C	INTACT	GRAY	0
941	EIGHTH	8132	METAL HATCH	WEST - D	INTACT	GRAY	0
942	EIGHTH	8132	METAL HATCH	EAST - B	INTACT	GRAY	0
943	EIGHTH	8132	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
944	EIGHTH	8132	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
945	EIGHTH	8132	WALLBOARD CEILING	WEST - D	INTACT	WHITE	0
946	EIGHTH	8132	METAL AIR VENT - CEILING	WEST - D	INTACT	WHITE	0
947	EIGHTH	8132	METAL HATCH	NORTH - A	INTACT	GRAY	0
948	EIGHTH	8133	METAL AC UNIT	NORTH - A	INTACT	WHITE	- 0.16
949	EIGHTH	8133	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0
950	EIGHTH	8133	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
953	EIGHTH	8133	PLASTER CEILING	NORTH - A	INTACT	WHITE	0
954	EIGHTH	8133	PLASTER CEILING	EAST - B	INTACT	WHITE	0.01
958	EIGHTH	8133	METAL AC UNIT	NORTH - A	INTACT	WHITE	- 0.04
959	EIGHTH	8133	METAL CONDUIT	NORTH - A	INTACT	WHITE	0
961	EIGHTH	8133	METAL HATCH	NORTH - A	INTACT	WHITE	0.12
962	EIGHTH	8133	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0.04
964	EIGHTH	8133	CERAMIC BLOCK WALL	NORTH - A	Not Intact - POOR	BEIGE	0.26
965	EIGHTH	8133	METAL PIPE	NORTH - A	Not Intact - POOR	BEIGE	0.02
967	EIGHTH	8133	METAL PIPE	NORTH - A	Not Intact - POOR	BEIGE	0.17
968	EIGHTH	8134	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
970	EIGHTH	8134	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.01
971	EIGHTH	8134	METAL AC UNIT	EAST - B	INTACT	WHITE	0
973	EIGHTH	CORR. 5	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.5
974	EIGHTH	CORR. 5	PLASTER WALL	NORTH - A	INTACT	WHITE	1.8
975	EIGHTH	CORR. 5	METAL AIR VENT - WALL	NORTH - A	INTACT	WHITE	0.3
976	EIGHTH	CORR. 5	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	2.1
977	EIGHTH	CORR. 5	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	Not Intact - POOR	BLUE	0.07
978	EIGHTH	CORR. 5	METAL PIPE	SOUTH - C	INTACT	BLUE	0.04
979	EIGHTH	CORR. 5	METAL PIPE	SOUTH - C	INTACT	BLUE	0.02
980	EIGHTH	CORR. 5	PLASTER WALL	SOUTH - C	INTACT	WHITE	2.1
981	EIGHTH	CORR. 5	METAL AIR VENT - CEILING	EAST - B	INTACT	BEIGE	0
982	EIGHTH	CORR. 5	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
983	EIGHTH	CORR. 5	METAL HATCH	EAST - B	INTACT	WHITE	0
984	EIGHTH	CORR. 5	METAL HATCH	EAST - B	INTACT	WHITE	0
985	EIGHTH	CORR. 5	METAL DOOR CASING	EAST - B	INTACT	RED	0
986	EIGHTH	CORR. 5	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
987	EIGHTH	8157	PLASTER WALL	NORTH - A	INTACT	WHITE	0
988	EIGHTH	8157	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
989	EIGHTH	8157	WALLBOARD CEILING	SOUTH - C	INTACT	WHITE	0
990	EIGHTH	8157	METAL CEILING	EAST - B	INTACT	WHITE	0
991	EIGHTH	8153	METAL CEILING	NORTH - A	INTACT	WHITE	0
992	EIGHTH	8153	METAL AC UNIT	NORTH - A	INTACT	TAN	0
993	EIGHTH	8153	METAL HATCH	SOUTH - C	INTACT	WHITE	0
994	EIGHTH	8153	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.12
995	EIGHTH	8154	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.4
996	EIGHTH	8154	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0
997	EIGHTH	8154	METAL HATCH	SOUTH - C	INTACT	WHITE	0
998	EIGHTH	8154	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
999	EIGHTH	8154	METAL DOOR CASING	NORTH - A	INTACT	BLUE	0
1000	EIGHTH	8205	METAL DUCT	SOUTH - C	INTACT	WHITE	0
1001	EIGHTH	8205	METAL DUCT	SOUTH - C	INTACT	WHITE	0.09
1002	EIGHTH	8158	METAL PRIVACY PARTITION	SOUTH - C	Not Intact - POOR	WHITE	0.07
1003	EIGHTH	8158	METAL PIPE	EAST - B	INTACT	WHITE	0.4
1004	EIGHTH	8158	PLASTER WALL	EAST - B	INTACT	WHITE	0.03
1006	EIGHTH	8158	METAL TRIM	EAST - B	INTACT	WHITE	0
1007	EIGHTH	8158	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1008	EIGHTH	8203	METAL CEILING	SOUTH - C	INTACT	TAN	0
1009	EIGHTH	8203	METAL DUCT	SOUTH - C	INTACT	WHITE	0.01
1010	EIGHTH	8203	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
1011	EIGHTH	8203	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0
1012	EIGHTH	8189	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.01
1013	EIGHTH	8189	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
1014	EIGHTH	8189	METAL CONDUIT	EAST - B	INTACT	WHITE	0.6
1015	EIGHTH	8189	METAL CONDUIT	EAST - B	INTACT	WHITE	0.6
1016	EIGHTH	8189	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.02
1018	EIGHTH	8189	METAL HATCH	WEST - D	INTACT	WHITE	0
1019	EIGHTH	8189	WALLBOARD CEILING	WEST - D	INTACT	WHITE	0
1020	EIGHTH	8189	METAL DOOR CASING	EAST - B	INTACT	BLUE	0
1021	EIGHTH	8189	METAL WINDOW CASING	EAST - B	INTACT	BLUE	0
1023	EIGHTH	8167	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0
1024	EIGHTH	8167	PLASTER WALL	SOUTH - C	INTACT	WHITE	0
1025	EIGHTH	8167	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.4
1026	EIGHTH	8167	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
1028	EIGHTH	8167	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.2
1031	EIGHTH	8167	METAL AIR VENT - WALL	NORTH - A	INTACT	WHITE	- 0.02
1032	EIGHTH	8167	METAL DOOR CASING	NORTH - A	Not Intact - POOR	BLUE	1.6
1033	EIGHTH	8166	PLASTER WALL	EAST - B	INTACT	BEIGE	0
1034	EIGHTH	8166	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0
1035	EIGHTH	8178	METAL DOOR	EAST - B	INTACT	BLUE	0.11
1036	EIGHTH	8178	METAL DOOR CASING	EAST - B	Not Intact - POOR	GREEN	2.7
1037	EIGHTH	8178	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0.02
1038	EIGHTH	8178	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0.02
1039	EIGHTH	8178	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0.06
1040	EIGHTH	8178	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
1041	EIGHTH	8178	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
1042	EIGHTH	8178	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
1043	EIGHTH	8178	METAL CONDUIT	SOUTH - C	Not Intact - POOR	TAN	0.13
1044	EIGHTH	8178	CERAMIC BLOCK WALL	SOUTH - C	Not Intact - POOR	TAN	0.01
1046	EIGHTH	8178	CERAMIC BLOCK WALL	WEST - D	Not Intact - POOR	TAN	0.05

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1047	EIGHTH	8178	CERAMIC BLOCK WALL	NORTH - A	Not Intact - POOR	TAN	0.01
1050	EIGHTH	8178	CERAMIC BLOCK WALL	EAST - B	Not Intact - POOR	TAN	0.02
1051	EIGHTH	8178	CONCRETE WALL	SOUTH - C	Not Intact - POOR	TAN	2.5
1052	EIGHTH	8178	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	GRAY	0.11
1053	EIGHTH	8166	CONCRETE FIRE EXTINGUISHER CASING	WEST - D	Not Intact - POOR	GRAY	0.13
1054	EIGHTH	8166	METAL FIRE EXTINGUISHER CASING	WEST - D	Not Intact - POOR	BLUE	2
1055	EIGHTH	8166	METAL PIPE	WEST - D	INTACT	BLUE	0.09
1056	EIGHTH	8166	METAL PIPE	WEST - D	INTACT	BLUE	0.05
1057	EIGHTH	8162	METAL PRIVACY PARTITION	EAST - B	INTACT	BEIGE	0.22
1059	EIGHTH	8001	METAL DOOR	NORTH - A	INTACT	TAN	0.11
1060	EIGHTH	8001	METAL DOOR CASING	NORTH - A	Not Intact - POOR	RED	2.2
1061	EIGHTH	8001	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.1
1062	EIGHTH	8001	METAL CONDUIT	EAST - B	INTACT	BEIGE	0.1
1063	EIGHTH	8001	METAL HATCH	WEST - D	INTACT	BEIGE	0.25
1064	EIGHTH	8001	METAL STAIR RISER	EAST - B	INTACT	TAN	2.2
1065	EIGHTH	8001	CONCRETE STAIR TREAD	EAST - B	Not Intact - POOR	YELLOW	0.07
1066	EIGHTH	8001	METAL STAIR TREAD	EAST - B	Not Intact - POOR	BLACK	0.01
1067	EIGHTH	8001	METAL STAIR RISER	EAST - B	Not Intact - POOR	YELLOW	2.1
1068	EIGHTH	8001	METAL BASEBOARD	NORTH - A	Not Intact - POOR	YELLOW	0.09
1069	EIGHTH	8001	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0.04
1072	EIGHTH	8001	PLASTER WALL	WEST - D	INTACT	BEIGE	0.19
1073	EIGHTH	8001	PLASTER CEILING	EAST - B	INTACT	BEIGE	0
1	EIGHTH	8001	PLASTER CEILING	EAST - B	INTACT	BEIGE	0
2	SEVENTH	7 - 118 - c	PLASTER WALL	NORTH - A	INTACT	BEIGE	2.6
5	SEVENTH	7 - 118 - c	CONCRETE FIRE EXTINGUISHER CASING	NORTH - A	INTACT	RED	0.04
6	SEVENTH	7 - 118 - c	METAL FIRE EXTINGUISHER CASING	NORTH - A	INTACT	BLUE	1.6
7	SEVENTH	7 - 118 - c	METAL HATCH	NORTH - A	INTACT	GRAY	0
8	SEVENTH	7 - 118 - c	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
9	SEVENTH	7 - 118 - c	PLASTER WALL	WEST - D	INTACT	WHITE	2.2
10	SEVENTH	ELEVATOR LOBBY 2	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
11	SEVENTH	ELEVATOR LOBBY 2	WALLBOARD WALL	EAST - B	INTACT	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
12	SEVENTH	ELEVATOR LOBBY 2	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
13	SEVENTH	7212	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
14	SEVENTH	7212	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.02
15	SEVENTH	7212	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0.11
17	SEVENTH	7212	PLASTER WALL	NORTH - A	Not Intact - POOR	WHITE	0.09
18	SEVENTH	7212	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
19	SEVENTH	7212	WOOD DOOR	SOUTH - C	INTACT	GRAY	0
20	SEVENTH	7212	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	GRAY	0.01
21	SEVENTH	7214	METAL DOOR CASING	SOUTH - C	INTACT	GRAY	0
22	SEVENTH	7214	WOOD DOOR	SOUTH - C	INTACT	GRAY	0
23	SEVENTH	7213	WOOD DOOR	NORTH - A	INTACT	GRAY	0
24	SEVENTH	7213	METAL DOOR CASING	NORTH - A	INTACT	GRAY	0
25	SEVENTH	7215	METAL DOOR CASING	SOUTH - C	INTACT	GRAY	0
26	SEVENTH	7215	WOOD DOOR	SOUTH - C	INTACT	GRAY	0
27	SEVENTH	7211	WOOD DOOR	NORTH - A	INTACT	GRAY	0
28	SEVENTH	7216	WOOD DOOR	EAST - B	INTACT	GRAY	0
29	SEVENTH	7217	WOOD DOOR	EAST - B	INTACT	GRAY	0
30	SEVENTH	7218	WOOD DOOR	SOUTH - C	INTACT	GRAY	0
31	SEVENTH	CORR. 1	METAL DOOR CASING	SOUTH - C	INTACT	BLUE	3.6
32	SEVENTH	CORR. 1	METAL AIR VENT - CEILING	NORTH - A	INTACT	BEIGE	0
33	SEVENTH	CORR. 1	PLASTER WALL	WEST - D	INTACT	WHITE	0.11
34	SEVENTH	CORR. 2	PLASTER WALL	EAST - B	INTACT	WHITE	5.9
35	SEVENTH	CORR. 2	PLASTER WALL	WEST - D	INTACT	WHITE	0.01
36	SEVENTH	CORR. 2	METAL DOOR CASING	EAST - B	INTACT	BLUE	- 0.06
38	SEVENTH	7208	METAL AC UNIT	EAST - B	INTACT	WHITE	0.02
39	SEVENTH	7208	METAL PIPE	EAST - B	INTACT	WHITE	0.01
40	SEVENTH	7208	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.02
41	SEVENTH	7154	PLASTER WALL	SOUTH - C	INTACT	WHITE	2
42	SEVENTH	7154	PLASTER WALL	NORTH - A	INTACT	WHITE	2.1
43	SEVENTH	7154	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0.01
44	SEVENTH	7154	METAL DOOR CASING	EAST - B	INTACT	RED	0
45	SEVENTH	7154	METAL DOOR CASING	WEST - D	INTACT	BLUE	4.8
46	SEVENTH	ELEVATOR LOBBY 3	PLASTER WALL	NORTH - A	INTACT	WHITE	2.2
47	SEVENTH	ELEVATOR LOBBY 3	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
48	SEVENTH	ELEVATOR LOBBY 3	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0.01

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
50	SEVENTH	ELEVATOR LOBBY 3	METAL TRIM	EAST - B	INTACT	BEIGE	0.4
51	SEVENTH	ELEVATOR LOBBY 3	METAL PIPE	WEST - D	Not Intact - POOR	BEIGE	0.05
52	SEVENTH	ELEVATOR LOBBY 3	METAL PIPE	WEST - D	Not Intact - POOR	BEIGE	0.07
54	SEVENTH	7154	METAL AC UNIT	NORTH - A	INTACT	BEIGE	0.04
55	SEVENTH	7152	METAL AC UNIT	NORTH - A	INTACT	BEIGE	0.06
56	SEVENTH	7152	METAL PIPE	NORTH - A	INTACT	BEIGE	0
57	SEVENTH	7152	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.01
60	SEVENTH	7152	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.15
61	SEVENTH	7152	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
62	SEVENTH	7152	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.02
63	SEVENTH	7152	METAL CEILING	SOUTH - C	INTACT	WHITE	0.01
64	SEVENTH	7154	METAL CEILING	SOUTH - C	INTACT	WHITE	0.02
65	SEVENTH	7152	METAL CONDUIT	NORTH - A	INTACT	WHITE	0
66	SEVENTH	7152	PLASTER WALL	NORTH - A	INTACT	WHITE	0.21
67	SEVENTH	7152	METAL DOOR CASING	NORTH - A	INTACT	BLUE	3.3
6	SEVENTH	7003	METAL STAIR TREAD	EAST - B	Not Intact - POOR	WHITE	0.01
7	SEVENTH	7003	METAL STAIR TREAD	EAST - B	Not Intact - POOR	BLACK	0.3
8	SEVENTH	7003	METAL BASEBOARD	EAST - B	Not Intact - POOR	WHITE	0.14
10	SEVENTH	7003	METAL STAIR RISER	EAST - B	Not Intact - POOR	WHITE	1
11	SEVENTH	7003	METAL STAIR STRINGER	EAST - B	INTACT	BROWN	4.9
12	SEVENTH	7003	PLASTER CEILING	EAST - B	INTACT	WHITE	0.04
13	SEVENTH	7003	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	1.1
16	SEVENTH	7003	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	RED	1.8
17	SEVENTH	7003	METAL FLOOR	SOUTH - C	Not Intact - POOR	WHITE	0.04
18	SEVENTH	7003	PLASTER WALL	NORTH - A	INTACT	WHITE	1.7
19	SEVENTH	CORR. 8	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	- 0.49
20	SEVENTH	CORR. 8	METAL DOOR CASING	WEST - D	INTACT	RED	0.01
21	SEVENTH	CORR. 8	METAL HATCH	SOUTH - C	INTACT	WHITE	0
22	SEVENTH	CORR. 3	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
23	SEVENTH	CORR. 3	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.02
24	SEVENTH	CORR. 3	METAL RADIATOR	SOUTH - C	INTACT	TAN	0.26
25	SEVENTH	CORR. 3	METAL DUCT	SOUTH - C	INTACT	WHITE	0.03
26	SEVENTH	CORR. 3	PLASTER WALL	EAST - B	INTACT	WHITE	1.9

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
27	SEVENTH	CORR. 3	CONCRETE FIRE EXTINGUISHER CASING	WEST - D	Not Intact - POOR	RED	0.04
29	SEVENTH	CORR. 3	METAL FIRE EXTINGUISHER CASING	WEST - D	INTACT	BLUE	2.7
30	SEVENTH	CORR. 3	METAL PIPE	WEST - D	INTACT	WHITE	0.02
32	SEVENTH	7177	CERAMIC BLOCK WALL	NORTH - A	INTACT	TAN	0.02
33	SEVENTH	7177	CERAMIC BLOCK WALL	EAST - B	INTACT	TAN	0.02
35	SEVENTH	7177	CERAMIC BLOCK WALL	SOUTH - C	INTACT	TAN	0.04
36	SEVENTH	7177	CERAMIC BLOCK WALL	WEST - D	INTACT	TAN	0.01
37	SEVENTH	7177	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0.04
38	SEVENTH	7177	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0.03
39	SEVENTH	7177	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
40	SEVENTH	7177	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.03
41	SEVENTH	7177	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.01
42	SEVENTH	7177	METAL CONDUIT	NORTH - A	INTACT	GRAY	0.06
43	SEVENTH	7177	METAL CONDUIT	NORTH - A	INTACT	GRAY	0.04
44	SEVENTH	7177	METAL CONDUIT	NORTH - A	INTACT	GRAY	0.24
45	SEVENTH	7177	METAL CONDUIT	NORTH - A	INTACT	GRAY	0.17
46	SEVENTH	7174	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
47	SEVENTH	7174	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.16
48	SEVENTH	7174	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	0.02
49	SEVENTH	7174	METAL PIPE	NORTH - A	INTACT	WHITE	0
50	SEVENTH	7174	METAL AC UNIT	EAST - B	INTACT	WHITE	0
54	SEVENTH	7174	METAL DOOR CASING	EAST - B	INTACT	BLUE	2.6
55	SEVENTH	7165	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
59	SEVENTH	7165	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.01
60	SEVENTH	7165	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.29
61	SEVENTH	7165	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0.01
62	SEVENTH	7165	METAL CONDUIT	NORTH - A	INTACT	WHITE	0
63	SEVENTH	7165	METAL AC UNIT	WEST - D	INTACT	WHITE	0.01
64	SEVENTH	7165	METAL PIPE	WEST - D	INTACT	WHITE	0.02
66	SEVENTH	7165	PLASTER CEILING	WEST - D	INTACT	WHITE	0.19
67	SEVENTH	7176	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
68	SEVENTH	7176	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.01

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
69	SEVENTH	7176	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	0.08
70	SEVENTH	7176	METAL CONDUIT	WEST - D	INTACT	WHITE	0.02
71	SEVENTH	7176	METAL AC UNIT	EAST - B	INTACT	WHITE	0.06
72	SEVENTH	7176	METAL PIPE	EAST - B	INTACT	WHITE	4.1
73	SEVENTH	7176	METAL AIR VENT - WALL	EAST - B	INTACT	WHITE	0.02
75	SEVENTH	7176	PLASTER CEILING	EAST - B	INTACT	WHITE	0.05
76	SEVENTH	7176	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.16
77	SEVENTH	7164	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.01
78	SEVENTH	7164	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
79	SEVENTH	7164	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.22
80	SEVENTH	7164	METAL AC UNIT	WEST - D	INTACT	WHITE	0
81	SEVENTH	7164	METAL PIPE	WEST - D	INTACT	WHITE	0.12
82	SEVENTH	7164	METAL HATCH	SOUTH - C	INTACT	WHITE	0
84	SEVENTH	7164	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0
85	SEVENTH	CORR. 4	METAL AC UNIT	EAST - B	INTACT	BEIGE	- 0.2
86	SEVENTH	CORR. 4	PLASTER WALL	SOUTH - C	INTACT	WHITE	2.9
87	SEVENTH	CORR. 4	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	3
88	SEVENTH	CORR. 4	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	2.9
90	SEVENTH	CORR. 4	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	Not Intact - POOR	RED	0.05
91	SEVENTH	7180	METAL PRIVACY PARTITION	EAST - B	INTACT	BEIGE	0.02
92	SEVENTH	7180	METAL PRIVACY PARTITION	EAST - B	INTACT	BEIGE	0.03
93	SEVENTH	7180	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	RED	0.01
94	SEVENTH	7180	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
95	SEVENTH	7180	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0
96	SEVENTH	7180	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.05
97	SEVENTH	7180	PLASTER CEILING	NORTH - A	INTACT	WHITE	0
99	SEVENTH	7180	METAL HATCH	NORTH - A	INTACT	WHITE	0.01
100	SEVENTH	7180	METAL AIR VENT - CEILING	WEST - D	INTACT	WHITE	2.9
101	SEVENTH	7179	METAL CEILING	NORTH - A	INTACT	WHITE	0.03
103	SEVENTH	7001	METAL DOOR CASING	NORTH - A	INTACT	RED	2
104	SEVENTH	7001	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0.17
105	SEVENTH	7001	METAL BASEBOARD	NORTH - A	INTACT	YELLOW	0.11

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
106	SEVENTH	7001	METAL STAIR STRINGER	SOUTH - C	INTACT	TAN	3
107	SEVENTH	7001	CONCRETE STAIR TREAD	SOUTH - C	INTACT	YELLOW	0.07
108	SEVENTH	7001	METAL STAIR TREAD	SOUTH - C	INTACT	BLACK	0.02
109	SEVENTH	7001	METAL STAIR RISER	SOUTH - C	INTACT	YELLOW	1.7
110	SEVENTH	7001	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.13
111	SEVENTH	7001	METAL DOOR CASING	NORTH - A	INTACT	RED	1.9
112	SEVENTH	7001	PLASTER DOOR CASING	EAST - B	INTACT	WHITE	0
113	SEVENTH	7001	PLASTER WALL	WEST - D	INTACT	WHITE	0.15
114	SEVENTH	CORR. 5	METAL HATCH	EAST - B	INTACT	WHITE	0.02
115	SEVENTH	CORR. 5	METAL HATCH	WEST - D	Not Intact - POOR	WHITE	0.03
116	SEVENTH	CORR. 5	METAL HATCH	SOUTH - C	Not Intact - POOR	WHITE	0.02
117	SEVENTH	CORR. 5	WALLBOARD CEILING	SOUTH - C	Not Intact - POOR	WHITE	0.07
118	SEVENTH	CORR. 5	PLASTER WALL	SOUTH - C	INTACT	WHITE	3.8
119	SEVENTH	7185	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.01
120	SEVENTH	7185	METAL CEILING	NORTH - A	INTACT	WHITE	0
121	SEVENTH	7185	PLASTER CEILING	NORTH - A	INTACT	WHITE	0
122	SEVENTH	7185	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.22
125	SEVENTH	7185	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
126	SEVENTH	7185	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
127	SEVENTH	7194	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0.01
128	SEVENTH	7194	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.01
129	SEVENTH	7194	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0.01
130	SEVENTH	7194	METAL PIPE	SOUTH - C	INTACT	WHITE	0.01
131	SEVENTH	7194	METAL AC UNIT	SOUTH - C	INTACT	WHITE	0.01
132	SEVENTH	7194	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.04
133	SEVENTH	7198	METAL PIPE	SOUTH - C	INTACT	WHITE	0.01
136	SEVENTH	7198	METAL AC UNIT	SOUTH - C	INTACT	WHITE	0.05
137	SEVENTH	7198	METAL DOOR CASING	SOUTH - C	INTACT	WHITE	2.4
139	SEVENTH	CORR. 6	PLASTER WALL	NORTH - A	INTACT	WHITE	1.8
141	SEVENTH	CORR. 6	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	4.1
142	SEVENTH	CORR. 6	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLACK	0.03
143	SEVENTH	CORR. 6	PLASTER WALL	SOUTH - C	INTACT	WHITE	1.9
144	SEVENTH	7119	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
145	SEVENTH	7119	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.02
146	SEVENTH	7119	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.13
147	SEVENTH	7119	METAL AC UNIT	NORTH - A	INTACT	TAN	0
148	SEVENTH	7119	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0
149	SEVENTH	7119	METAL HATCH	NORTH - A	INTACT	WHITE	0.01
150	SEVENTH	7119	METAL CONDUIT	WEST - D	INTACT	WHITE	0
151	SEVENTH	7119	METAL AIR VENT - CEILING	WEST - D	INTACT	WHITE	- 0.13
152	SEVENTH	7119	PLASTER CEILING	WEST - D	INTACT	WHITE	0.1
153	SEVENTH	7123	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
154	SEVENTH	7123	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
155	SEVENTH	7123	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
156	SEVENTH	7123	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	- 0.52
160	SEVENTH	7110	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	- 0.34
161	SEVENTH	7110	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
162	SEVENTH	7110	METAL PIPE	NORTH - A	INTACT	WHITE	0.03
163	SEVENTH	7110	METAL AC UNIT	SOUTH - C	INTACT	TAN	0
164	SEVENTH	7110	METAL DUCT	SOUTH - C	INTACT	WHITE	0.02
165	SEVENTH	7110	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.05
166	SEVENTH	7110	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0.02
167	SEVENTH	7110	METAL HATCH	EAST - B	INTACT	WHITE	0.02
168	SEVENTH	CORR. 7	METAL HATCH	SOUTH - C	INTACT	WHITE	0.02
169	SEVENTH	CORR. 7	METAL FAN	SOUTH - C	INTACT	WHITE	0.01
170	SEVENTH	CORR. 7	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0.02
171	SEVENTH	CORR. 7	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.02
172	SEVENTH	CORR. 7	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
173	SEVENTH	CORR. 7	METAL RADIATOR	SOUTH - C	INTACT	GRAY	- 0.41
174	SEVENTH	CORR. 7	PLASTER WALL	WEST - D	INTACT	WHITE	2.2
175	SEVENTH	7133	METAL PIPE	SOUTH - C	INTACT	WHITE	0.05
176	SEVENTH	7133	METAL AC UNIT	WEST - D	INTACT	TAN	0
177	SEVENTH	7133	METAL CONDUIT	WEST - D	INTACT	BEIGE	0
179	SEVENTH	7133	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.4
181	SEVENTH	CORR. 7	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	BLUE	2.4
182	SEVENTH	CORR. 7	CONCRETE FIRE EXTINGUISHER CASING	EAST - B	INTACT	BLACK	0.04
184	SEVENTH	CORR. 7	METAL CONDUIT	EAST - B	INTACT	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
185	SEVENTH	7144	METAL DOOR	WEST - D	INTACT	GRAY	0
186	SEVENTH	7144	METAL DOOR CASING	WEST - D	INTACT	GRAY	0
187	SEVENTH	7144	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	0.07
188	SEVENTH	7144	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
189	SEVENTH	7144	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
190	SEVENTH	7144	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
191	SEVENTH	7144	WALLBOARD CEILING	SOUTH - C	INTACT	WHITE	0
192	SEVENTH	7144	METAL CONDUIT	EAST - B	INTACT	BEIGE	0.08
193	SEVENTH	7142	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.01
194	SEVENTH	7142	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
195	SEVENTH	7142	METAL AC UNIT	EAST - B	INTACT	TAN	0
196	SEVENTH	7142	METAL HATCH	SOUTH - C	INTACT	GRAY	0.03
197	SEVENTH	7142	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.02
198	SEVENTH	7142	METAL PIPE	SOUTH - C	INTACT	WHITE	0.07
200	SEVENTH	7142	METAL DOOR CASING	EAST - B	Not Intact - POOR	GRAY	0.5
201	SEVENTH	7129	CERAMIC BLOCK WALL	NORTH - A	INTACT	TAN	0.01
202	SEVENTH	7129	CERAMIC BLOCK WALL	EAST - B	INTACT	TAN	0.04
203	SEVENTH	7129	CERAMIC BLOCK WALL	SOUTH - C	INTACT	TAN	0.01
204	SEVENTH	7129	CERAMIC BLOCK WALL	WEST - D	INTACT	TAN	0.02
205	SEVENTH	7129	CONCRETE WALL	WEST - D	INTACT	TAN	0.01
206	SEVENTH	7129	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
207	SEVENTH	7129	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.08
208	SEVENTH	7129	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.04
209	SEVENTH	7129	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.01
210	SEVENTH	7129	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0.06
211	SEVENTH	7129	METAL DOOR	WEST - D	Not Intact - POOR	WHITE	0.16
212	SEVENTH	7129	CONCRETE FLOOR	WEST - D	Not Intact - POOR	GRAY	0.04
213	SEVENTH	7128	METAL AC UNIT	SOUTH - C	Not Intact - POOR	TAN	0
214	SEVENTH	7128	METAL FIRE SPRINKLER PIPE	WEST - D	INTACT	RED	0
215	SEVENTH	7128	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
216	SEVENTH	7002	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.18
217	SEVENTH	7002	METAL DOOR CASING	NORTH - A	INTACT	RED	2.3
218	SEVENTH	7002	METAL CONDUIT	WEST - D	INTACT	WHITE	0.18

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
219	SEVENTH	7002	METAL STAIR STRINGER	WEST - D	INTACT	TAN	4.9
220	SEVENTH	7002	METAL BASEBOARD	NORTH - A	Not Intact - POOR	YELLOW	0.14
221	SEVENTH	7002	METAL STAIR RISER	NORTH - A	INTACT	YELLOW	1.4
222	SEVENTH	7002	CONCRETE STAIR TREAD	NORTH - A	INTACT	YELLOW	0.05
223	SEVENTH	7002	METAL STAIR TREAD	NORTH - A	INTACT	BLACK	0.11
224	SEVENTH	7002	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.03
231	SIXTH	6129	CERAMIC BLOCK WALL	NORTH - A	INTACT	ORANGE	0.07
232	SIXTH	6129	CERAMIC BLOCK WALL	NORTH - A	INTACT	ORANGE	0.04
233	SIXTH	6129	CERAMIC BLOCK WALL	EAST - B	INTACT	ORANGE	0.01
234	SIXTH	6129	CERAMIC BLOCK WALL	SOUTH - C	INTACT	ORANGE	0.02
235	SIXTH	6129	CONCRETE WALL	SOUTH - C	INTACT	ORANGE	0.05
236	SIXTH	6129	CONCRETE FLOOR	SOUTH - C	INTACT	GRAY	0.09
237	SIXTH	6129	METAL CONDUIT	NORTH - A	INTACT	GRAY	0.1
238	SIXTH	6129	METAL CONDUIT	NORTH - A	INTACT	GRAY	0.18
239	SIXTH	6129	METAL CONDUIT	NORTH - A	INTACT	GRAY	0.17
240	SIXTH	6129	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
241	SIXTH	6129	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
242	SIXTH	6129	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0.01
243	SIXTH	6129	METAL DOOR CASING	WEST - D	INTACT	YELLOW	2.6
244	SIXTH	6129	METAL DOOR	WEST - D	INTACT	BEIGE	0.1
245	SIXTH	CORR. 1	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
246	SIXTH	CORR. 1	PLASTER WALL	WEST - D	INTACT	WHITE	2.3
247	SIXTH	CORR. 1	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	BLUE	3.8
248	SIXTH	CORR. 1	CONCRETE FIRE EXTINGUISHER CASING	EAST - B	INTACT	BLUE	0.06
249	SIXTH	CORR. 2	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	- 0.09
250	SIXTH	CORR. 2	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
251	SIXTH	CORR. 2	METAL RADIATOR	SOUTH - C	INTACT	WHITE	0.29
252	SIXTH	CORR. 2	METAL DUCT	SOUTH - C	INTACT	WHITE	0.04
253	SIXTH	CORR. 2	METAL FAN	SOUTH - C	INTACT	WHITE	0.02
254	SIXTH	CORR. 2	METAL CONDUIT	WEST - D	INTACT	WHITE	0.02
255	SIXTH	CORR. 2	METAL HATCH	SOUTH - C	INTACT	WHITE	0
256	SIXTH	CORR. 2	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0
257	SIXTH	CORR. 2	PLASTER WALL	EAST - B	INTACT	WHITE	0.05

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
258	SIXTH	6137	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
259	SIXTH	6137	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	0.23
260	SIXTH	6137	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.01
261	SIXTH	6137	METAL HATCH	NORTH - A	INTACT	WHITE	0.3
263	SIXTH	6137	PLASTER WALL	NORTH - A	INTACT	WHITE	0.11
264	SIXTH	6137	METAL DOOR CASING	NORTH - A	INTACT	GRAY	2
265	SIXTH	6137	METAL AC UNIT	EAST - B	INTACT	WHITE	0.04
266	SIXTH	6137	METAL CONDUIT	EAST - B	INTACT	WHITE	0.06
269	SIXTH	6137	PLASTER CEILING	EAST - B	INTACT	WHITE	0.02
270	SIXTH	6134	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.5
271	SIXTH	6134	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
272	SIXTH	6134	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.8
274	SIXTH	6134	PLASTER WALL	NORTH - A	INTACT	WHITE	0.22
275	SIXTH	6134	METAL DOOR CASING	NORTH - A	INTACT	GRAY	3.5
276	SIXTH	6134	METAL AC UNIT	WEST - D	INTACT	WHITE	0
277	SIXTH	6134	METAL PIPE	WEST - D	INTACT	WHITE	0.01
279	SIXTH	6134	METAL CONDUIT	WEST - D	INTACT	WHITE	0.03
280	SIXTH	6134	PLASTER CEILING	WEST - D	INTACT	WHITE	0.01
281	SIXTH	6134	METAL AIR VENT - WALL	WEST - D	INTACT	WHITE	0
282	SIXTH	CORR. 2	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	- 0.28
283	SIXTH	6139	METAL AC UNIT	EAST - B	INTACT	WHITE	0.01
284	SIXTH	6139	METAL PIPE	EAST - B	INTACT	WHITE	0
285	SIXTH	6139	CONCRETE CEILING	EAST - B	INTACT	WHITE	0.02
287	SIXTH	6139	PLASTER WALL	NORTH - A	INTACT	WHITE	0.07
289	SIXTH	6139	METAL DOOR CASING	NORTH - A	INTACT	GRAY	2.2
290	SIXTH	6139	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	0.11
291	SIXTH	6139	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.6
292	SIXTH	6140	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
293	SIXTH	6140	METAL HATCH	SOUTH - C	INTACT	WHITE	0.22
294	SIXTH	6140	METAL AC UNIT	EAST - B	INTACT	WHITE	0
295	SIXTH	6140	METAL DUCT	EAST - B	INTACT	WHITE	0.01
296	SIXTH	6140	METAL PIPE	SOUTH - C	INTACT	WHITE	0.01
297	SIXTH	6140	METAL AIR VENT - WALL	EAST - B	INTACT	WHITE	0
298	SIXTH	6118	METAL HATCH	NORTH - A	INTACT	WHITE	0
299	SIXTH	6118	PLASTER WALL	NORTH - A	Not Intact - POOR	WHITE	0
300	SIXTH	6118	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.01

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
301	SIXTH	6118	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
303	SIXTH	6118	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.28
304	SIXTH	6118	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
305	SIXTH	6119	WOOD DOOR	SOUTH - C	INTACT	WHITE	0
306	SIXTH	6117	WOOD DOOR	SOUTH - C	INTACT	WHITE	0.01
307	SIXTH	6115C	WOOD DOOR	EAST - B	INTACT	GRAY	0
308	SIXTH	6115C	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
309	SIXTH	6115C	PLASTER WALL	WEST - D	INTACT	WHITE	0.15
310	SIXTH	6115C	METAL HATCH	WEST - D	INTACT	WHITE	0.13
311	SIXTH	6115C	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0.4
312	SIXTH	6115C	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.02
313	SIXTH	6115C	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
314	SIXTH	6115C	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
315	SIXTH	CORR. 3	PLASTER WALL	NORTH - A	INTACT	WHITE	1.9
316	SIXTH	CORR. 3	METAL DOOR CASING	WEST - D	INTACT	BLACK	0
317	SIXTH	CORR. 3	METAL DOOR	WEST - D	INTACT	BLACK	0
318	SIXTH	CORR. 3	METAL FIREHOSE CLOSET	SOUTH - C	INTACT	GRAY	3.7
320	SIXTH	CORR. 3	CONCRETE FIREHOSE CLOSET	SOUTH - C	INTACT	GRAY	0.05
321	SIXTH	6127	METAL RADIATOR COVER	SOUTH - C	INTACT	GRAY	0.08
322	SIXTH	6127	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
323	SIXTH	6127	METAL WINDOW SASH	SOUTH - C	INTACT	WHITE	0.6
324	SIXTH	6127	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.04
325	SIXTH	6127	METAL PRIVACY PARTITION	WEST - D	INTACT	BEIGE	0
326	SIXTH	6127	METAL CONDUIT	NORTH - A	INTACT	BEIGE	0.12
327	SIXTH	6127	METAL PIPE	NORTH - A	Not Intact - POOR	WHITE	20.1
328	SIXTH	6127	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.21
329	SIXTH	6127	METAL HATCH	NORTH - A	INTACT	WHITE	0.18
342	SIXTH	6002	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.3
343	SIXTH	6002	METAL DOOR CASING	NORTH - A	Not Intact - POOR	RED	2
344	SIXTH	6002	METAL CONDUIT	WEST - D	INTACT	WHITE	0.08
345	SIXTH	6002	PLASTER WALL	WEST - D	INTACT	WHITE	0.14
349	SIXTH	6002	PLASTER CEILING	WEST - D	INTACT	WHITE	0.1
350	SIXTH	6002	CONCRETE STAIR TREAD	WEST - D	Not Intact - POOR	YELLOW	0.4
351	SIXTH	6002	METAL STAIR TREAD	WEST - D	Not Intact - POOR	BLACK	0.06

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
352	SIXTH	6002	METAL STAIR RISER	WEST - D	Not Intact - POOR	WHITE	1.2
353	SIXTH	6002	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0.07
355	SIXTH	6002	METAL FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0.06
356	SIXTH	CORR. 4	METAL HATCH	SOUTH - C	INTACT	WHITE	0
358	SIXTH	CORR. 4	METAL HATCH	NORTH - A	INTACT	WHITE	0.02
359	SIXTH	CORR. 4	METAL DUCT	NORTH - A	INTACT	WHITE	0.04
360	SIXTH	CORR. 4	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
361	SIXTH	CORR. 4	PLASTER WALL	NORTH - A	INTACT	WHITE	2.1
362	SIXTH	CORR. 4	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	- 0.17
363	SIXTH	CORR. 4	METAL DOOR CASING	WEST - D	INTACT	RED	5
364	SIXTH	CORR. 4	METAL DOOR CASING	WEST - D	INTACT	RED	2.6
365	SIXTH	CORR. 8	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
366	SIXTH	CORR. 8	PLASTER WALL	NORTH - A	INTACT	WHITE	3.1
367	SIXTH	6151	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
368	SIXTH	6151	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
370	SIXTH	6151	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.06
371	SIXTH	6151	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.03
372	SIXTH	6151	METAL PIPE	NORTH - A	INTACT	WHITE	4.9
373	SIXTH	6151	METAL AIR VENT - WALL	NORTH - A	INTACT	WHITE	0.02
374	SIXTH	6151	METAL CEILING	NORTH - A	INTACT	WHITE	0.07
377	SIXTH	6151	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.09
378	SIXTH	6152	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
379	SIXTH	6152	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.28
380	SIXTH	6152	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	- 0.07
381	SIXTH	6152	METAL AC UNIT	NORTH - A	INTACT	WHITE	0
382	SIXTH	6152	METAL AIR VENT - WALL	NORTH - A	INTACT	WHITE	0.02
383	SIXTH	6152	METAL PIPE	NORTH - A	INTACT	WHITE	0
384	SIXTH	6152	METAL CEILING	NORTH - A	INTACT	WHITE	0.01
385	SIXTH	6152	METAL DUCT	NORTH - A	INTACT	WHITE	0
386	SIXTH	6152	METAL DOOR CASING	NORTH - A	Not Intact - POOR	WHITE	0.02
387	SIXTH	6155	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
388	SIXTH	6155	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.01
390	SIXTH	6155	METAL RADIATOR	SOUTH - C	INTACT	WHITE	0.29
391	SIXTH	6155	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.04

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
392	SIXTH	6155	METAL AIR VENT - WALL	NORTH - A	INTACT	WHITE	- 0.03
393	SIXTH	6155	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.06
394	SIXTH	6155	METAL PIPE	NORTH - A	INTACT	WHITE	0.03
395	SIXTH	6155	METAL DUCT	NORTH - A	INTACT	WHITE	0.05
396	SIXTH	6155	METAL CEILING	NORTH - A	INTACT	WHITE	0.08
397	SIXTH	6155	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.16
398	SIXTH	6003	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.04
400	SIXTH	6003	METAL DOOR CASING	SOUTH - C	INTACT	RED	2.9
402	SIXTH	6003	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	1.9
403	SIXTH	6003	CONCRETE STAIR TREAD	EAST - B	Not Intact - POOR	YELLOW	0.05
404	SIXTH	6003	METAL STAIR TREAD	EAST - B	Not Intact - POOR	BLACK	0.02
405	SIXTH	6003	METAL STAIR RISER	EAST - B	Not Intact - POOR	YELLOW	1.3
406	SIXTH	6003	METAL BASEBOARD	SOUTH - C	Not Intact - POOR	YELLOW	0.25
407	SIXTH	6003	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	YELLOW	0.03
408	SIXTH	6003	METAL STAIR STRINGER	NORTH - A	INTACT	BROWN	3
409	SIXTH	ELEVATOR LOBBY 1	METAL FIRE EXTINGUISHER CASING	NORTH - A	INTACT	BLUE	2.8
410	SIXTH	ELEVATOR LOBBY 1	CONCRETE FIRE EXTINGUISHER CASING	NORTH - A	INTACT	GRAY	0.08
413	SIXTH	CORR. 5	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0.01
414	SIXTH	CORR. 5	METAL DOOR	NORTH - A	Not Intact - POOR	GRAY	0
417	SIXTH	CORR. 5	METAL DOOR CASING	NORTH - A	Not Intact - POOR	GRAY	2
418	SIXTH	CORR. 5	METAL THRESHOLD	NORTH - A	Not Intact - POOR	GRAY	28.1
419	SIXTH	CORR. 5	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.19
421	SIXTH	CORR. 5	METAL HATCH	EAST - B	INTACT	WHITE	0.29
422	SIXTH	CORR. 5	METAL FAN	NORTH - A	INTACT	WHITE	0.11
423	SIXTH	CORR. 5	METAL DUCT	NORTH - A	INTACT	WHITE	0.01
424	SIXTH	CORR. 5	METAL PIPE	NORTH - A	INTACT	WHITE	0
425	SIXTH	CORR. 5	METAL CONDUIT	NORTH - A	INTACT	WHITE	0
428	SIXTH	6219	METAL DOOR CASING	WEST - D	INTACT	BLUE	3.1
429	SIXTH	6210	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
430	SIXTH	6210	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.02
431	SIXTH	6210	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	0.22
432	SIXTH	6210	METAL HATCH	WEST - D	INTACT	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
433	SIXTH	6210	WALLBOARD CEILING	WEST - D	INTACT	WHITE	0
434	SIXTH	6210	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0.01
436	SIXTH	6210	METAL AC UNIT	EAST - B	INTACT	WHITE	0
437	SIXTH	6217	METAL AIR VENT - CEILING	NORTH - A	INTACT	BEIGE	0.09
438	SIXTH	6217	METAL PIPE	WEST - D	INTACT	WHITE	0.5
439	SIXTH	6217	PLASTER WALL	EAST - B	INTACT	WHITE	0
440	SIXTH	ELEVATOR LOBBY 2	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
441	SIXTH	ELEVATOR LOBBY 2	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
442	SIXTH	ELEVATOR LOBBY 2	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0.01
443	SIXTH	ELEVATOR LOBBY 2	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
444	SIXTH	ELEVATOR LOBBY 3	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
445	SIXTH	ELEVATOR LOBBY 3	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0
446	SIXTH	ELEVATOR LOBBY 3	METAL PIPE	NORTH - A	Not Intact - POOR	WHITE	0
447	SIXTH	ELEVATOR LOBBY 3	METAL CONDUIT	WEST - D	INTACT	WHITE	0
448	SIXTH	ELEVATOR LOBBY 3	PLASTER WALL	WEST - D	Not Intact - POOR	WHITE	2.3
451	SIXTH	6206	PLASTER WALL	WEST - D	Not Intact - POOR	WHITE	0.06
452	SIXTH	6206	PLASTER CONDUIT	WEST - D	Not Intact - POOR	TAN	0.01
453	SIXTH	6206	METAL DOOR	EAST - B	Not Intact - POOR	PEACH	0.24
455	SIXTH	6206	METAL DOOR CASING	EAST - B	Not Intact - POOR	GREEN	1.8
456	SIXTH	6206	METAL FIRE SPRINKLER PIPE	EAST - B	Not Intact - POOR	RED	0.01
457	SIXTH	6206	METAL PIPE	NORTH - A	Not Intact - POOR	WHITE	0.09
458	SIXTH	6206	METAL PIPE	NORTH - A	Not Intact - POOR	WHITE	0.07
459	SIXTH	CORR. 6	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
460	SIXTH	CORR. 6	PLASTER WALL	SOUTH - C	INTACT	WHITE	2.1
461	SIXTH	CORR. 6	METAL HATCH	SOUTH - C	INTACT	WHITE	0
462	SIXTH	CORR. 6	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
463	SIXTH	CORR. 6	METAL DOOR	SOUTH - C	INTACT	BLACK	0
465	SIXTH	CORR. 6	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	2
466	SIXTH	CORR. 6	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	GRAY	0.06
467	SIXTH	CORR. 6	METAL PIPE	SOUTH - C	INTACT	WHITE	0.01
468	SIXTH	6194	METAL PIPE	SOUTH - C	Not Intact - POOR	WHITE	0.02

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
470	SIXTH	6194	METAL AC UNIT	SOUTH - C	Not Intact - POOR	WHITE	0.02
471	SIXTH	6194	METAL DUCT	SOUTH - C	Not Intact - POOR	WHITE	0.04
472	SIXTH	6194	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.07
473	SIXTH	6194	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	WHITE	1.8
474	SIXTH	CORR. 7	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
475	SIXTH	CORR. 7	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
476	SIXTH	CORR. 7	METAL RADIATOR	SOUTH - C	Not Intact - POOR	BROWN	0.3
477	SIXTH	CORR. 7	METAL FAN	SOUTH - C	INTACT	WHITE	0.04
478	SIXTH	CORR. 7	METAL DUCT	SOUTH - C	INTACT	WHITE	0.13
479	SIXTH	CORR. 7	METAL WINDOW SILL	SOUTH - C	Not Intact - POOR	WHITE	0.4
481	SIXTH	CORR. 7	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
482	SIXTH	CORR. 7	PLASTER WALL	WEST - D	INTACT	WHITE	3
483	SIXTH	6170	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.5
484	SIXTH	6170	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0.01
485	SIXTH	6170	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	0.3
486	SIXTH	6170	METAL AC UNIT	EAST - B	INTACT	WHITE	0.02
487	SIXTH	6170	METAL PIPE	EAST - B	INTACT	WHITE	2.2
488	SIXTH	6170	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0.01
489	SIXTH	6170	METAL HATCH	EAST - B	INTACT	WHITE	0
490	SIXTH	6170	PLASTER CEILING	EAST - B	INTACT	WHITE	0.01
492	SIXTH	6169	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.01
493	SIXTH	6169	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
495	SIXTH	6169	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.14
496	SIXTH	6169	METAL PIPE	WEST - D	INTACT	WHITE	0.04
497	SIXTH	6169	METAL AC UNIT	WEST - D	INTACT	WHITE	0.03
498	SIXTH	6169	METAL DUCT	WEST - D	INTACT	WHITE	0.04
501	SIXTH	6167	METAL DUCT	WEST - D	Not Intact - POOR	WHITE	0.09
502	SIXTH	6167	METAL AC UNIT	WEST - D	INTACT	WHITE	0.03
503	SIXTH	6167	METAL CONDUIT	NORTH - A	INTACT	WHITE	0
504	SIXTH	6176	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.03
505	SIXTH	6176	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
508	SIXTH	6176	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	0.26
509	SIXTH	6176	METAL AC UNIT	EAST - B	INTACT	WHITE	0.1
510	SIXTH	6176	METAL DUCT	EAST - B	INTACT	WHITE	0.03

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
511	SIXTH	6176	METAL PIPE	EAST - B	INTACT	WHITE	0
512	SIXTH	6176	METAL HATCH	EAST - B	INTACT	WHITE	0
514	SIXTH	6176	PLASTER CEILING	EAST - B	INTACT	WHITE	0
515	SIXTH	6164	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0
516	SIXTH	6164	METAL HATCH	SOUTH - C	INTACT	WHITE	0.26
517	SIXTH	6164	METAL DOOR CASING	WEST - D	INTACT	GRAY	2
520	SIXTH	6177	CERAMIC BLOCK WALL	NORTH - A	INTACT	TAN	0.01
523	SIXTH	6177	CERAMIC BLOCK WALL	EAST - B	INTACT	TAN	0.01
526	SIXTH	6177	CERAMIC BLOCK WALL	SOUTH - C	INTACT	TAN	0.02
528	SIXTH	6177	CERAMIC BLOCK WALL	WEST - D	INTACT	TAN	0
529	SIXTH	6177	CONCRETE WALL	SOUTH - C	INTACT	TAN	0.07
530	SIXTH	6177	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	GRAY	0.09
531	SIXTH	6177	METAL CONDUIT	NORTH - A	INTACT	GRAY	0.08
532	SIXTH	6177	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.02
533	SIXTH	6177	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.03
534	SIXTH	6177	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
535	SIXTH	6177	METAL ELECTRICAL BOX MOUNT	WEST - D	Not Intact - POOR	GRAY	0.03
536	SIXTH	6177	METAL ELECTRICAL BOX MOUNT	SOUTH - C	Not Intact - POOR	GRAY	0.08
537	SIXTH	6177	METAL ELECTRICAL BOX MOUNT	SOUTH - C	Not Intact - POOR	GRAY	0.04
538	SIXTH	6001	METAL FIRE SPRINKLER PIPE	NORTH - A	Not Intact - POOR	RED	0.03
539	SIXTH	6001	METAL CONDUIT	EAST - B	Not Intact - POOR	WHITE	0.2
541	SIXTH	6001	CONCRETE STAIR TREAD	SOUTH - C	Not Intact - POOR	YELLOW	0.04
542	SIXTH	6001	METAL STAIR TREAD	SOUTH - C	Not Intact - POOR	BLACK	0.01
544	SIXTH	6001	METAL STAIR RISER	SOUTH - C	Not Intact - POOR	YELLOW	1.3
545	SIXTH	6001	METAL BASEBOARD	NORTH - A	INTACT	YELLOW	0.08
546	SIXTH	6001	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0.01
547	SIXTH	6001	METAL STAIR STRINGER	NORTH - A	Not Intact - POOR	TAN	2.1
548	SIXTH	6180	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0
550	SIXTH	6180	METAL DUCT	SOUTH - C	Not Intact - POOR	WHITE	0.04
551	SIXTH	6180	METAL FAN	SOUTH - C	INTACT	WHITE	0.02
554	SIXTH	6180	METAL CEILING	NORTH - A	Not Intact - POOR	WHITE	0.08
555	SIXTH	6180	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0.02

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
556	SIXTH	6180	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0
557	SIXTH	6180	METAL RADIATOR COVER	SOUTH - C	Not Intact - POOR	BEIGE	0.4
558	SIXTH	6180	METAL PIPE	SOUTH - C	Not Intact - POOR	BEIGE	0.06
559	SIXTH	6180	CERAMIC BLOCK WALL	WEST - D	INTACT	WHITE	2.2
560	SIXTH	RECEPTION	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0.02
561	SIXTH	RECEPTION	METAL DUCT	EAST - B	INTACT	WHITE	0.09
562	SIXTH	RECEPTION	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.03
563	SIXTH	RECEPTION	METAL CEILING	NORTH - A	INTACT	WHITE	- 0.03
565	SIXTH	RECEPTION	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0.09
566	SIXTH	RECEPTION	METAL HATCH	EAST - B	INTACT	WHITE	0.02
567	SIXTH	RECEPTION	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	RED	0
568	SIXTH	RECEPTION	METAL PIPE	WEST - D	INTACT	WHITE	0.08
569	SIXTH	6186	METAL CEILING	NORTH - A	INTACT	WHITE	0.09
570	SIXTH	6188	METAL CEILING	NORTH - A	INTACT	WHITE	0.22
571	SIXTH	6190	METAL CEILING	SOUTH - C	INTACT	WHITE	0.07
572	SIXTH	6190	METAL DOOR CASING	SOUTH - C	INTACT	BLUE	0.03
573	SIXTH	6191	METAL CEILING	WEST - D	INTACT	WHITE	0.11
574	SIXTH	6192	METAL WINDOW CASING	SOUTH - C	INTACT	BLUE	0.04
583	FOURTH	ELEVATOR LOBBY 1	PLASTER WALL	NORTH - A	INTACT	WHITE	2.5
584	FOURTH	ELEVATOR LOBBY 1	METAL FIRE EXTINGUISHER CASING	NORTH - A	INTACT	BLUE	2.6
585	FOURTH	ELEVATOR LOBBY 1	CONCRETE FIRE EXTINGUISHER CASING	NORTH - A	Not Intact - POOR	GRAY	0.04
586	FOURTH	ELEVATOR LOBBY 1	METAL PIPE	NORTH - A	INTACT	WHITE	0
587	FOURTH	CORR. 1	PLASTER WALL	SOUTH - C	INTACT	WHITE	0
588	FOURTH	CORR. 1	METAL DOOR CASING	EAST - B	INTACT	RED	0
589	FOURTH	CORR. 1	METAL DOOR CASING	WEST - D	INTACT	RED	0
590	FOURTH	CORR. 1	METAL AIR VENT - CEILING	WEST - D	INTACT	WHITE	0
591	FOURTH	4150	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
592	FOURTH	4150	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
594	FOURTH	4150	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.06
595	FOURTH	4150	PLASTER WALL	EAST - B	INTACT	WHITE	2
597	FOURTH	4150	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.04
598	FOURTH	4150	METAL DUCT	NORTH - A	INTACT	WHITE	0.02
599	FOURTH	4150	METAL PIPE	NORTH - A	Not Intact - POOR	WHITE	6.4

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
600	FOURTH	4150	METAL CEILING	NORTH - A	INTACT	WHITE	0.07
601	FOURTH	4150	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.11
602	FOURTH	4150	METAL DOOR CASING	NORTH - A	INTACT	BLUE	2.1
603	FOURTH	4153	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
605	FOURTH	4153	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
606	FOURTH	4153	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.11
607	FOURTH	4153	SLATE WINDOW SILL	SOUTH - C	INTACT	WHITE	0
608	FOURTH	4153	METAL CONDUIT	WEST - D	INTACT	WHITE	0
609	FOURTH	4153	METAL CEILING	WEST - D	INTACT	WHITE	0.02
610	FOURTH	4153	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.01
611	FOURTH	4151	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.04
612	FOURTH	4151	METAL AIR VENT - WALL	NORTH - A	INTACT	WHITE	0.04
614	FOURTH	4151	METAL DUCT	NORTH - A	INTACT	WHITE	0.08
616	FOURTH	4151	METAL PIPE	NORTH - A	INTACT	WHITE	0.09
617	FOURTH	4151	METAL CEILING	NORTH - A	INTACT	WHITE	0.05
618	FOURTH	4151	METAL CONDUIT	NORTH - A	INTACT	WHITE	0
620	FOURTH	4151	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.07
621	FOURTH	4151	PLASTER WALL	NORTH - A	INTACT	WHITE	0.17
622	FOURTH	4151	METAL DOOR CASING	WEST - D	INTACT	BLUE	0.02
623	FOURTH	4151	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0.01
624	FOURTH	4151	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.02
625	FOURTH	4151	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.18
626	FOURTH	4151	SLATE WINDOW SILL	SOUTH - C	INTACT	WHITE	0.01
627	FOURTH	4150	SLATE WINDOW SILL	SOUTH - C	INTACT	WHITE	0
628	FOURTH	4003	METAL DOOR CASING	SOUTH - C	INTACT	RED	2.6
629	FOURTH	4003	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	1
630	FOURTH	4003	METAL STAIR STRINGER	NORTH - A	INTACT	TAN	5
631	FOURTH	4003	METAL STAIR BASEBOARD	WEST - D	Not Intact - POOR	YELLOW	2.4
632	FOURTH	4003	CONCRETE STAIR TREAD	WEST - D	Not Intact - POOR	YELLOW	0.1
633	FOURTH	4003	METAL STAIR TREAD	WEST - D	Not Intact - POOR	BLACK	0.01
634	FOURTH	4003	METAL STAIR RISER	WEST - D	Not Intact - POOR	YELLOW	1.9
635	FOURTH	4003	PLASTER CEILING	EAST - B	INTACT	WHITE	0.03
636	FOURTH	4003	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	YELLOW	0.08
637	FOURTH	ELEVATOR LOBBY 2	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
638	FOURTH	ELEVATOR LOBBY 2	WALLBOARD WALL	EAST - B	INTACT	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
639	FOURTH	ELEVATOR LOBBY 2	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
640	FOURTH	ELEVATOR LOBBY 2	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
641	FOURTH	ELEVATOR LOBBY 2	METAL DOOR	EAST - B	INTACT	GRAY	0
643	FOURTH	ELEVATOR LOBBY 2	METAL DOOR CASING	EAST - B	Not Intact - POOR	GRAY	0
644	FOURTH	CORR. 2	PLASTER WALL	EAST - B	Not Intact - POOR	WHITE	1.5
645	FOURTH	CORR. 2	METAL AIR VENT - CEILING	NORTH - A	INTACT	BEIGE	0.01
646	FOURTH	CORR. 2	METAL DOOR CASING	NORTH - A	INTACT	BLUE	4
647	FOURTH	4208	METAL DOOR CASING	EAST - B	Not Intact - POOR	BLUE	0.01
649	FOURTH	4208	METAL PIPE	WEST - D	Not Intact - POOR	WHITE	0.02
650	FOURTH	4208	METAL PIPE	SOUTH - C	Not Intact - POOR	WHITE	0
652	FOURTH	4208	METAL AC UNIT	SOUTH - C	Not Intact - POOR	TAN	0.01
653	FOURTH	4208	PLASTER WALL	WEST - D	INTACT	WHITE	1.7
654	FOURTH	4208	METAL RADIATOR	WEST - D	INTACT	WHITE	0.19
655	FOURTH	4208	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.21
656	FOURTH	4208	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
657	FOURTH	4208	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	0.13
658	FOURTH	4208	WOOD WINDOW SILL	WEST - D	INTACT	WHITE	0.04
659	FOURTH	4207	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
660	FOURTH	4207	METAL HATCH	WEST - D	INTACT	WHITE	0.03
661	FOURTH	4207	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0.01
663	FOURTH	4207	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.15
664	FOURTH	4207	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	WHITE	0
665	FOURTH	CORR. 3	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0
666	FOURTH	CORR. 3	METAL DUCT	WEST - D	INTACT	WHITE	0.11
667	FOURTH	CORR. 3	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0.03
668	FOURTH	CORR. 3	WOOD BOARD	SOUTH - C	INTACT	WHITE	0.04
669	FOURTH	CORR. 3	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0
670	FOURTH	CORR. 3	PLASTER WALL	NORTH - A	INTACT	WHITE	0.08
671	FOURTH	CORR. 3	METAL CONDUIT	NORTH - A	INTACT	WHITE	0.04
672	FOURTH	4254	METAL DOOR	EAST - B	Not Intact - POOR	GRAY	0
673	FOURTH	4254	METAL LADDER	EAST - B	Not Intact - POOR	BLACK	0.02
674	FOURTH	4254	METAL STAIR HANDRAIL	EAST - B	Not Intact - POOR	GRAY	0
675	FOURTH	4254	METAL STAIR STRINGER	EAST - B	Not Intact - POOR	GRAY	0.01

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
676	FOURTH	4254	METAL PIPE	WEST - D	INTACT	GRAY	0.04
677	FOURTH	4254	CONCRETE COLUMN	WEST - D	INTACT	TAN	0.03
679	FOURTH	4254	CONCRETE COLUMN	WEST - D	INTACT	TAN	0.01
680	FOURTH	4254	METAL PIPE	WEST - D	Not Intact - POOR	BLACK	0
681	FOURTH	4254	METAL FIRE SPRINKLER PIPE	SOUTH - C	Not Intact - POOR	BLACK	0
682	FOURTH	4254	METAL TANK	SOUTH - C	Not Intact - POOR	BROWN	0
683	FOURTH	4254	METAL PIPE	SOUTH - C	Not Intact - POOR	BROWN	0
684	FOURTH	4254	CONCRETE BLOCK WALL	SOUTH - C	INTACT	BEIGE	0.02
688	FOURTH	4254	CERAMIC BLOCK WALL	SOUTH - C	Not Intact - POOR	BEIGE	0.02
691	FOURTH	4254	CONCRETE WALL	SOUTH - C	Not Intact - POOR	BEIGE	0.01
692	FOURTH	4254	CONCRETE BLOCK WALL	NORTH - A	Not Intact - POOR	BEIGE	0.02
693	FOURTH	4254	METAL TANK	WEST - D	Not Intact - POOR	GREEN	0
694	FOURTH	4254	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0.11
695	FOURTH	4254	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0
696	FOURTH	4254	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
697	FOURTH	4254	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
701	FOURTH	4254	CONCRETE COLUMN	NORTH - A	INTACT	TAN	0.01
702	FOURTH	CORR. 4	METAL AIR VENT - CEILING	NORTH - A	INTACT	BEIGE	0
703	FOURTH	CORR. 4	METAL HATCH	EAST - B	INTACT	WHITE	0
704	FOURTH	CORR. 4	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	BLUE	2.9
705	FOURTH	CORR. 4	CONCRETE FIRE EXTINGUISHER CASING	EAST - B	INTACT	GRAY	0.07
706	FOURTH	CORR. 4	PLASTER WALL	WEST - D	INTACT	WHITE	2
707	FOURTH	4 - 419	CERAMIC BLOCK WALL	SOUTH - C	INTACT	TAN	0.05
708	FOURTH	4 - 419	CERAMIC BLOCK WALL	WEST - D	INTACT	TAN	0.05
709	FOURTH	4 - 419	CERAMIC BLOCK WALL	NORTH - A	INTACT	TAN	0.04
710	FOURTH	4 - 419	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0.03
711	FOURTH	4 - 419	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0.08
712	FOURTH	4 - 419	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0
713	FOURTH	4 - 419	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.01
714	FOURTH	4 - 419	METAL CONDUIT	WEST - D	INTACT	GRAY	0.3

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
715	FOURTH	4 - 419	METAL CONDUIT	NORTH - A	Not Intact - POOR	TAN	0.08
716	FOURTH	4 - 419	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0
717	FOURTH	4 - 419	CONCRETE WALL	NORTH - A	INTACT	TAN	0.01
718	FOURTH	4 - 419	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	GRAY	0.04
719	FOURTH	4244	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
720	FOURTH	4244	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.12
721	FOURTH	4244	WOOD WINDOW SILL	EAST - B	INTACT	WHITE	0.01
722	FOURTH	4244	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
723	FOURTH	4244	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
724	FOURTH	4244	METAL FIRE SPRINKLER PIPE	SOUTH - C	Not Intact - POOR	BLACK	0
725	FOURTH	4244	METAL DOOR CASING	WEST - D	INTACT	GRAY	0.01
726	FOURTH	4216	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
727	FOURTH	4216	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.06
728	FOURTH	4216	SLATE WINDOW SILL	WEST - D	INTACT	WHITE	0
729	FOURTH	4216	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	0.14
730	FOURTH	4216	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.21
731	FOURTH	4216	PLASTER CEILING	NORTH - A	INTACT	WHITE	0
732	FOURTH	4216	METAL HATCH	NORTH - A	INTACT	GRAY	0
733	FOURTH	4216	METAL DOOR CASING	EAST - B	INTACT	WHITE	0
734	FOURTH	4216	METAL AC UNIT	EAST - B	INTACT	WHITE	0
735	FOURTH	4216	METAL DUCT	EAST - B	INTACT	WHITE	0.01
736	FOURTH	4216	METAL PIPE	EAST - B	INTACT	WHITE	0.01
737	FOURTH	4004	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	RED	0.01
738	FOURTH	4004	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
739	FOURTH	4004	PLASTER CEILING	WEST - D	Not Intact - POOR	WHITE	0.07
740	FOURTH	4004	METAL STAIR STRINGER	WEST - D	Not Intact - POOR	TAN	6.2
741	FOURTH	4004	CONCRETE STAIR TREAD	SOUTH - C	Not Intact - POOR	YELLOW	0.04
742	FOURTH	4004	METAL STAIR TREAD	SOUTH - C	Not Intact - POOR	BLACK	0.01
743	FOURTH	4004	METAL STAIR RISER	SOUTH - C	Not Intact - POOR	YELLOW	1.2
744	FOURTH	4004	METAL BASEBOARD	EAST - B	Not Intact - POOR	YELLOW	0.08
745	FOURTH	4004	CONCRETE FLOOR	EAST - B	Not Intact - POOR	YELLOW	0.06
746	FOURTH	CORR. 5	PLASTER WALL	NORTH - A	INTACT	WHITE	2.1
747	FOURTH	CORR. 5	METAL AIR VENT - CEILING	NORTH - A	INTACT	BEIGE	0.01
748	FOURTH	4243	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
750	FOURTH	4243	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.06
751	FOURTH	4238	METAL PIPE	WEST - D	Not Intact - POOR	WHITE	0.5
752	FOURTH	4238	METAL CONDUIT	WEST - D	Not Intact - POOR	WHITE	0.02
753	FOURTH	4238	METAL FAN	WEST - D	INTACT	BEIGE	0.06
754	FOURTH	4238	METAL HATCH	WEST - D	Not Intact - POOR	GREEN	0
755	FOURTH	4238	METAL HATCH	SOUTH - C	Not Intact - POOR	BEIGE	0.28
756	FOURTH	4238	METAL FIRE SPRINKLER PIPE	NORTH - A	Not Intact - POOR	WHITE	0
757	FOURTH	4226	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0
758	FOURTH	4226	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	BLUE	1.5
759	FOURTH	4226	PLASTER WALL	EAST - B	INTACT	WHITE	0
760	FOURTH	4226	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0
761	FOURTH	4226	METAL AC UNIT	SOUTH - C	INTACT	TAN	0
762	FOURTH	4226	METAL DUCT	SOUTH - C	INTACT	WHITE	0.02
763	FOURTH	4226	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
765	FOURTH	4226	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.01
766	FOURTH	4226	SLATE WINDOW SILL	NORTH - A	INTACT	WHITE	0.3
768	FOURTH	4226	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0.05
769	FOURTH	4232	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.2
770	FOURTH	4232	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
771	FOURTH	4232	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.17
772	FOURTH	4232	METAL FAN	EAST - B	INTACT	WHITE	0
773	FOURTH	4232	METAL DUCT	EAST - B	INTACT	WHITE	0.12
774	FOURTH	4232	METAL AC UNIT	WEST - D	INTACT	WHITE	0.1
775	FOURTH	4232	METAL CEILING	WEST - D	INTACT	WHITE	0.01
776	FOURTH	4232	METAL DOOR CASING	NORTH - A	INTACT	BLUE	2.6
777	FOURTH	4231	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
778	FOURTH	4231	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.4
779	FOURTH	4231	SLATE WINDOW SILL	NORTH - A	INTACT	WHITE	0
781	FOURTH	4231	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0.14
782	FOURTH	4231	PLASTER CEILING	NORTH - A	Not Intact - POOR	WHITE	0.05
784	FOURTH	4231	METAL PIPE	NORTH - A	INTACT	WHITE	1.5
785	FOURTH	4231	PLASTER WALL	EAST - B	INTACT	WHITE	0.01
786	FOURTH	4231	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0
787	FOURTH	4231	METAL AC UNIT	SOUTH - C	INTACT	WHITE	0.01

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
788	FOURTH	4231	METAL AIR VENT - WALL	SOUTH - C	INTACT	WHITE	0.01
789	FOURTH	MECH. RM 2	WOOD WALL	EAST - B	Not Intact - POOR	WHITE	0
790	FOURTH	MECH. RM 2	CONCRETE COLUMN	NORTH - A	INTACT	WHITE	0
791	FOURTH	MECH. RM 2	METAL PIPE	NORTH - A	INTACT	BLACK	0.01
792	FOURTH	MECH. RM 2	CONCRETE COLUMN	SOUTH - C	INTACT	WHITE	0
793	FOURTH	MECH. RM 2	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
794	FOURTH	MECH. RM 2	METAL FAN	SOUTH - C	INTACT	GRAY	0
796	FOURTH	MECH. RM 2	BRICK WALL	SOUTH - C	INTACT	WHITE	0.01
797	FOURTH	MECH. RM 2	BRICK WALL	WEST - D	INTACT	WHITE	0.06
798	FOURTH	MECH. RM 2	METAL BEAM	SOUTH - C	INTACT	WHITE	0
799	FOURTH	MECH. RM 2	METAL BEAM	WEST - D	INTACT	WHITE	0
800	FOURTH	MECH. RM 2	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
802	FOURTH	MECH. RM 2	BRICK WALL	NORTH - A	INTACT	WHITE	0.08
803	FOURTH	MECH. RM 2	METAL FIRE SPRINKLER PIPE	WEST - D	INTACT	RED	0
804	FOURTH	MECH. RM 2	CONCRETE COLUMN	NORTH - A	INTACT	WHITE	0
805	FOURTH	CORR. 6	METAL RADIATOR	SOUTH - C	INTACT	GREEN	0.26
807	FOURTH	CORR. 6	METAL WINDOW SILL	SOUTH - C	Not Intact - POOR	GREEN	0.14
808	FOURTH	CORR. 6	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
809	FOURTH	CORR. 6	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.09
810	FOURTH	CORR. 6	METAL FAN	SOUTH - C	Not Intact - POOR	WHITE	0.01
811	FOURTH	CORR. 6	METAL DUCT	SOUTH - C	INTACT	WHITE	0.03
812	FOURTH	CORR. 6	PLASTER WALL	WEST - D	INTACT	GREEN	0
813	FOURTH	CORR. 6	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	GREEN	3.1
814	FOURTH	CORR. 6	CONCRETE FIRE EXTINGUISHER CASING	EAST - B	INTACT	GRAY	0.04
815	FOURTH	CORR. 6	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
816	FOURTH	4145	WOOD BOARD	NORTH - A	INTACT	GRAY	0.01
817	FOURTH	4145	WALLBOARD WALL	NORTH - A	Not Intact - POOR	WHITE	0
818	FOURTH	4145	WALLBOARD WALL	SOUTH - C	Not Intact - POOR	WHITE	0
819	FOURTH	4145	METAL RADIATOR COVER	WEST - D	Not Intact - POOR	BLUE	0.1
820	FOURTH	4145	METAL PIPE	WEST - D	Not Intact - POOR	BLUE	0.03
821	FOURTH	4145	METAL FIRE SPRINKLER PIPE	WEST - D	INTACT	RED	0.03
822	FOURTH	4145	WALLBOARD CEILING	WEST - D	INTACT	WHITE	0.05
823	FOURTH	4145	METAL PIPE	WEST - D	INTACT	BLACK	0.02

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
824	FOURTH	4145	METAL DOOR CASING	EAST - B	Not Intact - POOR	BLUE	3.8
825	FOURTH	4129	CERAMIC BLOCK WALL	EAST - B	Not Intact - POOR	TAN	0.02
826	FOURTH	4129	CERAMIC BLOCK WALL	EAST - B	Not Intact - POOR	TAN	0.01
827	FOURTH	4129	CERAMIC BLOCK WALL	SOUTH - C	Not Intact - POOR	TAN	0.01
828	FOURTH	4129	CONCRETE WALL	SOUTH - C	Not Intact - POOR	TAN	0.03
829	FOURTH	4129	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.04
831	FOURTH	4129	METAL CONDUIT	NORTH - A	INTACT	TAN	0.07
832	FOURTH	4129	CONCRETE FLOOR	WEST - D	Not Intact - POOR	GRAY	0.01
833	FOURTH	4129	METAL DOOR	WEST - D	Not Intact - POOR	PEACH	0.14
834	FOURTH	CORR. 7	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
835	FOURTH	CORR. 7	METAL CEILING	EAST - B	INTACT	WHITE	0.05
836	FOURTH	CORR. 7	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	RED	0
837	FOURTH	CORR. 7	METAL AC UNIT	EAST - B	INTACT	TAN	0.02
839	FOURTH	CORR. 7	METAL HATCH	EAST - B	INTACT	WHITE	0.01
840	FOURTH	CORR. 7	PLASTER WALL	EAST - B	INTACT	GREEN	0.02
841	FOURTH	CORR. 7	METAL PIPE	NORTH - A	INTACT	GREEN	0.06
842	FOURTH	CORR. 8	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
843	FOURTH	CORR. 8	WALLBOARD WALL	NORTH - A	Not Intact - POOR	GREEN	0
844	FOURTH	CORR. 8	WALLBOARD WALL	SOUTH - C	INTACT	GREEN	0
845	FOURTH	CORR. 8	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	2.7
846	FOURTH	CORR. 8	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	Not Intact - POOR	RED	0.05
847	FOURTH	4002	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.6
848	FOURTH	4002	METAL CONDUIT	WEST - D	INTACT	WHITE	0.1
849	FOURTH	4002	METAL BASEBOARD	NORTH - A	INTACT	YELLOW	0.12
850	FOURTH	4002	METAL STAIR RISER	NORTH - A	Not Intact - POOR	YELLOW	1.4
852	FOURTH	4002	METAL STAIR RISER	SOUTH - C	INTACT	TAN	5.1
853	FOURTH	4002	CONCRETE STAIR TREAD	SOUTH - C	Not Intact - POOR	YELLOW	0.12
854	FOURTH	4002	METAL STAIR TREAD	SOUTH - C	Not Intact - POOR	BLACK	0.01
855	FOURTH	4002	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0.02
858	FOURTH	4002	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.06
859	FOURTH	4157	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0
860	FOURTH	4157	METAL HATCH	NORTH - A	INTACT	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
861	FOURTH	4157	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.01
862	FOURTH	4157	METAL DUCT	NORTH - A	INTACT	WHITE	0.09
863	FOURTH	ELEVATOR LOBBY 3	METAL DOOR	WEST - D	INTACT	BLUE	0
864	FOURTH	ELEVATOR LOBBY 3	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
865	FOURTH	4001	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.03
866	FOURTH	4001	METAL DOOR CASING	NORTH - A	Not Intact - POOR	RED	2
867	FOURTH	4001	METAL STAIR STRINGER	SOUTH - C	INTACT	TAN	3.2
870	FOURTH	4001	METAL STAIR BASEBOARD	WEST - D	Not Intact - POOR	YELLOW	4.2
872	FOURTH	4001	CONCRETE STAIR TREAD	WEST - D	Not Intact - POOR	YELLOW	0.03
873	FOURTH	4001	METAL STAIR RISER	WEST - D	Not Intact - POOR	YELLOW	0.8
874	FOURTH	4001	METAL STAIR TREAD	WEST - D	Not Intact - POOR	BLACK	0
875	FOURTH	4001	CONCRETE FLOOR	WEST - D	Not Intact - POOR	YELLOW	0.02
877	FOURTH	CORR. 9	METAL WINDOW CASING	WEST - D	Not Intact - POOR	WHITE	0.02
878	FOURTH	CORR. 9	SLATE WINDOW SILL	WEST - D	INTACT	BLUE	0
879	FOURTH	CORR. 9	METAL RADIATOR COVER	WEST - D	INTACT	BLUE	- 0.11
880	FOURTH	CORR. 10	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0.03
882	FOURTH	CORR. 10	METAL HATCH	EAST - B	Not Intact - POOR	WHITE	0.02
883	FOURTH	CORR. 10	METAL AIR VENT - CEILING	EAST - B	Not Intact - POOR	WHITE	0
884	FOURTH	CORR. 10	WALLBOARD WALL	SOUTH - C	INTACT	BLUE	0
885	FOURTH	4183	METAL DOOR CASING	NORTH - A	Not Intact - POOR	BLUE	0.15
886	FOURTH	CORR. 10	METAL DOOR CASING	SOUTH - C	INTACT	WHITE	0
887	FOURTH	CORR. 10	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	0
888	FOURTH	CORR. 10	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	0.01
889	FOURTH	BATHROOM	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
890	FOURTH	CORR. 11	METAL RADIATOR	SOUTH - C	Not Intact - POOR	BLUE	- 0.12
891	FOURTH	CORR. 11	METAL WINDOW SILL	SOUTH - C	INTACT	BLUE	- 0.02
892	FOURTH	CORR. 11	METAL DUCT	SOUTH - C	INTACT	WHITE	0.04
894	FOURTH	CORR. 11	METAL FAN	SOUTH - C	INTACT	WHITE	0.05
895	FOURTH	CORR. 11	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	- 0.38
896	FOURTH	CORR. 11	WALLBOARD WALL	WEST - D	INTACT	BLUE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
898	FOURTH	CORR. 11	METAL FIRE EXTINGUISHER CASING	WEST - D	INTACT	BLUE	4.8
899	FOURTH	CORR. 11	CONCRETE FIRE EXTINGUISHER CASING	WEST - D	INTACT	GRAY	0.06
900	FOURTH	4177	CERAMIC BLOCK WALL	NORTH - A	INTACT	TAN	0.01
901	FOURTH	4177	CERAMIC BLOCK WALL	SOUTH - C	INTACT	TAN	0.02
903	FOURTH	4177	CERAMIC BLOCK WALL	WEST - D	INTACT	TAN	0.03
904	FOURTH	4177	METAL CONDUIT	SOUTH - C	INTACT	TAN	0.24
905	FOURTH	4177	METAL ELECTRICAL BOX MOUNT	SOUTH - C	Not Intact - POOR	GRAY	0.06
907	FOURTH	4177	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
908	FOURTH	4177	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0.04
909	FOURTH	4177	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.03
910	FOURTH	4177	CONCRETE WALL	SOUTH - C	INTACT	TAN	0.02
911	FOURTH	4177	CONCRETE FLOOR	SOUTH - C	Not Intact - POOR	GRAY	0.01
921	THIRD	3178	CERAMIC BLOCK WALL	NORTH - A	INTACT	ORANGE	0.03
922	THIRD	3178	CERAMIC BLOCK WALL	SOUTH - C	INTACT	ORANGE	0.01
923	THIRD	3178	CERAMIC BLOCK WALL	WEST - D	INTACT	ORANGE	0.02
924	THIRD	3178	METAL CONDUIT	SOUTH - C	INTACT	ORANGE	0
925	THIRD	3178	METAL CONDUIT	SOUTH - C	INTACT	ORANGE	0.17
926	THIRD	3178	METAL CONDUIT	NORTH - A	INTACT	ORANGE	0.11
928	THIRD	3178	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.05
929	THIRD	3178	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.01
930	THIRD	3178	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0.04
931	THIRD	3178	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0.01
932	THIRD	3178	METAL DOOR	EAST - B	INTACT	GRAY	0.16
933	THIRD	3178	METAL DOOR CASING	EAST - B	INTACT	GREEN	1.8
935	THIRD	3178	CONCRETE FLOOR	EAST - B	INTACT	GRAY	0.07
936	THIRD	3178	CONCRETE WALL	SOUTH - C	INTACT	ORANGE	0.02
937	THIRD	3179	WALLBOARD WALL	WEST - D	INTACT	BEIGE	0
938	THIRD	3179	WALLBOARD WALL	NORTH - A	INTACT	BEIGE	0
939	THIRD	3179	WALLBOARD WALL	SOUTH - C	INTACT	BEIGE	0
940	THIRD	3179	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0
941	THIRD	3179	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
942	THIRD	3179	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
943	THIRD	3179	METAL DOOR CASING	EAST - B	INTACT	GRAY	0.02
944	THIRD	3179	METAL BEAM	NORTH - A	INTACT	GREEN	0
945	THIRD	3163A	METAL BEAM	SOUTH - C	INTACT	GREEN	0
946	THIRD	3163A	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
947	THIRD	3163A	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
948	THIRD	3163A	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
949	THIRD	3163A	WOOD BOARD	NORTH - A	INTACT	GRAY	0
950	THIRD	3163A	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.01
951	THIRD	3 - 174 - 9	METAL FIREHOSE CLOSET	WEST - D	INTACT	WHITE	0
952	THIRD	3 - 174 - 9	METAL FIRE EXTINGUISHER CASING	WEST - D	INTACT	WHITE	0
953	THIRD	3 - 174 - 9	METAL DOOR CASING	SOUTH - C	INTACT	BLUE	0
954	THIRD	3 - 174 - 9	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
955	THIRD	3176	PLASTER WALL	NORTH - A	INTACT	WHITE	0
956	THIRD	3176	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
957	THIRD	3176	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.02
958	THIRD	3176	METAL WINDOW SILL	WEST - D	Not Intact - POOR	WHITE	0
959	THIRD	3176	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
960	THIRD	3176	METAL AC UNIT	EAST - B	INTACT	GRAY	0
961	THIRD	3176B	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
962	THIRD	3168	WALLBOARD COLUMN	EAST - B	INTACT	WHITE	0
963	THIRD	3168	WALLBOARD COLUMN	WEST - D	INTACT	WHITE	0
964	THIRD	3168	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.6
965	THIRD	3168	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
966	THIRD	3168	METAL WINDOW SILL	EAST - B	INTACT	WHITE	0
967	THIRD	3168	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
968	THIRD	3168	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
969	THIRD	3168	METAL AC UNIT	EAST - B	INTACT	GRAY	0
970	THIRD	3168	METAL HATCH	NORTH - A	INTACT	WHITE	0
971	THIRD	3168	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
972	THIRD	3168	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0
973	THIRD	3168	METAL HATCH	WEST - D	INTACT	WHITE	0
974	THIRD	3168	METAL HATCH	WEST - D	INTACT	WHITE	0
975	THIRD	3168	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.02
976	THIRD	3168	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
979	THIRD	3168	METAL WINDOW SILL	WEST - D	INTACT	WHITE	0
980	THIRD	3168	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
981	THIRD	3168	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	WHITE	0
982	THIRD	3-100-M	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	WHITE	0
983	THIRD	3-100-M	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
984	THIRD	3-100-M	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
985	THIRD	3182	METAL DOOR CASING	SOUTH - C	INTACT	GRAY	0
986	THIRD	3180	METAL DOOR CASING	SOUTH - C	INTACT	GRAY	0
987	THIRD	CORR. 1	METAL DOOR CASING	SOUTH - C	INTACT	GRAY	0
988	THIRD	CORR. 1	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
989	THIRD	CORR. 1	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
990	THIRD	3187A	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
992	THIRD	3187A	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.02
993	THIRD	3187A	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
994	THIRD	3187A	METAL HATCH	SOUTH - C	INTACT	WHITE	0
995	THIRD	3187A	WALLBOARD CEILING	SOUTH - C	INTACT	WHITE	0
996	THIRD	3187A	METAL DOOR CASING	EAST - B	Not Intact - POOR	BLUE	0.01
997	THIRD	3001	PLASTER WALL	NORTH - A	INTACT	WHITE	2.4
998	THIRD	3001	PLASTER WALL	WEST - D	INTACT	WHITE	0.09
999	THIRD	3001	PLASTER WALL	EAST - B	INTACT	WHITE	0.09
1001	THIRD	3001	METAL DOOR CASING	NORTH - A	INTACT	RED	2.3
1002	THIRD	3001	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.04
1003	THIRD	3001	METAL CONDUIT	EAST - B	INTACT	WHITE	0.1
1004	THIRD	3001	METAL BASEBOARD	EAST - B	INTACT	YELLOW	0.3
1005	THIRD	3001	METAL FLOOR	EAST - B	Not Intact - POOR	YELLOW	0.7
1006	THIRD	3001	METAL STAIR RISER	SOUTH - C	INTACT	YELLOW	0.8
1007	THIRD	3001	CONCRETE STAIR TREAD	SOUTH - C	INTACT	YELLOW	0.06
1008	THIRD	3001	METAL STAIR TREAD	SOUTH - C	INTACT	BLACK	0.03
1011	THIRD	3001	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.05
1012	THIRD	3001	METAL STAIR STRINGER	SOUTH - C	INTACT	TAN	2.4
1013	THIRD	3200	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
1014	THIRD	3200	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.6
1015	THIRD	3200	METAL WINDOW SILL	NORTH - A	INTACT	WHITE	0
1016	THIRD	3200	PLASTER WALL	WEST - D	INTACT	WHITE	0.2

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1017	THIRD	3200	METAL AC UNIT	SOUTH - C	INTACT	GRAY	0
1018	THIRD	3200	METAL DOOR CASING	SOUTH - C	INTACT	GRAY	0
1019	THIRD	ELEVATOR LOBBY 1	PLASTER WALL	EAST - B	Not Intact - POOR	BEIGE	0.03
1021	THIRD	ELEVATOR LOBBY 1	METAL DOOR CASING	WEST - D	INTACT	GRAY	0
1022	THIRD	ELEVATOR LOBBY 1	METAL CONDUIT	NORTH - A	INTACT	BEIGE	0.04
1023	THIRD	ELEVATOR LOBBY 1	CONCRETE CEILING	NORTH - A	INTACT	BEIGE	0.02
1024	THIRD	ELEVATOR LOBBY 1	METAL DOOR	WEST - D	INTACT	GRAY	0.1
1025	THIRD	ELEVATOR LOBBY 2	PLASTER WALL	NORTH - A	INTACT	WHITE	2.4
1026	THIRD	ELEVATOR LOBBY 2	METAL FIRE EXTINGUISHER CASING	NORTH - A	INTACT	GRAY	3.4
1027	THIRD	ELEVATOR LOBBY 2	CONCRETE FIRE EXTINGUISHER CASING	NORTH - A	INTACT	GRAY	0.03
1029	THIRD	3215	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
1030	THIRD	3215	METAL DOOR CASING	EAST - B	INTACT	GRAY	0
1032	THIRD	3215	METAL WINDOW CASING	EAST - B	INTACT	GRAY	0
1033	THIRD	3215	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
1034	THIRD	3215	METAL HATCH	EAST - B	INTACT	WHITE	0
1036	THIRD	3215	METAL HATCH	EAST - B	INTACT	GRAY	0
1037	THIRD	3215	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0
1038	THIRD	3215	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
1039	THIRD	CORR. 2	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
1040	THIRD	CORR. 2	METAL DOOR CASING	NORTH - A	INTACT	GRAY	0.03
1041	THIRD	CORR. 2	METAL HATCH	EAST - B	INTACT	WHITE	0
1042	THIRD	3200	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0
1043	THIRD	3200	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
1044	THIRD	3200	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
1046	THIRD	3222	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.3
1047	THIRD	3222	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
1048	THIRD	3222	WALLBOARD CEILING	WEST - D	INTACT	WHITE	0
1049	THIRD	3222	METAL HATCH	NORTH - A	INTACT	WHITE	0
1050	THIRD	3222	METAL HATCH	SOUTH - C	INTACT	WHITE	0
1051	THIRD	CORR. 3	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	WHITE	0
1052	THIRD	CORR. 3	WALLBOARD CEILING	WEST - D	INTACT	WHITE	0
1053	THIRD	4001	CONCRETE FLOOR	WEST - D	INTACT	YELLOW	0.04
1054	THIRD	4001	CONCRETE STAIR TREAD	WEST - D	INTACT	YELLOW	0.04

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1055	THIRD	4001	METAL STAIR TREAD	WEST - D	INTACT	BLACK	0.01
1056	THIRD	4001	METAL STAIR RISER	WEST - D	INTACT	YELLOW	1.9
1057	THIRD	4001	METAL BASEBOARD	WEST - D	INTACT	YELLOW	1.9
1058	THIRD	4001	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	RED	0
1059	THIRD	4001	METAL DOOR CASING	EAST - B	INTACT	RED	2.2
1060	THIRD	4001	METAL STAIR STRINGER	EAST - B	INTACT	BEIGE	4.6
1061	THIRD	4001	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.14
1063	THIRD	4001	METAL CONDUIT	EAST - B	INTACT	WHITE	0
1066	THIRD	4001	PLASTER CEILING	EAST - B	INTACT	WHITE	0.1
1068	THIRD	3229	CERAMIC BLOCK WALL	NORTH - A	INTACT	ORANGE	0.03
1069	THIRD	3229	CERAMIC BLOCK WALL	SOUTH - C	INTACT	ORANGE	0.01
1070	THIRD	3229	CERAMIC BLOCK WALL	WEST - D	INTACT	ORANGE	0.02
1071	THIRD	3229	CONCRETE WALL	NORTH - A	INTACT	ORANGE	0.02
1072	THIRD	3229	METAL CONDUIT	NORTH - A	INTACT	ORANGE	0.05
1073	THIRD	3229	METAL DOOR CASING	EAST - B	INTACT	GREEN	2.4
1074	THIRD	3229	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
1076	THIRD	3229	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
1077	THIRD	12	METAL RAILING	NORTH - A	INTACT	GRAY	0
1079	THIRD	12	METAL STAIR STRINGER	NORTH - A	INTACT	GRAY	0
1080	THIRD	4	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
1081	THIRD	4	METAL WINDOW CASING	EAST - B	INTACT	GRAY	0
1082	THIRD	3225	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
1083	THIRD	5	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
1085	THIRD	5	METAL DOOR CASING	NORTH - A	INTACT	GRAY	0
1086	THIRD	6	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
1087	THIRD	6	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
1088	THIRD	6	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
1089	THIRD	6	METAL AIR VENT - CEILING	WEST - D	INTACT	WHITE	0
1090	THIRD	3213B	METAL AIR VENT - CEILING	WEST - D	INTACT	WHITE	0
1091	THIRD	3213B	METAL WINDOW CASING	WEST - D	Not Intact - POOR	GRAY	79.2
1093	THIRD	3213B	WALLBOARD WALL	WEST - D	INTACT	WHITE	1.5
1094	THIRD	3213B	METAL DOOR CASING	WEST - D	Not Intact - POOR	GRAY	0
1095	THIRD	3257	PLASTER WALL	EAST - B	INTACT	WHITE	0
1096	THIRD	3257	PLASTER WALL	NORTH - A	INTACT	WHITE	8
1098	THIRD	3257	PLASTER WALL	SOUTH - C	INTACT	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1099	THIRD	3257	PLASTER WALL	WEST - D	INTACT	WHITE	0
1100	THIRD	3257	WALLBOARD CEILING	WEST - D	INTACT	WHITE	0
1101	THIRD	3257	METAL HATCH	WEST - D	INTACT	WHITE	0
1103	THIRD	7	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
1114	THIRD	3003	CONCRETE STAIR TREAD	SOUTH - C	Not Intact - POOR	YELLOW	0.04
1115	THIRD	3003	METAL STAIR TREAD	SOUTH - C	Not Intact - POOR	BLACK	0.01
1117	THIRD	3003	METAL BASEBOARD	EAST - B	Not Intact - POOR	YELLOW	0.29
1119	THIRD	3003	METAL STAIR RISER	SOUTH - C	Not Intact - POOR	YELLOW	2.9
1120	THIRD	3003	METAL STAIR STRINGER	NORTH - A	INTACT	TAN	6.1
1121	THIRD	3003	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0.22
1122	THIRD	3003	PLASTER WALL	WEST - D	INTACT	WHITE	0.12
1123	THIRD	3003	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.1
1125	THIRD	3003	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0.25
1126	THIRD	3151	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
1127	THIRD	3151	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
1128	THIRD	3151	METAL AC UNIT	NORTH - A	INTACT	GRAY	0
1129	THIRD	3002	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.8
1130	THIRD	3002	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.6
1133	THIRD	3002	METAL CONDUIT	WEST - D	INTACT	WHITE	0.14
1134	THIRD	3002	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.04
1135	THIRD	3002	METAL STAIR STRINGER	SOUTH - C	INTACT	TAN	2.4
1136	THIRD	3002	METAL STAIR RISER	SOUTH - C	Not Intact - POOR	YELLOW	1.2
1137	THIRD	3002	METAL STAIR BASEBOARD	WEST - D	Not Intact - POOR	YELLOW	2.2
1138	THIRD	3002	CONCRETE STAIR TREAD	SOUTH - C	Not Intact - POOR	YELLOW	0.03
1139	THIRD	3002	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0.09
1140	THIRD	3002	METAL STAIR TREAD	SOUTH - C	Not Intact - POOR	BLACK	0.06
1141	THIRD	CORR. 8	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
1142	THIRD	CORR. 8	METAL HATCH	SOUTH - C	INTACT	GRAY	0
1143	THIRD	CORR. 8	METAL DOOR CASING	WEST - D	INTACT	RED	0
1147	THIRD	CORR. 9	PLASTER WALL	WEST - D	INTACT	WHITE	3
1148	THIRD	CORR. 9	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	BLUE	3.7
1149	THIRD	CORR. 9	CONCRETE FIRE EXTINGUISHER CASING	EAST - B	INTACT	BLACK	0.06

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1150	THIRD	3141	PLASTER CEILING	EAST - B	INTACT	WHITE	0.05
1151	THIRD	3141	METAL HATCH	EAST - B	INTACT	WHITE	0
1152	THIRD	3141	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
1153	THIRD	3141	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	- 0.29
1154	THIRD	3141	SLATE WINDOW SILL	WEST - D	INTACT	WHITE	0
1155	THIRD	3132	SLATE WINDOW SILL	EAST - B	INTACT	WHITE	- 0.09
1156	THIRD	3132	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.02
1157	THIRD	3132	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
1158	THIRD	3130a	METAL RADIATOR COVER	EAST - B	INTACT	BLUE	0.5
1168	THIRD	3142	METAL RADIATOR COVER	WEST - D	Not Intact - POOR	WHITE	0.9
1169	THIRD	3142	SLATE WINDOW SILL	WEST - D	INTACT	WHITE	0
1170	THIRD	3142	WALLBOARD CEILING	WEST - D	INTACT	WHITE	0.08
1171	THIRD	3116	METAL WINDOW CASING	WEST - D	INTACT	BLACK	0
1172	THIRD	3116	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0.01
1173	THIRD	3116	METAL DOOR	SOUTH - C	INTACT	BLACK	0
1174	THIRD	3116	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0
1175	THIRD	3116	WALLBOARD DOOR	SOUTH - C	INTACT	WHITE	0
1176	THIRD	3116	WALLBOARD DOOR	WEST - D	INTACT	WHITE	0
1177	THIRD	3123	WALLBOARD DOOR	NORTH - A	INTACT	WHITE	0
1178	THIRD	CORR. 11	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
1179	THIRD	CORR. 11	METAL WINDOW CASING	SOUTH - C	INTACT	BLACK	0
1180	THIRD	CORR. 11	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	WHITE	0
1181	SECOND	2003	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0.23
1182	SECOND	2003	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0.2
1183	SECOND	2003	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	RED	2.1
1185	SECOND	2003	PLASTER WALL	EAST - B	INTACT	WHITE	0.19
1186	SECOND	2003	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.03
1187	SECOND	2003	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	WHITE	0.02
1188	SECOND	2003	METAL BASEBOARD	WEST - D	Not Intact - POOR	YELLOW	0.06
1189	SECOND	2002	METAL BASEBOARD	NORTH - A	Not Intact - POOR	YELLOW	0.21
1190	SECOND	2002	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.6
1192	SECOND	2002	METAL DOOR CASING	NORTH - A	INTACT	RED	2.7
1193	SECOND	2002	CONCRETE STAIR TREAD	SOUTH - C	Not Intact - POOR	YELLOW	0.07

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1194	SECOND	2002	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0.07
1198	SECOND	2002	METAL STAIR RISER	SOUTH - C	Not Intact - POOR	YELLOW	0.3
1199	SECOND	2002	METAL STAIR STRINGER	SOUTH - C	INTACT	TAN	6.4
1200	SECOND	2002	METAL CONDUIT	WEST - D	INTACT	WHITE	0.18
1201	SECOND	2002	PLASTER WALL	EAST - B	INTACT	WHITE	0.15
1202	SECOND	2002	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.12
1203	SECOND	CORR. 1	PLASTER WALL	NORTH - A	INTACT	WHITE	2.3
1204	SECOND	CORR. 1	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
1206	SECOND	CORR. 1	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	3.3
1208	SECOND	CORR. 1	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	GRAY	0.05
1209	SECOND	CORR. 1	METAL PIPE	SOUTH - C	INTACT	GRAY	0.02
1210	SECOND	CORR. 1	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	WHITE	0
1211	SECOND	CORR. 1	PLASTER WALL	NORTH - A	INTACT	WHITE	0
1212	SECOND	2106	METAL PRIVACY PARTITION	EAST - B	INTACT	GRAY	0
1214	SECOND	2106	METAL PIPE	NORTH - A	INTACT	WHITE	0.02
1215	SECOND	2106	METAL DUCT	SOUTH - C	INTACT	WHITE	0.01
1216	SECOND	2106	METAL LOUVER	SOUTH - C	INTACT	GRAY	4.4
1217	SECOND	2105	METAL LOUVER	SOUTH - C	INTACT	GRAY	3
1218	SECOND	2105	METAL PRIVACY PARTITION	EAST - B	INTACT	GRAY	0
1219	SECOND	2105	METAL DUCT	SOUTH - C	INTACT	WHITE	0.01
1220	SECOND	2105	METAL DOOR CASING	SOUTH - C	INTACT	BLUE	1.7
1221	SECOND	2113	PLASTER COLUMN	NORTH - A	INTACT	WHITE	0.09
1223	SECOND	2113	PLASTER COLUMN	SOUTH - C	INTACT	WHITE	0.2
1225	SECOND	2113	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
1226	SECOND	2113	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.14
1230	SECOND	2113	WOOD WINDOW SILL	NORTH - A	Not Intact - POOR	WHITE	0
1231	SECOND	2113	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0
1232	SECOND	2113	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0
1233	SECOND	2113	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.5
1234	SECOND	2113	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
1237	SECOND	2113	WOOD WINDOW SILL	SOUTH - C	Not Intact - POOR	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1238	SECOND	CORR. 2	METAL FIRE EXTINGUISHER CASING	EAST - B	Not Intact - POOR	WHITE	0
1239	SECOND	CORR. 2	CONCRETE FIRE EXTINGUISHER CASING	EAST - B	Not Intact - POOR	RED	0.07
1240	SECOND	CORR. 2	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
1241	SECOND	2141	METAL DOOR CASING	EAST - B	INTACT	BLUE	0
1242	SECOND	2132	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
1244	SECOND	2132	METAL WINDOW CASING	EAST - B	INTACT	WHITE	- 0.2
1245	SECOND	2132	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.07
1246	SECOND	2132	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
1259	SECOND	2130	CERAMIC BLOCK WALL	NORTH - A	INTACT	TAN	0.02
1260	SECOND	2130	CERAMIC BLOCK WALL	EAST - B	INTACT	TAN	0.02
1261	SECOND	2130	CERAMIC BLOCK WALL	SOUTH - C	INTACT	TAN	0.04
1262	SECOND	2130	CERAMIC BLOCK WALL	WEST - D	INTACT	TAN	0.01
1264	SECOND	2130	METAL CONDUIT	WEST - D	Not Intact - POOR	TAN	0.02
1265	SECOND	2130	METAL CONDUIT	EAST - B	Not Intact - POOR	TAN	0.21
1266	SECOND	2130	METAL CONDUIT	SOUTH - C	Not Intact - POOR	TAN	0.07
1267	SECOND	2130	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.02
1268	SECOND	2130	METAL ELECTRICAL BOX MOUNT	EAST - B	Not Intact - POOR	GRAY	0.02
1269	SECOND	2130	METAL ELECTRICAL BOX MOUNT	SOUTH - C	Not Intact - POOR	GRAY	0.1
1270	SECOND	2130	CONCRETE WALL	SOUTH - C	INTACT	TAN	0.02
1271	SECOND	2130	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	GRAY	0.04
1272	SECOND	2130	METAL DOOR CASING	WEST - D	Not Intact - POOR	GREEN	2.1
1273	SECOND	2150	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
1274	SECOND	2150	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
1275	SECOND	2150	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
1276	SECOND	2150	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
1277	SECOND	2150	SLATE WINDOW SILL	SOUTH - C	INTACT	WHITE	0
1278	SECOND	2150	METAL AC UNIT	NORTH - A	INTACT	GRAY	0
1279	SECOND	CORR. 3	PLASTER WALL	NORTH - A	INTACT	WHITE	2.9
1280	SECOND	CORR. 3	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
1281	SECOND	CORR. 3	METAL FIRE EXTINGUISHER CASING	NORTH - A	INTACT	WHITE	0
1282	SECOND	CORR. 3	METAL AIR VENT - CEILING	NORTH - A	INTACT	BEIGE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1283	SECOND	CORR. 3	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0
1285	SECOND	CORR. 3	METAL HATCH	NORTH - A	INTACT	WHITE	0
1286	SECOND	CORR. 3	METAL DOOR CASING	WEST - D	INTACT	BLUE	0
1287	SECOND	ELEVATOR LOBBY 1	METAL FIRE EXTINGUISHER CASING	NORTH - A	INTACT	BLUE	2.9
1288	SECOND	ELEVATOR LOBBY 1	CONCRETE FIRE EXTINGUISHER CASING	NORTH - A	INTACT	GRAY	0.06
1289	SECOND	ELEVATOR LOBBY 1	METAL DOOR	EAST - B	INTACT	BLUE	0
1291	SECOND	ELEVATOR LOBBY 1	METAL WALL	NORTH - A	INTACT	WHITE	0
1292	SECOND	ELEVATOR LOBBY 1	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
1293	SECOND	ELEVATOR LOBBY 1	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
1294	SECOND	2222	BRICK WALL	SOUTH - C	Not Intact - POOR	WHITE	0
1295	SECOND	2222	METAL PIPE	SOUTH - C	INTACT	BLACK	0
1297	SECOND	2222	CONCRETE COLUMN	EAST - B	INTACT	WHITE	0
1298	SECOND	2222	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	RED	0
1299	SECOND	2222	METAL FIRE SPRINKLER PIPE	SOUTH - C	INTACT	RED	0.02
1300	SECOND	2222	CONCRETE COLUMN	SOUTH - C	INTACT	WHITE	0
1301	SECOND	2222	CONCRETE COLUMN	NORTH - A	INTACT	WHITE	0
1302	SECOND	2222	METAL BEAM	NORTH - A	INTACT	GREEN	0
1304	SECOND	2222	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.01
1305	SECOND	2222	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
1306	SECOND	2222	METAL TRANSFORMER	NORTH - A	INTACT	GRAY	0
1307	SECOND	2222	METAL TRANSFORMER	WEST - D	INTACT	GRAY	0
1308	SECOND	2222	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0
1309	SECOND	2222	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0
1310	SECOND	2222	METAL CONDUIT	WEST - D	INTACT	WHITE	0
1311	SECOND	2222	METAL CONDUIT	WEST - D	INTACT	WHITE	0
1312	SECOND	2222	METAL BEAM	WEST - D	INTACT	WHITE	0
1313	SECOND	2222	BRICK WALL	NORTH - A	INTACT	WHITE	0.01
1314	SECOND	2222	METAL FIRE SPRINKLER PIPE	WEST - D	INTACT	RED	0.01
1315	SECOND	2222	CONCRETE COLUMN	WEST - D	INTACT	WHITE	0
1316	SECOND	CORR. 3	METAL FIREHOSE CLOSET	WEST - D	INTACT	WHITE	0
1317	SECOND	CORR. 3	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
1319	SECOND	CORR. 3	METAL WINDOW CASING	EAST - B	INTACT	BLUE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1320	SECOND	2 - 56 - M	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
1321	SECOND	2 - 56 - M	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.06
1322	SECOND	2 - 56 - M	METAL RADIATOR	NORTH - A	INTACT	WHITE	0.4
1325	SECOND	2 - 56 - M	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0.6
1326	SECOND	2 - 56 - M	SLATE WINDOW SILL	NORTH - A	INTACT	WHITE	0
1327	SECOND	2 - 56 - M	WALLBOARD CEILING	NORTH - A	INTACT	WHITE	0
1328	SECOND	2 - 56 - M	METAL RADIATOR	EAST - B	INTACT	WHITE	0.5
1329	SECOND	2 - 56 - M	METAL HATCH	EAST - B	INTACT	WHITE	0
1330	SECOND	2 - 56 - M	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
1331	SECOND	2 - 56 - M	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.3
1332	SECOND	2 - 56 - M	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	GRAY	3.5
1334	SECOND	2 - 56 - M	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	Not Intact - POOR	GRAY	0.11
1335	SECOND	CORR. 4	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
1336	SECOND	CORR. 4	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.4
1337	SECOND	CORR. 4	WALLBOARD WINDOW SILL	EAST - B	Not Intact - POOR	BLUE	0.08
1338	SECOND	CORR. 4	WALLBOARD WINDOW SILL	EAST - B	Not Intact - POOR	BLUE	0.17
1339	SECOND	CORR. 4	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.23
1340	SECOND	CORR. 5	METAL CEILING	NORTH - A	INTACT	WHITE	0.02
1341	SECOND	CORR. 5	METAL ELECTRICAL BOX MOUNT	SOUTH - C	Not Intact - POOR	WHITE	0.4
1342	SECOND	CORR. 5	METAL HATCH	EAST - B	INTACT	WHITE	0
1343	SECOND	CORR. 5	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	WHITE	2.4
1344	SECOND	CORR. 5	METAL FIRE EXTINGUISHER CASING	EAST - B	Not Intact - POOR	GRAY	0.04
1345	SECOND	CORR. 5	PLASTER CEILING	WEST - D	INTACT	WHITE	0.07
1346	SECOND	CORR. 5	METAL DUCT	NORTH - A	INTACT	WHITE	0.13
1347	SECOND	CORR. 5	METAL FIRE SPRINKLER PIPE	NORTH - A	Not Intact - POOR	BLACK	0
1348	SECOND	2214	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	BLUE	0.02
1349	SECOND	2214	METAL DUCT	SOUTH - C	INTACT	WHITE	- 0.26
1350	SECOND	2214	METAL WINDOW CASING	NORTH - A	INTACT	BLACK	0
1351	SECOND	2214	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.04
1352	SECOND	2214	SLATE WINDOW SILL	NORTH - A	Not Intact - POOR	WHITE	0.5
1353	SECOND	2214	SLATE WINDOW SILL	NORTH - A	Not Intact - POOR	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1354	SECOND	2213a	CONCRETE WALL	NORTH - A	INTACT	TAN	0.03
1355	SECOND	2213a	CONCRETE WALL	EAST - B	Not Intact - POOR	GRAY	0.14
1356	SECOND	2213a	METAL DOOR	EAST - B	Not Intact - POOR	PEACH	0.13
1357	SECOND	2004	METAL DOOR	WEST - D	INTACT	GRAY	0
1358	SECOND	2004	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	RED	0
1359	SECOND	2004	CONCRETE STAIR TREAD	WEST - D	Not Intact - POOR	YELLOW	0.04
1360	SECOND	2004	CONCRETE STAIR TREAD	WEST - D	Not Intact - POOR	BLACK	0.02
1361	SECOND	2004	METAL STAIR RISER	WEST - D	Not Intact - POOR	YELLOW	2.2
1362	SECOND	2004	METAL BASEBOARD	WEST - D	Not Intact - POOR	YELLOW	0.14
1363	SECOND	2004	METAL STAIR STRINGER	WEST - D	INTACT	TAN	5.6
1364	SECOND	2004	PLASTER WALL	SOUTH - C	INTACT	WHITE	0.14
1365	SECOND	2004	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0
1366	SECOND	2216	METAL DUCT	WEST - D	INTACT	WHITE	0.13
1368	SECOND	2216	METAL CEILING	WEST - D	INTACT	WHITE	0
1369	SECOND	2216	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
1370	SECOND	2216	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.01
1371	SECOND	2216	SLATE WINDOW SILL	SOUTH - C	INTACT	WHITE	0.25
1372	SECOND	2216	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.1
1374	SECOND	2216	METAL RADIATOR	SOUTH - C	INTACT	WHITE	0.4
1376	SECOND	2216	METAL RADIATOR	NORTH - A	INTACT	WHITE	0.24
1379	SECOND	2216	METAL CEILING	NORTH - A	INTACT	WHITE	0.01
1380	SECOND	2216	METAL DUCT	NORTH - A	INTACT	WHITE	0.4
1384	SECOND	2216	SLATE WINDOW SILL	NORTH - A	Not Intact - POOR	WHITE	0
1385	SECOND	2216	SLATE RADIATOR COVER	NORTH - A	INTACT	WHITE	0.1
1386	SECOND	2216b	METAL CEILING	EAST - B	INTACT	WHITE	0.02
1387	SECOND	2216b	SLATE WINDOW SILL	NORTH - A	INTACT	WHITE	0
1388	SECOND	2216b	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	0.12
1389	SECOND	221A	METAL STAIR HANDRAIL	NORTH - A	Not Intact - POOR	GRAY	0
1390	SECOND	221A	METAL STAIR STRINGER	SOUTH - C	INTACT	GRAY	0
1391	SECOND	221E	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	WHITE	0
1393	SECOND	CORR. 6	PLASTER WALL	WEST - D	INTACT	WHITE	2.2
1394	SECOND	CORR. 6	METAL HATCH	EAST - B	INTACT	GRAY	0
1395	SECOND	CORR. 6	METAL DOOR	WEST - D	INTACT	GRAY	- 0.4

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1396	SECOND	CORR. 6	METAL FIRE EXTINGUISHER CASING	WEST - D	INTACT	BLACK	2.8
1397	SECOND	CORR. 6	CONCRETE FIRE EXTINGUISHER CASING	WEST - D	INTACT	BLUE	0.04
1398	SECOND	CORR. 6	METAL PIPE	WEST - D	INTACT	BROWN	0
1399	SECOND	CORR. 6	METAL PIPE	WEST - D	INTACT	BROWN	0
1400	SECOND	CORR. 6	METAL FIRE EXTINGUISHER CASING	WEST - D	INTACT	WHITE	0
1402	SECOND	2164	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
1403	SECOND	2164	METAL AC UNIT	WEST - D	INTACT	GRAY	0
1404	SECOND	2164	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
1407	SECOND	2165	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
1408	SECOND	2165	METAL AC UNIT	WEST - D	INTACT	GRAY	0
1409	SECOND	2165	METAL DOOR CASING	WEST - D	Not Intact - POOR	GRAY	0
1410	SECOND	2177	METAL DOOR CASING	EAST - B	INTACT	GRAY	0
1411	SECOND	2177	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
1412	SECOND	2170	METAL AC UNIT	NORTH - A	INTACT	GRAY	0
1413	SECOND	2170	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
1414	SECOND	2170	WALLBOARD WALL	NORTH - A	INTACT	WHITE	8.8
1415	SECOND	2170	WALLBOARD WALL	EAST - B	INTACT	WHITE	8.1
1416	SECOND	2170	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
1417	SECOND	2170	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
1418	SECOND	2001	PLASTER WALL	NORTH - A	INTACT	WHITE	0.22
1419	SECOND	2001	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.17
1420	SECOND	2001	METAL BASEBOARD	NORTH - A	Not Intact - POOR	BEIGE	0.19
1421	SECOND	2001	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	BEIGE	- 0.14
1422	SECOND	2001	CONCRETE STAIR TREAD	SOUTH - C	Not Intact - POOR	BEIGE	- 0.55
1423	SECOND	2001	METAL STAIR TREAD	SOUTH - C	Not Intact - POOR	BLACK	0
1424	SECOND	2001	METAL STAIR STRINGER	SOUTH - C	INTACT	TAN	3.8
1425	SECOND	2001	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.18
1426	SECOND	CORR. 7	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
1427	SECOND	CORR. 7	METAL FIREHOSE CLOSET	SOUTH - C	INTACT	WHITE	0
1428	SECOND	CORR. 7	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	WHITE	0
1429	SECOND	CORR. 7	WALLBOARD CEILING	SOUTH - C	INTACT	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1430	SECOND	CORR. 7	METAL HATCH	SOUTH - C	INTACT	WHITE	0
1431	SECOND	CORR. 7	METAL DOOR CASING	WEST - D	INTACT	RED	0
1432	SECOND	CORR. 7	METAL WINDOW CASING	SOUTH - C	INTACT	BLUE	0
1433	SECOND	2182	METAL AC UNIT	NORTH - A	INTACT	GRAY	0
1434	SECOND	2182	METAL AC UNIT	NORTH - A	INTACT	GRAY	0
1435	SECOND	2182	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	0
1436	FIRST	1152a	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.01
1437	FIRST	1152a	METAL DUCT	NORTH - A	INTACT	WHITE	0.02
1438	FIRST	1152a	METAL PIPE	NORTH - A	INTACT	WHITE	0.2
1439	FIRST	1152a	METAL CONDUIT	NORTH - A	INTACT	WHITE	0
1440	FIRST	1152a	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.04
1441	FIRST	1152a	PLASTER WALL	NORTH - A	INTACT	WHITE	0.18
1442	FIRST	1152a	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
1443	FIRST	1152a	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.02
1444	FIRST	1152a	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.2
1446	FIRST	1152a	SLATE WINDOW SILL	SOUTH - C	INTACT	WHITE	0
1447	FIRST	CORR. 1	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	BLUE	2.5
1448	FIRST	CORR. 1	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	- 0.25
1449	FIRST	CORR. 1	METAL CONDUIT	EAST - B	INTACT	WHITE	0
1450	FIRST	CORR. 1	METAL HATCH	EAST - B	INTACT	WHITE	0
1451	FIRST	CORR. 1	PLASTER WALL	WEST - D	INTACT	WHITE	2.3
1452	FIRST	CORR. 1	METAL FIRE EXTINGUISHER CASING	WEST - D	INTACT	BLUE	2.5
1453	FIRST	CORR. 1	CONCRETE FIRE EXTINGUISHER CASING	WEST - D	INTACT	GRAY	0.1
1454	FIRST	CORR. 1	METAL PIPE	WEST - D	INTACT	WHITE	0.06
1455	FIRST	1160	METAL PIPE	EAST - B	INTACT	WHITE	0.02
1457	FIRST	1160	METAL AC UNIT	EAST - B	INTACT	WHITE	0.01
1458	FIRST	1160	METAL DUCT	EAST - B	INTACT	WHITE	0.04
1459	FIRST	1160	METAL AIR VENT - WALL	EAST - B	INTACT	WHITE	0
1460	FIRST	1160	PLASTER CEILING	EAST - B	INTACT	WHITE	0.01
1463	FIRST	1160	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0.01
1464	FIRST	1160	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.02
1465	FIRST	1160	METAL HATCH	EAST - B	INTACT	WHITE	0
1466	FIRST	1160	METAL CONDUIT	WEST - D	INTACT	WHITE	0
1467	FIRST	1160	METAL DOOR CASING	SOUTH - C	Not Intact - POOR	BLUE	6.5

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1468	FIRST	1160	PLASTER WALL	NORTH - A	Not Intact - POOR	WHITE	0.07
1476	FIRST	1159	CONCRETE FLOOR	WEST - D	Not Intact - POOR	GRAY	0.22
1477	FIRST	1159	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
1478	FIRST	1159	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
1480	FIRST	1159	METAL PIPE	EAST - B	INTACT	WHITE	0
1481	FIRST	1159	PLASTER CEILING	EAST - B	Not Intact - POOR	WHITE	0.5
1482	FIRST	1159	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.03
1483	FIRST	1158	METAL FIRE SPRINKLER PIPE	EAST - B	INTACT	RED	0
1484	FIRST	1158	CONCRETE FLOOR	EAST - B	INTACT	GRAY	0.01
1485	FIRST	1158	SLATE WINDOW SILL	WEST - D	INTACT	WHITE	0
1486	FIRST	1158	PLASTER CEILING	EAST - B	INTACT	WHITE	0.02
1487	FIRST	1159	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
1488	FIRST	1159	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.02
1489	FIRST	1159	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.21
1490	FIRST	1159	METAL CONDUIT	SOUTH - C	INTACT	WHITE	0
1491	FIRST	1159	SLATE WINDOW SILL	EAST - B	INTACT	WHITE	0
1492	FIRST	1159	METAL AC UNIT	WEST - D	INTACT	WHITE	0.06
1493	FIRST	1159	METAL DUCT	WEST - D	INTACT	WHITE	0.01
1494	FIRST	1114	METAL X - RAY SHIELD	NORTH - A	INTACT	BLUE	14.7
1495	FIRST	1114	PLASTER WALL	NORTH - A	INTACT	BLUE	0
1496	FIRST	1114	WALLBOARD WALL	SOUTH - C	INTACT	BLUE	7
1497	FIRST	1114	WALLBOARD WALL	NORTH - A	INTACT	BLUE	0
1498	FIRST	1114	WALLBOARD WALL	WEST - D	INTACT	BLUE	8.1
1499	FIRST	1114	LINOLEUM FLOOR	NORTH - A	INTACT	BEIGE	0
1500	FIRST	1114	LINOLEUM FLOOR	SOUTH - C	INTACT	BEIGE	0
1502	FIRST	1114	METAL AIR VENT - CEILING	NORTH - A	INTACT	WHITE	- 0.21
1503	FIRST	1108	WALLBOARD WALL	NORTH - A	INTACT	WHITE	0
1504	FIRST	1108	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	3.7
1506	FIRST	1108	PLASTER WALL	WEST - D	INTACT	WHITE	0
1507	FIRST	1108	LINOLEUM FLOOR	WEST - D	INTACT	BEIGE	3.2
1509	FIRST	CORR. 2	PLASTER WALL	NORTH - A	INTACT	WHITE	0
1510	FIRST	CORR. 2	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	3.7
1511	FIRST	CORR. 2	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	GRAY	0.04
1512	FIRST	CORR. 2	METAL DOOR CASING	WEST - D	INTACT	BLUE	3.3

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1513	FIRST	1103	PLASTER WALL	NORTH - A	Not Intact - POOR	WHITE	0.05
1514	FIRST	1103	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0.01
1515	FIRST	1103	PLASTER WALL	WEST - D	INTACT	WHITE	0
1516	FIRST	1103	WALLBOARD WALL	EAST - B	INTACT	WHITE	0
1517	FIRST	1103	PLASTER X - RAY SHIELD	EAST - B	INTACT	WHITE	0.03
1518	FIRST	1103	PLASTER X - RAY SHIELD	EAST - B	INTACT	WHITE	0.01
1519	FIRST	1103	PLASTER X - RAY SHIELD	EAST - B	INTACT	WHITE	0
1520	FIRST	1103	VFT FLOOR	EAST - B	INTACT	WHITE	17.1
1521	FIRST	1002	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.7
1522	FIRST	1002	METAL CONDUIT	WEST - D	INTACT	WHITE	0.18
1523	FIRST	1002	METAL STAIR STRINGER	SOUTH - C	INTACT	TAN	3.7
1524	FIRST	1002	METAL STAIR RISER	SOUTH - C	Not Intact - POOR	TAN	1.6
1525	FIRST	1002	METAL STAIR TREAD	WEST - D	Not Intact - POOR	BLACK	0.02
1526	FIRST	1002	CONCRETE STAIR TREAD	WEST - D	Not Intact - POOR	YELLOW	0.04
1527	FIRST	1002	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0
1528	FIRST	CORR. 3	PLASTER WALL	EAST - B	INTACT	WHITE	0
1529	FIRST	1125	METAL DOOR CASING	WEST - D	INTACT	BLUE	0
1530	FIRST	1131	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
1531	FIRST	1131	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.01
1532	FIRST	1131	SLATE WINDOW SILL	WEST - D	INTACT	WHITE	0
1533	FIRST	1131	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
1534	FIRST	1131	METAL DOOR	WEST - D	INTACT	GRAY	0
1535	FIRST	1131	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	0.04
1536	FIRST	CORR. 3	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	BLUE	2.1
1537	FIRST	CORR. 3	CONCRETE FIRE EXTINGUISHER CASING	EAST - B	INTACT	GRAY	0.07
1538	FIRST	CORR. 3	METAL PIPE	EAST - B	INTACT	WHITE	0.02
1539	FIRST	1123	METAL DOOR	EAST - B	Not Intact - POOR	GRAY	0
1540	FIRST	1123	METAL DOOR CASING	EAST - B	Not Intact - POOR	GRAY	0.01
1542	FIRST	1123	METAL THRESHOLD	EAST - B	Not Intact - POOR	BLUE	0.12
1543	FIRST	1123	METAL ELECTRICAL BOX MOUNT	WEST - D	INTACT	GRAY	0
1544	FIRST	1123	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0.01

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1545	FIRST	1123	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
1547	FIRST	1123	METAL ELECTRICAL BOX MOUNT	NORTH - A	INTACT	GRAY	0
1548	FIRST	1123	METAL TRANSFORMER	NORTH - A	Not Intact - POOR	GRAY	0.08
1549	FIRST	1122	CERAMIC BLOCK WALL	NORTH - A	INTACT	TAN	0.01
1550	FIRST	1122	CERAMIC BLOCK WALL	EAST - B	INTACT	TAN	0.02
1551	FIRST	1122	CERAMIC BLOCK WALL	SOUTH - C	INTACT	TAN	0.05
1552	FIRST	1122	CERAMIC BLOCK WALL	WEST - D	INTACT	TAN	0.4
1553	FIRST	1122	CONCRETE WALL	SOUTH - C	INTACT	TAN	0.01
1554	FIRST	1122	CONCRETE FLOOR	WEST - D	Not Intact - POOR	GRAY	0.14
1555	FIRST	1122	METAL ELECTRICAL BOX MOUNT	NORTH - A	Not Intact - POOR	GRAY	0.06
1556	FIRST	1122	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
1557	FIRST	1122	METAL CONDUIT	NORTH - A	Not Intact - POOR	TAN	0.09
1558	FIRST	1122	METAL CONDUIT	EAST - B	Not Intact - POOR	TAN	0.04
1559	FIRST	1003	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.09
1560	FIRST	1003	METAL STAIR TREAD	EAST - B	INTACT	STAIN	4
1561	FIRST	1003	METAL STAIR RISER	EAST - B	Not Intact - POOR	YELLOW	1.5
1562	FIRST	1003	CONCRETE STAIR TREAD	EAST - B	Not Intact - POOR	RED	0
1563	FIRST	1003	METAL STAIR TREAD	EAST - B	Not Intact - POOR	BLACK	0.01
1566	FIRST	1003	METAL BASEBOARD	SOUTH - C	Not Intact - POOR	YELLOW	0.06
1567	FIRST	1003	PLASTER CEILING	NORTH - A	INTACT	WHITE	0.03
1568	FIRST	1100	WALLBOARD CEILING	SOUTH - C	INTACT	WHITE	0
1569	FIRST	1100	WALLBOARD CEILING	EAST - B	INTACT	WHITE	0
1570	FIRST	CORR. 4	METAL FIRE EXTINGUISHER CASING	EAST - B	INTACT	WHITE	0
1571	FIRST	CORR. 4	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
1572	FIRST	1237	WALLBOARD WALL	WEST - D	INTACT	WHITE	0
1573	FIRST	1237	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0
1574	FIRST	CORR5	METAL FIREHOSE CLOSET	NORTH - A	INTACT	WHITE	0
1576	FIRST	ELEVATOR LOBBY 1	METAL FIRE EXTINGUISHER CASING	NORTH - A	INTACT	BLUE	2.1
1577	FIRST	ELEVATOR LOBBY 1	CONCRETE FIRE EXTINGUISHER CASING	NORTH - A	INTACT	GRAY	0.05

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1578	FIRST	ELEVATOR LOBBY 1	METAL PIPE	NORTH - A	INTACT	WHITE	0.03
1579	FIRST	ELEVATOR LOBBY 1	METAL PIPE	NORTH - A	INTACT	WHITE	0.08
1580	FIRST	CORR. 6	PLASTER WALL	WEST - D	INTACT	WHITE	2.3
1581	FIRST	CORR. 6	METAL FIRE SPRINKLER PIPE	WEST - D	INTACT	WHITE	0.02
1582	FIRST	1195	METAL AC UNIT	EAST - B	INTACT	WHITE	0
1583	FIRST	1195	METAL DUCT	EAST - B	INTACT	WHITE	0.03
1584	FIRST	1196	METAL DUCT	EAST - B	INTACT	WHITE	0.06
1585	FIRST	1196	METAL AC UNIT	EAST - B	INTACT	WHITE	0
1587	FIRST	1197	METAL AC UNIT	EAST - B	INTACT	WHITE	0.02
1588	FIRST	1197	METAL DUCT	EAST - B	INTACT	WHITE	0.06
1590	FIRST	1200	CERAMIC BLOCK WALL	NORTH - A	INTACT	TAN	0
1591	FIRST	1200	CERAMIC BLOCK WALL	EAST - B	INTACT	TAN	0.21
1592	FIRST	1200	CERAMIC BLOCK WALL	SOUTH - C	INTACT	TAN	0.01
1593	FIRST	1200	CERAMIC BLOCK WALL	WEST - D	INTACT	TAN	0.08
1595	FIRST	1200	CONCRETE WALL	NORTH - A	INTACT	TAN	0.06
1596	FIRST	1200	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	GRAY	0.03
1597	FIRST	1200	METAL DOOR	EAST - B	INTACT	PEACH	0.21
1598	FIRST	1200	METAL CONDUIT	SOUTH - C	INTACT	TAN	0.13
1599	FIRST	1190	METAL DOOR CASING	SOUTH - C	INTACT	BLUE	0
1600	FIRST	1143	METAL DOOR CASING	NORTH - A	INTACT	BLUE	0
1601	FIRST	1189	METAL DOOR CASING	SOUTH - C	INTACT	BLUE	0
1602	FIRST	1001	METAL DOOR CASING	NORTH - A	INTACT	RED	2
1605	FIRST	1001	METAL BASEBOARD	NORTH - A	Not Intact - POOR	YELLOW	- 0.25
1607	FIRST	1001	METAL STAIR BASEBOARD	EAST - B	Not Intact - POOR	YELLOW	2.2
1608	FIRST	1001	METAL STAIR RISER	SOUTH - C	Not Intact - POOR	YELLOW	0.25
1609	FIRST	1001	METAL STAIR TREAD	SOUTH - C	Not Intact - POOR	BLACK	0.04
1610	FIRST	1001	CONCRETE STAIR TREAD	SOUTH - C	Not Intact - POOR	YELLOW	- 0.67
1611	FIRST	1001	CONCRETE FLOOR	NORTH - A	Not Intact - POOR	YELLOW	0.16
1612	FIRST	1001	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.07
1614	FIRST	CORR. 7	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	2.2
1615	FIRST	CORR. 7	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	GRAY	0.07
1616	FIRST	1163	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1617	FIRST	1163	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.3
1618	FIRST	1163	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	0.07
1622	FIRST	1163	SLATE WINDOW SILL	SOUTH - C	INTACT	WHITE	- 0.08
1623	FIRST	1163	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.02
1624	FIRST	1163	METAL DUCT	NORTH - A	INTACT	WHITE	0.05
1625	FIRST	1165	METAL DUCT	NORTH - A	INTACT	WHITE	0.08
1626	FIRST	1165	METAL AC UNIT	NORTH - A	INTACT	WHITE	0.01
1629	FIRST	1165	METAL CEILING	NORTH - A	INTACT	WHITE	0.02
1630	FIRST	1165	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
1631	FIRST	1165	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.05
1632	FIRST	1165	METAL RADIATOR COVER	SOUTH - C	Not Intact - POOR	WHITE	0.13
1633	FIRST	1165	SLATE WINDOW SILL	SOUTH - C	Not Intact - POOR	WHITE	0.06
1634	FIRST	1165	PLASTER CEILING	SOUTH - C	Not Intact - POOR	WHITE	0
1635	FIRST	1165	METAL RADIATOR	SOUTH - C	INTACT	WHITE	0.13
1636	FIRST	1170	METAL AC UNIT	SOUTH - C	INTACT	WHITE	0.03
1637	FIRST	1170	METAL DUCT	SOUTH - C	INTACT	WHITE	0.01
1639	FIRST	1170	METAL CEILING	SOUTH - C	INTACT	WHITE	0.24
1640	FIRST	1170	METAL WINDOW SASH	NORTH - A	INTACT	BLACK	0
1641	FIRST	1170	METAL WINDOW CASING	NORTH - A	INTACT	WHITE	0.02
1643	FIRST	1170	METAL RADIATOR COVER	NORTH - A	INTACT	WHITE	- 0.21
1644	FIRST	1170	SLATE WINDOW SILL	NORTH - A	INTACT	WHITE	0
1645	FIRST	1170	METAL AIR VENT - WALL	SOUTH - C	Not Intact - POOR	WHITE	0.13
1646	FIRST	1170	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0.6
1647	FIRST	CORR. 8	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.02
1649	FIRST	CORR. 8	METAL WINDOW CASING	EAST - B	INTACT	WHITE	0.02
1650	FIRST	CORR. 8	METAL WINDOW SASH	EAST - B	INTACT	BLACK	0
1651	FIRST	CORR. 8	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
1653	FIRST	CORR. 8	SLATE WINDOW SILL	WEST - D	INTACT	WHITE	1.9
1654	FIRST	CORR. 8	SLATE WINDOW SILL	EAST - B	Not Intact - POOR	WHITE	0.07
1655	FIRST	CORR. 8	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.28
1656	FIRST	CORR. 8	METAL RADIATOR COVER	EAST - B	INTACT	WHITE	0.4
1658	FIRST	CORR. 8	PLASTER CEILING	SOUTH - C	INTACT	WHITE	0
1659	FIRST	CORR. 8	PLASTER CEILING	NORTH - A	INTACT	WHITE	0
1660	FIRST	CORR. 8	METAL DOOR	WEST - D	INTACT	BLUE	0
1661	FIRST	CORR. 8	METAL DOOR	EAST - B	INTACT	BLUE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1662	FIRST	CORR. 7	METAL PIPE	SOUTH - C	INTACT	WHITE	0.01
1663	FIRST	CORR. 7	METAL PIPE	SOUTH - C	INTACT	WHITE	0.01
1664	FIRST	1142	METAL HATCH	EAST - B	INTACT	WHITE	0
1665	FIRST	1142	METAL AIR VENT - CEILING	EAST - B	INTACT	WHITE	0.05
1686	GROUND	G001	METAL FIRE SPRINKLER PIPE	NORTH - A	INTACT	RED	0.05
1687	GROUND	G001	METAL DOOR CASING	NORTH - A	INTACT	RED	2.3
1688	GROUND	G001	METAL CONDUIT	EAST - B	INTACT	WHITE	0.18
1689	GROUND	G001	METAL STAIR RISER	SOUTH - C	Not Intact - POOR	TAN	1.8
1690	GROUND	G001	METAL STAIR STRINGER	SOUTH - C	INTACT	TAN	4.3
1691	GROUND	G001	METAL BASEBOARD	NORTH - A	INTACT	TAN	0.13
1692	GROUND	G001	CONCRETE STAIR TREAD	WEST - D	Not Intact - POOR	BEIGE	- 0.09
1693	GROUND	G001	CONCRETE STAIR TREAD	WEST - D	Not Intact - POOR	BLACK	0.01
1694	GROUND	G001	PLASTER CEILING	EAST - B	INTACT	WHITE	0.03
1695	GROUND	G001	PLASTER WALL	EAST - B	INTACT	WHITE	0.1
1696	GROUND	LOBBY 1	CONCRETE WALL	EAST - B	INTACT	WHITE	0
1697	GROUND	LOBBY 1	CONCRETE WALL	WEST - D	INTACT	WHITE	0
1698	GROUND	LOBBY 1	CONCRETE BLOCK WALL	EAST - B	INTACT	WHITE	0
1699	GROUND	LOBBY 1	CONCRETE BLOCK WALL	SOUTH - C	INTACT	WHITE	0
1700	GROUND	LOBBY 1	METAL RADIATOR COVER	EAST - B	INTACT	BLUE	0.01
1701	GROUND	LOBBY 1	METAL DOOR CASING	NORTH - A	INTACT	BLUE	0.01
1702	GROUND	LOBBY 1	METAL DOOR	EAST - B	Not Intact - POOR	BLUE	0
1703	GROUND	LOBBY 1	METAL DOOR	EAST - B	INTACT	BLUE	0
1704	GROUND	LOBBY 1	METAL DOOR	WEST - D	INTACT	BLUE	0.01
1705	GROUND	LOBBY 1	METAL FAN	EAST - B	INTACT	WHITE	0
1706	GROUND	PHARMACY	CONCRETE BLOCK WALL	EAST - B	INTACT	WHITE	0
1707	GROUND	PHARMACY	CONCRETE BLOCK WALL	NORTH - A	INTACT	WHITE	0
1708	GROUND	PHARMACY	METAL ELECTRICAL BOX MOUNT	EAST - B	INTACT	GRAY	0
1709	GROUND	PHARMACY	WALLBOARD WALL	EAST - B	Not Intact - POOR	WHITE	0
1710	GROUND	PHARMACY	METAL ELECTRICAL BOX MOUNT	SOUTH - C	INTACT	GRAY	0
1711	GROUND	PHARMACY	WALLBOARD WALL	SOUTH - C	INTACT	WHITE	0
1712	GROUND	PHARMACY	METAL DOOR	SOUTH - C	INTACT	TAN	0
1713	GROUND	PHARMACY	METAL DOOR CASING	SOUTH - C	INTACT	TAN	0
1714	GROUND	PHARMACY	METAL AIR VENT - CEILING	SOUTH - C	INTACT	WHITE	0
1715	GROUND	PHARMACY	CONCRETE BLOCK WALL	EAST - B	INTACT	WHITE	0

**Table 5 - Summary of XRF Measurements
West Haven VA Medical Center, Building 1**

Reading No.	Floor	Location	Substrate And Component	Side	Condition	Color	Results (mg/cm ²)
1717	GROUND	PHARMACY	CONCRETE BLOCK WALL	SOUTH - C	INTACT	WHITE	0
1718	GROUND	PHARMACY	CONCRETE BLOCK WALL	NORTH - A	Not Intact - POOR	WHITE	0
1719	GROUND	PHARMACY	METAL CONDUIT	WEST - D	INTACT	BEIGE	0
1721	GROUND	CORR. 1	METAL FIRE EXTINGUISHER CASING	SOUTH - C	INTACT	BLUE	3.7
1722	GROUND	CORR. 1	CONCRETE FIRE EXTINGUISHER CASING	SOUTH - C	Not Intact - POOR	BLACK	0.07
1723	GROUND	CORR. 1	METAL PIPE	SOUTH - C	INTACT	WHITE	0.02
1724	GROUND	CORR. 2	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0
1725	GROUND	CORR. 2	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.05
1726	GROUND	CORR. 2	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	- 0.01
1727	GROUND	CORR. 2	METAL DOOR CASING	WEST - D	INTACT	BLUE	0
1729	GROUND	CORR. 2	METAL CEILING	WEST - D	Not Intact - POOR	WHITE	0
1730	GROUND	CORR. 2	METAL HATCH	WEST - D	INTACT	WHITE	0
1731	GROUND	CORR. 2	METAL PIPE	EAST - B	INTACT	WHITE	0
1732	GROUND	CORR. 2	METAL AC UNIT	EAST - B	INTACT	WHITE	0.03
1733	GROUND	CORR. 2	METAL AIR VENT - WALL	EAST - B	INTACT	WHITE	0.05
1734	GROUND	CORR. 2	METAL DUCT	EAST - B	INTACT	WHITE	0.07
1735	GROUND	CORR. 2	METAL RADIATOR COVER	SOUTH - C	INTACT	WHITE	- 0.06
1736	GROUND	CORR. 2	METAL WINDOW CASING	SOUTH - C	INTACT	WHITE	0.02
1737	GROUND	CORR. 2	METAL WINDOW SASH	SOUTH - C	INTACT	BLACK	0.01
1738	GROUND	CORR. 2	SLATE WINDOW SILL	SOUTH - C	INTACT	WHITE	- 0.09
1739	GROUND	CORR. 2	METAL DOOR	WEST - D	Not Intact - POOR	GRAY	0
1741	GROUND	G208	METAL AC UNIT	EAST - B	Not Intact - POOR	WHITE	0.03
1742	GROUND	G208	METAL DUCT	EAST - B	Not Intact - POOR	WHITE	0.03
1744	GROUND	G208	METAL RADIATOR COVER	WEST - D	INTACT	WHITE	- 0.2
1745	GROUND	G208	METAL WINDOW CASING	WEST - D	INTACT	WHITE	0.02
1746	GROUND	G208	METAL WINDOW SASH	WEST - D	INTACT	BLACK	0
1747	GROUND	G208	SLATE WINDOW SILL	WEST - D	INTACT	WHITE	0
1748	GROUND	G208	PLASTER CEILING	EAST - B	INTACT	WHITE	0
1749	GROUND	CORR. 2	METAL FIRE EXTINGUISHER CASING	WEST - D	INTACT	BLUE	1.7
1750	GROUND	CORR. 2	CONCRETE FIRE EXTINGUISHER CASING	WEST - D	INTACT	GRAY	0.06
1751	GROUND	CORR. 2	METAL PIPE	WEST - D	INTACT	WHITE	0.02